



25800 Commercentre Drive
Lake Forest, CA 92630 USA

Telephone: 949.448.4100
Facsimile: 949.448.4111
www.intertek.com

Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address:	IronRidge, Inc. 1495 Zephyr Ave. Hayward, CA 94544
Product Description:	XR Rails with Integrated Grounding.
Ratings & Principle Characteristics:	<u>Fire Class Resistance Rating:</u> <ul style="list-style-type: none"> - Class A for Steep Slope Flush-Mount (symmetrical) Applications when using Type 1 and Type 2, Listed Photovoltaic Module. - Class A for Low Slope Flush-Mount and Tilt-Mount (symmetrical and asymmetrical) Applications when using Type 1, Listed Photovoltaic Module.
Models:	51-61GD-005, 51-61GD-005B, 51-5000-001, and 51-65-001
Brand Name:	N/A
Relevant Standards:	UL Subject 2703 (Section 15.2 and 15.3) Outline of Investigation for Rack Mounting Systems and Clamping Devices for Flat-Plate Photovoltaic Modules and Panels, Issue Number: 2, Nov 13, 2012 Referencing UL1703 (Section 31.2) Standard for Safety for Flat-Plate Photovoltaic Modules and Panels, May 20, 2014
Verification Issuing Office:	Intertek Testing Services NA, Inc. 25800 Commercentre Dr. Lake Forest, CA 92630
Date of Tests:	08/27/2014 to 01/07/2015
Test Report Number(s):	101541132LAX-002

This verification is part of the full test report(s) and should be read in conjunction with them. This report does not automatically imply product certification.

Completed by: Amar Kacel
Title: PV Engineer

Reviewed by: Andrew Koretoff
Title: Reviewer

Signature: 

Signature: 

Date: 01/26/2015

Date: 01/26/2015

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.