

January 29, 2021

Attn: Mr. Marshall Green
Quick Mount PV
2700 Mitchell Dr.
Walnut Creek, CA, 94598

RE: Quick Mount PV – QRail Standard
PV Panel Racking System
State of Florida Certification Letter

SEI Project No.: 19585.00

Dear Mr. Green:

Structural Engenuity Inc. (SEI) has completed its review of the Quick Mount PV – QRail Standard PV Panel Racking System (QMR-RS) for typical installations in the state of Florida. The QRail Standard is compliant with the sections of the following design references and codes when installed per the conditions and design criteria delineated herein.

Design References and Codes:

- 2015 Aluminum Design Manual, by the Aluminum Association
- Materials information and section and details provided by Quick Mount PV as appendages to this letter
- 2012 & 2015 International Building Code
- 2012, 2015, & 2018 International Residential Code
- 2020 Florida Residential Code (7th Edition)
- AC428, Acceptance Criteria for Modular Framing Systems Used to Support Photovoltaic (PV) Modules, November 2012 by ICC-ES

General Mounting System and Analysis Overview:

The QRail Standard consists of 6005-T5 (acceptable alternative materials include 6005A-T61 and 6061-T6) extruded aluminum per ASTM B221-08. The rails are used in pairs to support photovoltaic solar panels in order to span between points of attachment to the existing roof structure. The following tables and information summarize the structural analysis performed by SEI in order to certify the QRail Standard for the state noted above.

The analysis for certification included the following parameters for each rail system.

QRail Standard:

- Risk Category II
- Roof Slopes up to 45 degrees
- Portrait & Landscape orientation of photovoltaic panels
- Max Module Dimensions = Varies, see tables
- Max Mean Roof Height = Varies, see tables (If roof slope < 10°, use eave height)

1815 W. Diehl Rd, Suite 100, Naperville, IL 60563
630-219-1997 (P)
www.structuralengenuityinc.com


- Wind Analysis:
 - o Wind Category: B, C, and D
 - o Roof Zones 1, 2, and 3
 - o Wind Directionality Factor (K_d) = 0.85
 - o Topographic Factor (K_{zt}) = 1
- Snow Analysis:
 - o Snow Exposure Factor (C_e) = 1.0
 - o Thermal Factor (C_t) = 1.2
 - o Slope Factor (C_s) varies depending on roof slope
 - o Importance Factor (I_s) = 1
- Seismic Analysis:
 - o Seismic Design Category E or less (S_d = 2.0 max)
 - o Importance Factor (I_p) = 1
 - o Amplification Factor (a_p) = 1.0 per ICC-AC428
 - o Component Response Modification Factor (R_p) = 1.5 per ICC-AC 428

Applicable loading combinations consisting of dead, wind, snow, and seismic loads in accordance with the governing code requirements were used to determine allowable rail span lengths, based on bending stress capacity, shear capacity, axial capacity, and an assumption of a single-span condition with an allowable deflection of $L/60$. Design wind pressures were determined using Components and Cladding calculations per the applicable building or residential code in conjunction with the loading parameters noted above. Applicable roof snow load shall be based on ground snow load maps, equations, and factors per the design code for the location of the project in combination with the loading parameters noted above.

It should be noted that the analysis was limited to the capacity of the QRail Standard. Attachments of the rail to the roof structure and analysis of the roof structure itself shall be the responsibility of the installer, and should be reviewed and approved by a registered design professional where required by the local authority having jurisdiction.

Installation Notes:

The QRail Standard shall be installed with the following guidelines to be in compliance with attached span tables:

- Tables noted below assume two support rails are being used per each row of photovoltaic modules in a roof solar array.
- Rails shall be continuous and not spliced over a minimum of 2 supports except for span lengths shaded with  In these cases it is acceptable to use a minimum of 1 support per rail section as long as all supports are located at a maximum of 48" on center and the first and last rail sections have a minimum of 2 supports.
- System shall be mounted parallel to roof surface with a 2" to 10" gap between roof surface and bottom of module.
- Installation over roof overhangs or within 10" of any roof edge is not recommended
- Maximum end cantilever of aluminum support rail shall not exceed 1/3 of allowable span in the roof wind pressure zone of the cantilever.
- Tables attached are limited to structural capability of the support rails only; therefore, observe all local jurisdiction requirements regarding roof setback requirements when laying out support rails and solar array.

- Actual span lengths used must be within capacity of roof attachment and structural capacity of roof member supporting solar array.

Conclusion and Certification Summary:

Based on the structural analysis performed by SEI in regards to the loading parameters specified above for QRail Standard, the following C1 through C57 QRail Span tables for the Quick Mount PV QRail Standard System were determined. The various span information is controlled by the applicable wind and snow loads to the structure to which the array is being mounted on the roof and based on the roof zone to which the array is installed on the roof. The tables allow for multiple panel sizes and orientations as follows:

Tables 1-6: 15 ft max mean roof height, panels in portrait orientation with a maximum length of 67.5"

Tables 7-12: 15 ft max mean roof height, panels in landscape orientation with a maximum width of 42"

Tables 13-21: 30 ft max mean roof height, panels in portrait orientation with a maximum length of 67.5"

Tables 22-30: 30 ft max mean roof height, panels in landscape orientation with a maximum width of 42"

Tables 31-39: 60 ft max mean roof height, panels in portrait orientation with a maximum length of 67.5"

Tables 40-48: 60 ft max mean roof height, panels in landscape orientation with a maximum width of 42"


Tables 49-57: 60 ft max mean roof height, panels in portrait orientation with a maximum length of 82"

Tables 58-66: 30 ft max mean roof height, panels in portrait orientation with a maximum length of 80"

This letter is to certify that the loading criteria and design basis used for the structural analysis of the QRail Standard PV Panel Racking System for the span tables attached is validated and performed in compliance with the applicable design codes noted previously.

Please contact our office if you have any further questions relating to this matter.

Sincerely,



Peter Martin
Engineer III

pmartin@structuralenginuityinc.com



Allan T. Myket, P.E.
President/Founder

amyket@structuralenginuityinc.com


01/29/2021
FL COA No. 30952
Licensee Name: Allan T. Myket
Registration No. 77857

Structural Enginuity Inc.

THIS ITEM HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY ALLAN T. MYKET,
PE ON 01/29/2021 USING A DIGITAL SIGNATURE.

PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND
SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

1815 W. Diehl Rd, Suite 100, Naperville, IL 60563
630-219-1997 (P)
www.structuralenginuityinc.com



Rail Spans for Quick Mount PV QRail Standard System

Table 1		Mean Roof Height: 0 < h ≤ 15 ft							Panel Orientation: Portrait				
		Roof Angle: 0 < θ ≤ 7 degrees							Exposure Category: C				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	116	116	114	104	95	89	82	77	75	73	69
	10	102	102	102	101	100	95	89	82	77	75	73	69
	20	86	86	86	86	86	86	86	82	77	75	73	69
	30	74	74	74	74	74	74	74	74	74	73	73	69
	40	65	65	65	65	65	65	65	65	65	65	65	65
	50	59	59	59	59	59	59	59	59	59	59	59	59
	60	54	54	54	54	54	54	54	54	54	54	54	54
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 2	0	100	90	86	82	75	69	65	60	57	55	53	50
	10	100	90	86	82	75	69	65	60	57	55	53	50
	20	86	86	86	82	75	69	65	60	57	55	53	50
	30	74	74	74	74	74	69	65	60	57	55	53	50
	40	65	65	65	65	65	65	65	60	57	55	53	50
	50	59	59	59	59	59	59	59	59	57	55	53	50
	60	54	54	54	54	54	54	54	54	54	54	53	50
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 3	0	79	72	68	65	59	55	51	48	45	44	42	40
	10	79	72	68	65	59	55	51	48	45	44	42	40
	20	79	72	68	65	59	55	51	48	45	44	42	40
	30	74	72	68	65	59	55	51	48	45	44	42	40
	40	65	65	65	65	59	55	51	48	45	44	42	40
	50	59	59	59	59	59	55	51	48	45	44	42	40
	60	54	54	54	54	54	54	51	48	45	44	42	40
	70	50	50	50	50	50	50	50	48	45	44	42	40
	80	48	48	48	48	48	48	48	48	45	44	42	40
	90	44	44	44	44	44	44	44	44	44	44	42	40

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 2		Mean Roof Height: 0 < h ≤ 15 ft						Panel Orientation: Portrait					
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	112	107	102	93	86	80	74	70	68	66	62
	10	102	101	101	100	93	86	80	74	70	68	66	62
	20	86	86	86	86	86	85	80	74	70	68	66	62
	30	74	74	74	74	74	74	74	73	70	68	66	62
	40	65	65	65	65	65	65	65	65	65	65	65	62
	50	59	59	59	59	59	59	59	59	59	59	59	59
	60	54	54	54	54	54	54	54	54	54	54	54	54
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 2	0	90	81	77	74	68	63	58	55	51	50	48	46
	10	90	81	77	74	68	63	58	55	51	50	48	46
	20	86	81	77	74	68	63	58	55	51	50	48	46
	30	74	74	74	74	68	63	58	55	51	50	48	46
	40	65	65	65	65	65	63	58	55	51	50	48	46
	50	59	59	59	59	59	59	58	55	51	50	48	46
	60	54	54	54	54	54	54	54	54	51	50	48	46
	70	50	50	50	50	50	50	50	50	50	50	48	46
	80	48	48	48	48	48	48	48	48	48	48	48	46
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 3	0	72	64	61	58	54	50	46	43	41	40	38	36
	10	72	64	61	58	54	50	46	43	41	40	38	36
	20	72	64	61	58	54	50	46	43	41	40	38	36
	30	72	64	61	58	54	50	46	43	41	40	38	36
	40	65	64	61	58	54	50	46	43	41	40	38	36
	50	59	59	59	58	54	50	46	43	41	40	38	36
	60	54	54	54	54	54	50	46	43	41	40	38	36
	70	50	50	50	50	50	50	46	43	41	40	38	36
	80	48	48	48	48	48	48	46	43	41	40	38	36
	90	44	44	44	44	44	44	44	43	41	40	38	36

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 3		Mean Roof Height: 0 < h ≤ 15 ft						Panel Orientation: Portrait					
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	116	114	112	106	98	91	85	80	78	75	72
	10	99	97	96	95	92	90	87	85	80	78	75	72
	20	80	80	80	79	78	76	75	73	72	72	72	69
	30	67	67	67	67	67	67	67	66	64	64	63	62
	40	59	59	59	59	59	59	59	59	59	58	58	57
	50	54	54	54	54	54	54	54	54	54	54	54	53
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 2	0	100	90	86	83	76	70	66	61	58	56	54	51
	10	99	90	86	83	76	70	66	61	58	56	54	51
	20	80	80	80	79	76	70	66	61	58	56	54	51
	30	67	67	67	67	67	67	66	61	58	56	54	51
	40	59	59	59	59	59	59	59	59	58	56	54	51
	50	54	54	54	54	54	54	54	54	54	54	54	51
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 3	0	80	73	69	66	61	57	53	49	46	45	44	41
	10	80	73	69	66	61	57	53	49	46	45	44	41
	20	80	73	69	66	61	57	53	49	46	45	44	41
	30	67	67	67	66	61	57	53	49	46	45	44	41
	40	59	59	59	59	59	57	53	49	46	45	44	41
	50	54	54	54	54	54	54	53	49	46	45	44	41
	60	49	49	49	49	49	49	49	49	46	45	44	41
	70	46	46	46	46	46	46	46	46	46	45	44	41
	80	43	43	43	43	43	43	43	43	43	43	43	41
	90	41	41	41	41	41	41	41	41	41	41	41	41

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 4		Mean Roof Height: 0 < h ≤ 15 ft						Panel Orientation: Portrait					
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	111	109	104	96	89	83	77	72	70	68	65
	10	97	94	93	92	89	87	83	77	72	70	68	65
	20	80	79	78	78	76	74	73	72	69	69	68	65
	30	67	67	67	67	67	66	65	64	63	62	61	60
	40	59	59	59	59	59	59	59	58	57	57	57	56
	50	54	54	54	54	54	54	54	54	53	53	53	52
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 2	0	90	82	78	75	69	64	59	56	52	51	49	48
	10	90	82	78	75	69	64	59	56	52	51	49	48
	20	80	79	78	75	69	64	59	56	52	51	49	48
	30	67	67	67	67	67	64	59	56	52	51	49	48
	40	59	59	59	59	59	59	59	56	52	51	49	48
	50	54	54	54	54	54	54	54	54	52	51	49	48
	60	49	49	49	49	49	49	49	49	49	49	49	48
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 3	0	73	66	63	60	55	51	48	45	42	41	40	38
	10	73	66	63	60	55	51	48	45	42	41	40	38
	20	73	66	63	60	55	51	48	45	42	41	40	38
	30	67	66	63	60	55	51	48	45	42	41	40	38
	40	59	59	59	59	55	51	48	45	42	41	40	38
	50	54	54	54	54	54	51	48	45	42	41	40	38
	60	49	49	49	49	49	49	48	45	42	41	40	38
	70	46	46	46	46	46	46	46	45	42	41	40	38
	80	43	43	43	43	43	43	43	43	42	41	40	38
	90	41	41	41	41	41	41	41	41	41	41	40	38

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 5		Mean Roof Height: 0 < h ≤ 15 ft						Panel Orientation: Portrait					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	106	100	97	94	88	84	79	75	72	70	68	65
	10	94	91	89	87	84	81	78	75	72	70	68	65
	20	82	79	78	77	75	72	70	68	66	65	64	62
	30	73	72	70	70	68	66	64	63	61	60	60	58
	40	65	65	65	64	63	61	60	59	57	57	56	55
	50	59	59	59	59	58	57	56	55	54	53	53	52
	60	55	55	55	55	55	54	53	52	51	51	50	49
	70	51	51	51	51	51	51	51	50	49	48	48	48
	80	48	48	48	48	48	48	48	48	48	46	46	45
	90	45	45	45	45	45	45	45	45	45	45	44	44
Zone 2	0	106	100	97	94	88	83	77	72	68	66	64	61
	10	94	91	89	87	84	81	77	72	68	66	64	61
	20	82	79	78	77	75	72	70	68	66	65	64	61
	30	73	72	70	70	68	66	64	63	61	60	60	58
	40	65	65	65	64	63	61	60	59	57	57	56	55
	50	59	59	59	59	58	57	56	55	54	53	53	52
	60	55	55	55	55	55	54	53	52	51	51	50	49
	70	51	51	51	51	51	51	51	50	49	48	48	48
	80	48	48	48	48	48	48	48	48	48	46	46	45
	90	45	45	45	45	45	45	45	45	45	45	44	44
Zone 3	0	106	100	97	94	88	83	77	72	68	66	64	61
	10	94	91	89	87	84	81	77	72	68	66	64	61
	20	82	79	78	77	75	72	70	68	66	65	64	61
	30	73	72	70	70	68	66	64	63	61	60	60	58
	40	65	65	65	64	63	61	60	59	57	57	56	55
	50	59	59	59	59	58	57	56	55	54	53	53	52
	60	55	55	55	55	55	54	53	52	51	51	50	49
	70	51	51	51	51	51	51	51	50	49	48	48	48
	80	48	48	48	48	48	48	48	48	48	46	46	45
	90	45	45	45	45	45	45	45	45	45	45	44	44

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 6		Mean Roof Height: 0 < h ≤ 15 ft						Panel Orientation: Portrait					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	99	93	90	87	82	78	73	70	66	64	63	60
	10	91	87	85	83	80	77	73	70	66	64	63	60
	20	79	77	75	74	72	69	67	65	63	61	60	58
	30	72	69	68	68	66	64	62	60	58	58	57	55
	40	65	64	63	62	61	59	58	56	55	54	54	52
	50	59	59	59	58	57	56	55	53	52	51	51	50
	60	55	55	55	55	54	53	52	51	50	49	49	48
	70	51	51	51	51	51	50	49	48	48	48	46	46
	80	48	48	48	48	48	48	48	46	45	45	45	44
	90	45	45	45	45	45	45	45	45	44	43	43	42
Zone 2	0	99	93	90	87	81	75	70	66	62	60	58	55
	10	91	87	85	83	80	75	70	66	62	60	58	55
	20	79	77	75	74	72	69	67	65	62	60	58	55
	30	72	69	68	68	66	64	62	60	58	58	57	55
	40	65	64	63	62	61	59	58	56	55	54	54	52
	50	59	59	59	58	57	56	55	53	52	51	51	50
	60	55	55	55	55	54	53	52	51	50	49	49	48
	70	51	51	51	51	51	50	49	48	48	48	46	46
	80	48	48	48	48	48	48	48	46	45	45	45	44
	90	45	45	45	45	45	45	45	45	44	43	43	42
Zone 3	0	99	93	90	87	81	75	70	66	62	60	58	55
	10	91	87	85	83	80	75	70	66	62	60	58	55
	20	79	77	75	74	72	69	67	65	62	60	58	55
	30	72	69	68	68	66	64	62	60	58	58	57	55
	40	65	64	63	62	61	59	58	56	55	54	54	52
	50	59	59	59	58	57	56	55	53	52	51	51	50
	60	55	55	55	55	54	53	52	51	50	49	49	48
	70	51	51	51	51	51	50	49	48	48	48	46	46
	80	48	48	48	48	48	48	48	46	45	45	45	44
	90	45	45	45	45	45	45	45	45	44	43	43	42

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 7		Mean Roof Height: 0 < h ≤ 15 ft						Panel Orientation: Landscape					
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	121	121	112	105	98	95	92	87
	10	120	120	119	119	117	116	112	105	98	95	92	87
	20	101	101	101	101	101	101	101	101	98	95	92	87
	30	90	90	90	90	90	90	90	90	90	90	90	87
	40	82	82	82	82	82	82	82	82	82	82	82	82
	50	74	74	74	74	74	74	74	74	74	74	74	74
	60	68	68	68	68	68	68	68	68	68	68	68	68
	70	64	64	64	64	64	64	64	64	64	64	64	64
	80	60	60	60	60	60	60	60	60	60	60	60	60
	90	56	56	56	56	56	56	56	56	56	56	56	56
Zone 2	0	121	114	109	104	95	88	82	77	72	70	68	64
	10	120	114	109	104	95	88	82	77	72	70	68	64
	20	101	101	101	101	95	88	82	77	72	70	68	64
	30	90	90	90	90	90	88	82	77	72	70	68	64
	40	82	82	82	82	82	82	82	77	72	70	68	64
	50	74	74	74	74	74	74	74	74	72	70	68	64
	60	68	68	68	68	68	68	68	68	68	68	68	64
	70	64	64	64	64	64	64	64	64	64	64	64	64
	80	60	60	60	60	60	60	60	60	60	60	60	60
	90	56	56	56	56	56	56	56	56	56	56	56	56
Zone 3	0	100	90	86	82	76	70	65	61	57	55	54	51
	10	100	90	86	82	76	70	65	61	57	55	54	51
	20	100	90	86	82	76	70	65	61	57	55	54	51
	30	90	90	86	82	76	70	65	61	57	55	54	51
	40	82	82	82	82	76	70	65	61	57	55	54	51
	50	74	74	74	74	74	70	65	61	57	55	54	51
	60	68	68	68	68	68	68	65	61	57	55	54	51
	70	64	64	64	64	64	64	64	61	57	55	54	51
	80	60	60	60	60	60	60	60	60	57	55	54	51
	90	56	56	56	56	56	56	56	56	56	55	54	51

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 8		Mean Roof Height: 0 < h ≤ 15 ft					Panel Orientation: Landscape							
		Roof Angle: 0 < θ ≤ 7 degrees												
		Exposure Category: D												
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)												
		100	110	115	120	130	140	150	160	170	175	180	190	
Zone 1	0	121	121	121	121	118	109	101	94	89	86	83	79	
	10	120	119	118	117	116	109	101	94	89	86	83	79	
	20	101	101	101	101	101	101	100	94	89	86	83	79	
	30	90	90	90	90	90	90	90	90	89	86	83	79	
	40	82	82	82	82	82	82	82	82	82	82	82	79	
	50	74	74	74	74	74	74	74	74	74	74	74	74	
	60	68	68	68	68	68	68	68	68	68	68	68	68	
	70	64	64	64	64	64	64	64	64	64	64	64	64	
	80	60	60	60	60	60	60	60	60	60	60	60	60	
	90	56	56	56	56	56	56	56	56	56	56	56	56	
Zone 2	0	114	103	98	94	86	80	74	69	65	63	61	58	
	10	114	103	98	94	86	80	74	69	65	63	61	58	
	20	101	101	98	94	86	80	74	69	65	63	61	58	
	30	90	90	90	90	86	80	74	69	65	63	61	58	
	40	82	82	82	82	82	80	74	69	65	63	61	58	
	50	74	74	74	74	74	74	74	69	65	63	61	58	
	60	68	68	68	68	68	68	68	68	65	63	61	58	
	70	64	64	64	64	64	64	64	64	64	63	61	58	
	80	60	60	60	60	60	60	60	60	60	60	60	58	
	90	56	56	56	56	56	56	56	56	56	56	56	56	
Zone 3	0	90	81	78	74	68	63	59	55	52	50	49	46	
	10	90	81	78	74	68	63	59	55	52	50	49	46	
	20	90	81	78	74	68	63	59	55	52	50	49	46	
	30	90	81	78	74	68	63	59	55	52	50	49	46	
	40	82	81	78	74	68	63	59	55	52	50	49	46	
	50	74	74	74	74	68	63	59	55	52	50	49	46	
	60	68	68	68	68	68	63	59	55	52	50	49	46	
	70	64	64	64	64	64	63	59	55	52	50	49	46	
	80	60	60	60	60	60	60	59	55	52	50	49	46	
	90	56	56	56	56	56	56	56	55	52	50	49	46	

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 9		Mean Roof Height: 0 < h ≤ 15 ft						Panel Orientation: Landscape					
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	121	121	116	108	102	99	96	91
	10	119	117	116	115	113	111	109	107	102	99	96	91
	20	101	101	101	101	99	97	95	93	91	90	90	88
	30	86	86	86	86	86	86	85	83	82	81	81	79
	40	75	75	75	75	75	75	75	75	75	74	74	73
	50	68	68	68	68	68	68	68	68	68	68	68	68
	60	63	63	63	63	63	63	63	63	63	63	63	63
	70	58	58	58	58	58	58	58	58	58	58	58	58
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 2	0	121	115	110	105	97	89	83	78	73	72	69	65
	10	119	115	110	105	97	89	83	78	73	72	69	65
	20	101	101	101	101	97	89	83	78	73	72	69	65
	30	86	86	86	86	86	86	83	78	73	72	69	65
	40	75	75	75	75	75	75	75	75	73	72	69	65
	50	68	68	68	68	68	68	68	68	68	68	68	65
	60	63	63	63	63	63	63	63	63	63	63	63	63
	70	58	58	58	58	58	58	58	58	58	58	58	58
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 3	0	102	92	88	84	78	72	67	63	59	57	56	53
	10	102	92	88	84	78	72	67	63	59	57	56	53
	20	101	92	88	84	78	72	67	63	59	57	56	53
	30	86	86	86	84	78	72	67	63	59	57	56	53
	40	75	75	75	75	75	72	67	63	59	57	56	53
	50	68	68	68	68	68	68	67	63	59	57	56	53
	60	63	63	63	63	63	63	63	63	59	57	56	53
	70	58	58	58	58	58	58	58	58	58	57	56	53
	80	55	55	55	55	55	55	55	55	55	55	55	53
	90	52	52	52	52	52	52	52	52	52	52	52	52

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 10		Mean Roof Height: 0 < h ≤ 15 ft						Panel Orientation: Landscape					
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	121	113	105	98	92	89	87	82
	10	117	115	114	113	111	108	105	98	92	89	87	82
	20	101	100	99	98	96	94	92	90	88	87	86	82
	30	86	86	86	86	85	84	83	81	80	79	78	77
	40	75	75	75	75	75	75	75	74	73	72	72	72
	50	68	68	68	68	68	68	68	68	68	67	67	66
	60	63	63	63	63	63	63	63	63	63	63	63	62
	70	58	58	58	58	58	58	58	58	58	58	58	58
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 2	0	115	104	99	95	87	81	75	72	66	64	63	59
	10	115	104	99	95	87	81	75	72	66	64	63	59
	20	101	100	99	95	87	81	75	72	66	64	63	59
	30	86	86	86	86	85	81	75	72	66	64	63	59
	40	75	75	75	75	75	75	75	72	66	64	63	59
	50	68	68	68	68	68	68	68	68	66	64	63	59
	60	63	63	63	63	63	63	63	63	63	63	63	59
	70	58	58	58	58	58	58	58	58	58	58	58	58
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 3	0	92	83	80	76	70	65	61	57	53	52	50	48
	10	92	83	80	76	70	65	61	57	53	52	50	48
	20	92	83	80	76	70	65	61	57	53	52	50	48
	30	86	83	80	76	70	65	61	57	53	52	50	48
	40	75	75	75	75	70	65	61	57	53	52	50	48
	50	68	68	68	68	68	65	61	57	53	52	50	48
	60	63	63	63	63	63	63	61	57	53	52	50	48
	70	58	58	58	58	58	58	58	57	53	52	50	48
	80	55	55	55	55	55	55	55	55	53	52	50	48
	90	52	52	52	52	52	52	52	52	52	52	50	48

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 11		Mean Roof Height: 0 < h ≤ 15 ft							Panel Orientation: Landscape				
		Roof Angle: 27 < θ ≤ 45 degrees							Exposure Category: C				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	119	116	112	106	101	96	91	89	87	83
	10	119	115	113	111	107	103	99	95	91	89	87	83
	20	104	101	99	98	95	92	89	86	84	82	81	79
	30	93	91	89	88	86	84	82	80	78	77	76	74
	40	83	83	82	81	80	78	76	74	73	72	72	69
	50	75	75	75	75	74	73	72	70	69	68	67	66
	60	69	69	69	69	69	69	68	66	65	64	64	63
	70	65	65	65	65	65	65	64	63	62	62	61	60
	80	61	61	61	61	61	61	61	60	59	59	58	58
	90	58	58	58	58	58	58	58	58	57	57	56	55
Zone 2	0	121	121	119	116	112	105	98	92	86	84	82	77
	10	119	115	113	111	107	103	98	92	86	84	82	77
	20	104	101	99	98	95	92	89	86	84	82	81	77
	30	93	91	89	88	86	84	82	80	78	77	76	74
	40	83	83	82	81	80	78	76	74	73	72	72	69
	50	75	75	75	75	74	73	72	70	69	68	67	66
	60	69	69	69	69	69	69	68	66	65	64	64	63
	70	65	65	65	65	65	65	64	63	62	62	61	60
	80	61	61	61	61	61	61	61	60	59	59	58	58
	90	58	58	58	58	58	58	58	58	57	57	56	55
Zone 3	0	121	121	119	116	112	105	98	92	86	84	82	77
	10	119	115	113	111	107	103	98	92	86	84	82	77
	20	104	101	99	98	95	92	89	86	84	82	81	77
	30	93	91	89	88	86	84	82	80	78	77	76	74
	40	83	83	82	81	80	78	76	74	73	72	72	69
	50	75	75	75	75	74	73	72	70	69	68	67	66
	60	69	69	69	69	69	69	68	66	65	64	64	63
	70	65	65	65	65	65	65	64	63	62	62	61	60
	80	61	61	61	61	61	61	61	60	59	59	58	58
	90	58	58	58	58	58	58	58	58	57	57	56	55

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 12		Mean Roof Height: 0 < h ≤ 15 ft							Panel Orientation: Landscape				
		Roof Angle: 27 < θ ≤ 45 degrees							Exposure Category: D				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	116	113	111	104	98	93	88	84	82	80	76
	10	115	110	108	106	101	97	93	88	84	82	80	76
	20	101	97	96	94	91	88	85	82	79	78	77	74
	30	91	88	87	86	83	81	79	76	74	73	72	70
	40	83	81	80	79	77	75	74	72	70	69	68	66
	50	75	75	75	74	72	72	69	68	66	65	65	63
	60	69	69	69	69	68	67	66	64	63	62	62	60
	70	65	65	65	65	65	64	63	61	60	60	59	58
	80	61	61	61	61	61	61	60	59	58	57	57	56
	90	58	58	58	58	58	58	58	57	56	55	55	54
Zone 2	0	121	116	113	111	102	95	89	83	78	76	74	70
	10	115	110	108	106	101	95	89	83	78	76	74	70
	20	101	97	96	94	91	88	85	82	78	76	74	70
	30	91	88	87	86	83	81	79	76	74	73	72	70
	40	83	81	80	79	77	75	74	72	70	69	68	66
	50	75	75	75	74	72	72	69	68	66	65	65	63
	60	69	69	69	69	68	67	66	64	63	62	62	60
	70	65	65	65	65	65	64	63	61	60	60	59	58
	80	61	61	61	61	61	61	60	59	58	57	57	56
	90	58	58	58	58	58	58	58	57	56	55	55	54
Zone 3	0	121	116	113	111	102	95	89	83	78	76	74	70
	10	115	110	108	106	101	95	89	83	78	76	74	70
	20	101	97	96	94	91	88	85	82	78	76	74	70
	30	91	88	87	86	83	81	79	76	74	73	72	70
	40	83	81	80	79	77	75	74	72	70	69	68	66
	50	75	75	75	74	72	72	69	68	66	65	65	63
	60	69	69	69	69	68	67	66	64	63	62	62	60
	70	65	65	65	65	65	64	63	61	60	60	59	58
	80	61	61	61	61	61	61	60	59	58	57	57	56
	90	58	58	58	58	58	58	58	57	56	55	55	54

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 13		Mean Roof Height: 0 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 0 < θ ≤ 7 degrees							Exposure Category: B				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	116	116	116	116	106	99	92	86	83	81	76
	10	102	102	102	102	102	101	99	92	86	83	81	76
	20	86	86	86	86	86	86	86	86	85	83	81	76
	30	74	74	74	74	74	74	74	74	74	74	74	73
	40	65	65	65	65	65	65	65	65	65	65	65	65
	50	59	59	59	59	59	59	59	59	59	59	59	59
	60	54	54	54	54	54	54	54	54	54	54	54	54
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 2	0	112	100	95	91	83	77	72	67	63	61	59	56
	10	102	100	95	91	83	77	72	67	63	61	59	56
	20	86	86	86	86	83	77	72	67	63	61	59	56
	30	74	74	74	74	74	74	72	67	63	61	59	56
	40	65	65	65	65	65	65	65	65	63	61	59	56
	50	59	59	59	59	59	59	59	59	59	59	59	56
	60	54	54	54	54	54	54	54	54	54	54	54	54
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 3	0	87	79	75	72	66	61	57	53	50	48	48	44
	10	87	79	75	72	66	61	57	53	50	48	48	44
	20	86	79	75	72	66	61	57	53	50	48	48	44
	30	74	74	74	72	66	61	57	53	50	48	48	44
	40	65	65	65	65	65	61	57	53	50	48	48	44
	50	59	59	59	59	59	59	57	53	50	48	48	44
	60	54	54	54	54	54	54	54	53	50	48	48	44
	70	50	50	50	50	50	50	50	50	50	48	48	44
	80	48	48	48	48	48	48	48	48	48	48	48	44
	90	44	44	44	44	44	44	44	44	44	44	44	44

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 14		Mean Roof Height: 15 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	116	110	105	96	88	82	76	72	69	67	64
	10	102	102	101	100	96	88	82	76	72	69	67	64
	20	86	86	86	86	86	86	82	76	72	69	67	64
	30	74	74	74	74	74	74	74	73	72	69	67	64
	40	65	65	65	65	65	65	65	65	65	65	65	64
	50	59	59	59	59	59	59	59	59	59	59	59	59
	60	54	54	54	54	54	54	54	54	54	54	54	54
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 2	0	93	83	79	76	70	64	60	56	53	51	50	48
	10	93	83	79	76	70	64	60	56	53	51	50	48
	20	86	83	79	76	70	64	60	56	53	51	50	48
	30	74	74	74	74	70	64	60	56	53	51	50	48
	40	65	65	65	65	65	64	60	56	53	51	50	48
	50	59	59	59	59	59	59	59	56	53	51	50	48
	60	54	54	54	54	54	54	54	54	53	51	50	48
	70	50	50	50	50	50	50	50	50	50	50	50	48
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 3	0	73	66	63	60	55	51	48	45	42	41	39	37
	10	73	66	63	60	55	51	48	45	42	41	39	37
	20	73	66	63	60	55	51	48	45	42	41	39	37
	30	73	66	63	60	55	51	48	45	42	41	39	37
	40	65	65	63	60	55	51	48	45	42	41	39	37
	50	59	59	59	59	55	51	48	45	42	41	39	37
	60	54	54	54	54	54	51	48	45	42	41	39	37
	70	50	50	50	50	50	50	48	45	42	41	39	37
	80	48	48	48	48	48	48	48	45	42	41	39	37
	90	44	44	44	44	44	44	44	44	42	41	39	37

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 15		Mean Roof Height: 15 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	105	100	95	87	81	75	70	65	63	62	58
	10	102	100	100	95	87	81	75	70	65	63	62	58
	20	86	86	86	86	85	81	75	70	65	63	62	58
	30	74	74	74	74	74	74	73	70	65	63	62	58
	40	65	65	65	65	65	65	65	65	65	63	62	58
	50	59	59	59	59	59	59	59	59	59	59	59	58
	60	54	54	54	54	54	54	54	54	54	54	54	54
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 2	0	84	76	73	69	64	59	55	51	48	48	45	43
	10	84	76	73	69	64	59	55	51	48	48	45	43
	20	84	76	73	69	64	59	55	51	48	48	45	43
	30	74	74	73	69	64	59	55	51	48	48	45	43
	40	65	65	65	65	64	59	55	51	48	48	45	43
	50	59	59	59	59	59	59	55	51	48	48	45	43
	60	54	54	54	54	54	54	54	51	48	48	45	43
	70	50	50	50	50	50	50	50	50	48	48	45	43
	80	48	48	48	48	48	48	48	48	48	48	45	43
	90	44	44	44	44	44	44	44	44	44	44	44	43
Zone 3	0	67	60	57	55	51	48	44	41	38	37	36	34
	10	67	60	57	55	51	48	44	41	38	37	36	34
	20	67	60	57	55	51	48	44	41	38	37	36	34
	30	67	60	57	55	51	48	44	41	38	37	36	34
	40	65	60	57	55	51	48	44	41	38	37	36	34
	50	59	59	57	55	51	48	44	41	38	37	36	34
	60	54	54	54	54	51	48	44	41	38	37	36	34
	70	50	50	50	50	50	48	44	41	38	37	36	34
	80	48	48	48	48	48	48	44	41	38	37	36	34
	90	44	44	44	44	44	44	44	41	38	37	36	34

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 16		Mean Roof Height: 0 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 7 < θ ≤ 27 degrees							Exposure Category: B				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	116	116	116	113	109	101	94	89	86	83	79
	10	101	99	98	97	95	93	91	89	86	85	83	79
	20	80	80	80	80	80	78	77	76	74	74	73	72
	30	67	67	67	67	67	67	67	67	66	66	65	64
	40	59	59	59	59	59	59	59	59	59	59	59	59
	50	54	54	54	54	54	54	54	54	54	54	54	54
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 2	0	111	100	96	91	84	78	73	68	64	62	60	57
	10	101	99	96	91	84	78	73	68	64	62	60	57
	20	80	80	80	80	80	78	73	68	64	62	60	57
	30	67	67	67	67	67	67	67	67	64	62	60	57
	40	59	59	59	59	59	59	59	59	59	59	59	57
	50	54	54	54	54	54	54	54	54	54	54	54	54
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 3	0	89	80	77	73	68	63	58	55	51	50	48	46
	10	89	80	77	73	68	63	58	55	51	50	48	46
	20	80	80	77	73	68	63	58	55	51	50	48	46
	30	67	67	67	67	67	63	58	55	51	50	48	46
	40	59	59	59	59	59	59	58	55	51	50	48	46
	50	54	54	54	54	54	54	54	54	51	50	48	46
	60	49	49	49	49	49	49	49	49	49	49	48	46
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 17														
Mean Roof Height: 15 < h ≤ 30 ft														
Roof Angle: 7 < θ ≤ 27 degrees														
Exposure Category: C														
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)												
		100	110	115	120	130	140	150	160	170	175	180	190	
Zone 1	0	116	113	111	107	98	91	85	79	74	72	70	66	
	10	98	95	94	92	90	87	85	79	74	72	70	66	
	20	80	80	79	78	76	75	73	72	70	69	69	66	
	30	67	67	67	67	67	67	65	64	63	63	62	61	
	40	59	59	59	59	59	59	59	59	58	57	57	56	
	50	54	54	54	54	54	54	54	54	54	53	53	52	
	60	49	49	49	49	49	49	49	49	49	49	49	49	
	70	46	46	46	46	46	46	46	46	46	46	46	46	
	80	43	43	43	43	43	43	43	43	43	43	43	43	
	90	41	41	41	41	41	41	41	41	41	41	41	41	
Zone 2	0	93	84	80	77	72	65	61	57	54	52	51	48	
	10	93	84	80	77	72	65	61	57	54	52	51	48	
	20	80	80	79	77	72	65	61	57	54	52	51	48	
	30	67	67	67	67	67	65	61	57	54	52	51	48	
	40	59	59	59	59	59	59	59	57	54	52	51	48	
	50	54	54	54	54	54	54	54	54	54	52	51	48	
	60	49	49	49	49	49	49	49	49	49	49	49	48	
	70	46	46	46	46	46	46	46	46	46	46	46	46	
	80	43	43	43	43	43	43	43	43	43	43	43	43	
	90	41	41	41	41	41	41	41	41	41	41	41	41	
Zone 3	0	74	67	64	62	57	53	49	46	43	42	41	39	
	10	74	67	64	62	57	53	49	46	43	42	41	39	
	20	74	67	64	62	57	53	49	46	43	42	41	39	
	30	67	67	64	62	57	53	49	46	43	42	41	39	
	40	59	59	59	59	57	53	49	46	43	42	41	39	
	50	54	54	54	54	54	53	49	46	43	42	41	39	
	60	49	49	49	49	49	49	49	46	43	42	41	39	
	70	46	46	46	46	46	46	46	46	43	42	41	39	
	80	43	43	43	43	43	43	43	43	43	42	41	39	
	90	41	41	41	41	41	41	41	41	41	41	41	39	

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 18		Mean Roof Height: 15 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	113	107	102	98	90	83	78	73	68	66	64	61
	10	95	93	91	90	87	83	78	73	68	66	64	61
	20	80	78	77	76	75	73	72	69	68	66	64	61
	30	67	67	67	67	66	65	64	63	61	61	60	59
	40	59	59	59	59	59	59	58	58	57	56	56	55
	50	54	54	54	54	54	54	54	53	53	52	52	51
	60	49	49	49	49	49	49	49	49	49	49	49	48
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 2	0	85	77	74	70	65	60	56	52	49	48	46	44
	10	85	77	74	70	65	60	56	52	49	48	46	44
	20	80	77	74	70	65	60	56	52	49	48	46	44
	30	67	67	67	67	65	60	56	52	49	48	46	44
	40	59	59	59	59	59	59	56	52	49	48	46	44
	50	54	54	54	54	54	54	54	52	49	48	46	44
	60	49	49	49	49	49	49	49	49	49	48	46	44
	70	46	46	46	46	46	46	46	46	46	46	46	44
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 3	0	68	62	59	57	52	48	45	42	40	38	37	35
	10	68	62	59	57	52	48	45	42	40	38	37	35
	20	68	62	59	57	52	48	45	42	40	38	37	35
	30	67	62	59	57	52	48	45	42	40	38	37	35
	40	59	59	59	57	52	48	45	42	40	38	37	35
	50	54	54	54	54	52	48	45	42	40	38	37	35
	60	49	49	49	49	49	48	45	42	40	38	37	35
	70	46	46	46	46	46	46	45	42	40	38	37	35
	80	43	43	43	43	43	43	43	42	40	38	37	35
	90	41	41	41	41	41	41	41	41	40	38	37	35

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 19		Mean Roof Height: 0 < h ≤ 30 ft						Panel Orientation: Portrait					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: B											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	112	106	103	100	95	90	85	81	78	76	74	72
	10	97	94	93	91	88	85	82	79	77	75	74	72
	20	84	82	81	80	77	75	73	71	69	68	67	65
	30	74	73	72	72	70	68	67	65	64	63	62	61
	40	65	65	65	65	64	63	62	61	59	59	58	57
	50	59	59	59	59	59	59	58	57	56	55	55	54
	60	55	55	55	55	55	55	54	54	53	52	52	51
	70	51	51	51	51	51	51	51	51	50	50	49	49
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	45	45	45	45	45	45	45	45	45	45	45	45
Zone 2	0	112	106	103	100	95	90	85	80	75	73	72	67
	10	97	94	93	91	88	85	82	79	75	73	72	67
	20	84	82	81	80	77	75	73	71	69	68	67	65
	30	74	73	72	72	70	68	67	65	64	63	62	61
	40	65	65	65	65	64	63	62	61	59	59	58	57
	50	59	59	59	59	59	59	58	57	56	55	55	54
	60	55	55	55	55	55	55	54	54	53	52	52	51
	70	51	51	51	51	51	51	51	51	50	50	49	49
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	45	45	45	45	45	45	45	45	45	45	45	45
Zone 3	0	112	106	103	100	95	90	85	80	75	73	72	67
	10	97	94	93	91	88	85	82	79	75	73	72	67
	20	84	82	81	80	77	75	73	71	69	68	67	65
	30	74	73	72	72	70	68	67	65	64	63	62	61
	40	65	65	65	65	64	63	62	61	59	59	58	57
	50	59	59	59	59	59	59	58	57	56	55	55	54
	60	55	55	55	55	55	55	54	54	53	52	52	51
	70	51	51	51	51	51	51	51	51	50	50	49	49
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	45	45	45	45	45	45	45	45	45	45	45	45

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 20		Mean Roof Height: 15 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	101	95	92	89	84	79	75	72	67	66	64	61
	10	92	88	86	84	81	78	75	72	67	66	64	61
	20	80	77	76	75	73	70	68	66	63	62	61	59
	30	72	70	69	68	66	64	63	61	59	58	57	56
	40	65	64	64	63	61	60	58	57	56	55	54	53
	50	59	59	59	59	57	56	55	54	53	52	51	50
	60	55	55	55	55	54	53	52	51	50	49	49	48
	70	51	51	51	51	51	50	50	49	48	48	48	46
	80	48	48	48	48	48	48	48	48	46	45	45	44
	90	45	45	45	45	45	45	45	45	44	44	43	43
Zone 2	0	101	95	92	89	83	77	72	67	63	61	60	57
	10	92	88	86	84	81	77	72	67	63	61	60	57
	20	80	77	76	75	73	70	68	66	63	61	60	57
	30	72	70	69	68	66	64	63	61	59	58	57	56
	40	65	64	64	63	61	60	58	57	56	55	54	53
	50	59	59	59	59	57	56	55	54	53	52	51	50
	60	55	55	55	55	54	53	52	51	50	49	49	48
	70	51	51	51	51	51	50	50	49	48	48	48	46
	80	48	48	48	48	48	48	48	48	46	45	45	44
	90	45	45	45	45	45	45	45	45	44	44	43	43
Zone 3	0	101	95	92	89	83	77	72	67	63	61	60	57
	10	92	88	86	84	81	77	72	67	63	61	60	57
	20	80	77	76	75	73	70	68	66	63	61	60	57
	30	72	70	69	68	66	64	63	61	59	58	57	56
	40	65	64	64	63	61	60	58	57	56	55	54	53
	50	59	59	59	59	57	56	55	54	53	52	51	50
	60	55	55	55	55	54	53	52	51	50	49	49	48
	70	51	51	51	51	51	50	50	49	48	48	48	46
	80	48	48	48	48	48	48	48	48	46	45	45	44
	90	45	45	45	45	45	45	45	45	44	44	43	43

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 21		Mean Roof Height: 15 < h ≤ 30 ft						Panel Orientation: Portrait					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	96	89	86	84	78	74	70	66	63	61	60	57
	10	88	85	83	81	77	74	70	66	63	61	60	57
	20	78	75	74	72	70	67	65	63	60	59	58	56
	30	70	68	67	66	64	62	60	58	57	56	55	53
	40	64	63	62	61	60	58	57	55	53	53	52	51
	50	59	59	58	57	56	55	53	52	51	50	49	48
	60	55	55	55	54	53	52	51	50	48	48	48	46
	70	51	51	51	51	50	49	48	48	46	46	45	44
	80	48	48	48	48	48	48	46	46	45	44	44	43
	90	45	45	45	45	45	45	45	44	43	43	42	41
Zone 2	0	96	89	86	82	76	72	66	62	58	56	55	52
	10	88	85	83	81	76	72	66	62	58	56	55	52
	20	78	75	74	72	70	67	65	62	58	56	55	52
	30	70	68	67	66	64	62	60	58	57	56	55	52
	40	64	63	62	61	60	58	57	55	53	53	52	51
	50	59	59	58	57	56	55	53	52	51	50	49	48
	60	55	55	55	54	53	52	51	50	48	48	48	46
	70	51	51	51	51	50	49	48	48	46	46	45	44
	80	48	48	48	48	48	48	46	46	45	44	44	43
	90	45	45	45	45	45	45	45	44	43	43	42	41
Zone 3	0	96	89	86	82	76	72	66	62	58	56	55	52
	10	88	85	83	81	76	72	66	62	58	56	55	52
	20	78	75	74	72	70	67	65	62	58	56	55	52
	30	70	68	67	66	64	62	60	58	57	56	55	52
	40	64	63	62	61	60	58	57	55	53	53	52	51
	50	59	59	58	57	56	55	53	52	51	50	49	48
	60	55	55	55	54	53	52	51	50	48	48	48	46
	70	51	51	51	51	50	49	48	48	46	46	45	44
	80	48	48	48	48	48	48	46	46	45	44	44	43
	90	45	45	45	45	45	45	45	44	43	43	42	41

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 22		Mean Roof Height: 0 < h ≤ 30 ft							Panel Orientation: Landscape				
		Roof Angle: 0 < θ ≤ 7 degrees							Exposure Category: B				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	121	121	121	116	109	106	102	97
	10	120	120	120	120	119	118	117	115	109	106	102	97
	20	101	101	101	101	101	101	101	101	101	101	100	97
	30	90	90	90	90	90	90	90	90	90	90	90	90
	40	82	82	82	82	82	82	82	82	82	82	82	82
	50	74	74	74	74	74	74	74	74	74	74	74	74
	60	68	68	68	68	68	68	68	68	68	68	68	68
	70	64	64	64	64	64	64	64	64	64	64	64	64
	80	60	60	60	60	60	60	60	60	60	60	60	60
	90	56	56	56	56	56	56	56	56	56	56	56	56
Zone 2	0	121	121	121	116	106	98	91	85	80	77	75	72
	10	120	120	120	116	106	98	91	85	80	77	75	72
	20	101	101	101	101	101	98	91	85	80	77	75	72
	30	90	90	90	90	90	90	90	85	80	77	75	72
	40	82	82	82	82	82	82	82	82	80	77	75	72
	50	74	74	74	74	74	74	74	74	74	74	74	72
	60	68	68	68	68	68	68	68	68	68	68	68	68
	70	64	64	64	64	64	64	64	64	64	64	64	64
	80	60	60	60	60	60	60	60	60	60	60	60	60
	90	56	56	56	56	56	56	56	56	56	56	56	56
Zone 3	0	111	100	95	91	84	77	72	67	63	61	60	56
	10	111	100	95	91	84	77	72	67	63	61	60	56
	20	101	100	95	91	84	77	72	67	63	61	60	56
	30	90	90	90	90	84	77	72	67	63	61	60	56
	40	82	82	82	82	82	77	72	67	63	61	60	56
	50	74	74	74	74	74	74	72	67	63	61	60	56
	60	68	68	68	68	68	68	68	67	63	61	60	56
	70	64	64	64	64	64	64	64	64	63	61	60	56
	80	60	60	60	60	60	60	60	60	60	60	60	56
	90	56	56	56	56	56	56	56	56	56	56	56	56

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 23		Mean Roof Height: 15 < h ≤ 30 ft							Panel Orientation: Landscape				
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	121	112	104	97	91	88	86	81
	10	120	119	118	118	116	112	104	97	91	88	86	81
	20	101	101	101	101	101	101	100	97	91	88	86	81
	30	90	90	90	90	90	90	90	90	90	88	86	81
	40	82	82	82	82	82	82	82	82	82	82	82	81
	50	74	74	74	74	74	74	74	74	74	74	74	74
	60	68	68	68	68	68	68	68	68	68	68	68	68
	70	64	64	64	64	64	64	64	64	64	64	64	64
	80	60	60	60	60	60	60	60	60	60	60	60	60
	90	56	56	56	56	56	56	56	56	56	56	56	56
Zone 2	0	117	106	101	96	88	82	76	72	67	65	63	59
	10	117	106	101	96	88	82	76	72	67	65	63	59
	20	101	101	101	96	88	82	76	72	67	65	63	59
	30	90	90	90	90	88	82	76	72	67	65	63	59
	40	82	82	82	82	82	82	76	72	67	65	63	59
	50	74	74	74	74	74	74	74	72	67	65	63	59
	60	68	68	68	68	68	68	68	68	67	65	63	59
	70	64	64	64	64	64	64	64	64	64	64	63	59
	80	60	60	60	60	60	60	60	60	60	60	60	59
	90	56	56	56	56	56	56	56	56	56	56	56	56
Zone 3	0	92	84	80	76	70	65	60	57	53	52	50	48
	10	92	84	80	76	70	65	60	57	53	52	50	48
	20	92	84	80	76	70	65	60	57	53	52	50	48
	30	90	84	80	76	70	65	60	57	53	52	50	48
	40	82	82	80	76	70	65	60	57	53	52	50	48
	50	74	74	74	74	70	65	60	57	53	52	50	48
	60	68	68	68	68	68	65	60	57	53	52	50	48
	70	64	64	64	64	64	64	60	57	53	52	50	48
	80	60	60	60	60	60	60	60	57	53	52	50	48
	90	56	56	56	56	56	56	56	56	53	52	50	48

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 24		Mean Roof Height: 15 < h ≤ 30 ft							Panel Orientation: Landscape				
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	111	102	95	89	83	81	78	74
	10	119	118	117	116	111	102	95	89	83	81	78	74
	20	101	101	101	101	101	100	95	89	83	81	78	74
	30	90	90	90	90	90	90	90	89	83	81	78	74
	40	82	82	82	82	82	82	82	82	82	81	78	74
	50	74	74	74	74	74	74	74	74	74	74	74	74
	60	68	68	68	68	68	68	68	68	68	68	68	68
	70	64	64	64	64	64	64	64	64	64	64	64	64
	80	60	60	60	60	60	60	60	60	60	60	60	60
	90	56	56	56	56	56	56	56	56	56	56	56	56
Zone 2	0	107	97	92	88	81	75	70	65	61	59	58	55
	10	107	97	92	88	81	75	70	65	61	59	58	55
	20	101	97	92	88	81	75	70	65	61	59	58	55
	30	90	90	90	88	81	75	70	65	61	59	58	55
	40	82	82	82	82	81	75	70	65	61	59	58	55
	50	74	74	74	74	74	74	70	65	61	59	58	55
	60	68	68	68	68	68	68	68	65	61	59	58	55
	70	64	64	64	64	64	64	64	64	61	59	58	55
	80	60	60	60	60	60	60	60	60	60	59	58	55
	90	56	56	56	56	56	56	56	56	56	56	56	55
Zone 3	0	85	76	73	70	64	59	55	52	49	48	46	43
	10	85	76	73	70	64	59	55	52	49	48	46	43
	20	85	76	73	70	64	59	55	52	49	48	46	43
	30	85	76	73	70	64	59	55	52	49	48	46	43
	40	82	76	73	70	64	59	55	52	49	48	46	43
	50	74	74	73	70	64	59	55	52	49	48	46	43
	60	68	68	68	68	64	59	55	52	49	48	46	43
	70	64	64	64	64	64	59	55	52	49	48	46	43
	80	60	60	60	60	60	59	55	52	49	48	46	43
	90	56	56	56	56	56	56	55	52	49	48	46	43

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 25		Mean Roof Height: $0 < h \leq 30$ ft				Panel Orientation: Landscape								
		Roof Angle: $7 < \theta \leq 27$ degrees				Exposure Category: B								
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)												
		100	110	115	120	130	140	150	160	170	175	180	190	
Zone 1	0	121	121	121	121	121	121	121	120	112	109	106	100	
	10	120	119	118	117	115	114	112	110	108	108	106	100	
	20	101	101	101	101	101	99	98	96	94	93	93	91	
	30	86	86	86	86	86	86	86	85	84	83	83	82	
	40	75	75	75	75	75	75	75	75	75	75	75	75	
	50	68	68	68	68	68	68	68	68	68	68	68	68	
	60	63	63	63	63	63	63	63	63	63	63	63	63	
	70	58	58	58	58	58	58	58	58	58	58	58	58	
	80	55	55	55	55	55	55	55	55	55	55	55	55	
	90	52	52	52	52	52	52	52	52	52	52	52	52	
Zone 2	0	121	121	121	116	107	99	92	86	81	79	76	72	
	10	120	119	118	116	107	99	92	86	81	79	76	72	
	20	101	101	101	101	101	99	92	86	81	79	76	72	
	30	86	86	86	86	86	86	86	85	81	79	76	72	
	40	75	75	75	75	75	75	75	75	75	75	75	72	
	50	68	68	68	68	68	68	68	68	68	68	68	68	
	60	63	63	63	63	63	63	63	63	63	63	63	63	
	70	58	58	58	58	58	58	58	58	58	58	58	58	
	80	55	55	55	55	55	55	55	55	55	55	55	55	
	90	52	52	52	52	52	52	52	52	52	52	52	52	
Zone 3	0	112	102	97	93	86	79	74	69	65	63	61	58	
	10	112	102	97	93	86	79	74	69	65	63	61	58	
	20	101	101	97	93	86	79	74	69	65	63	61	58	
	30	86	86	86	86	86	79	74	69	65	63	61	58	
	40	75	75	75	75	75	75	74	69	65	63	61	58	
	50	68	68	68	68	68	68	68	68	65	63	61	58	
	60	63	63	63	63	63	63	63	63	63	63	61	58	
	70	58	58	58	58	58	58	58	58	58	58	58	58	
	80	55	55	55	55	55	55	55	55	55	55	55	55	
	90	52	52	52	52	52	52	52	52	52	52	52	52	

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 26		Mean Roof Height: 15 < h ≤ 30 ft							Panel Orientation: Landscape				
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	121	116	108	101	94	92	89	84
	10	117	115	114	113	111	109	107	101	94	92	89	84
	20	101	101	100	99	97	95	93	91	89	88	87	84
	30	86	86	86	86	86	85	83	82	80	79	79	77
	40	75	75	75	75	75	75	75	75	74	73	72	72
	50	68	68	68	68	68	68	68	68	68	68	67	66
	60	63	63	63	63	63	63	63	63	63	63	63	62
	70	58	58	58	58	58	58	58	58	58	58	58	58
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 2	0	118	107	102	97	90	83	77	72	68	66	64	61
	10	117	107	102	97	90	83	77	72	68	66	64	61
	20	101	101	100	97	90	83	77	72	68	66	64	61
	30	86	86	86	86	86	83	77	72	68	66	64	61
	40	75	75	75	75	75	75	75	72	68	66	64	61
	50	68	68	68	68	68	68	68	68	68	66	64	61
	60	63	63	63	63	63	63	63	63	63	63	63	61
	70	58	58	58	58	58	58	58	58	58	58	58	58
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 3	0	94	86	82	78	72	67	62	58	55	53	52	49
	10	94	86	82	78	72	67	62	58	55	53	52	49
	20	94	86	82	78	72	67	62	58	55	53	52	49
	30	86	86	82	78	72	67	62	58	55	53	52	49
	40	75	75	75	75	72	67	62	58	55	53	52	49
	50	68	68	68	68	68	67	62	58	55	53	52	49
	60	63	63	63	63	63	63	62	58	55	53	52	49
	70	58	58	58	58	58	58	58	58	55	53	52	49
	80	55	55	55	55	55	55	55	55	55	53	52	49
	90	52	52	52	52	52	52	52	52	52	52	52	49

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 27		Mean Roof Height: 15 < h ≤ 30 ft							Panel Orientation: Landscape				
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	114	106	98	92	87	84	82	77
	10	116	113	112	111	109	106	98	92	87	84	82	77
	20	101	99	98	97	95	93	90	88	86	84	82	77
	30	86	86	86	86	84	83	81	80	78	77	76	75
	40	75	75	75	75	75	75	74	73	72	72	72	69
	50	68	68	68	68	68	68	68	68	67	66	66	65
	60	63	63	63	63	63	63	63	63	63	62	62	61
	70	58	58	58	58	58	58	58	58	58	58	58	58
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 2	0	108	98	93	89	82	76	72	66	63	61	59	56
	10	108	98	93	89	82	76	72	66	63	61	59	56
	20	101	98	93	89	82	76	72	66	63	61	59	56
	30	86	86	86	86	82	76	72	66	63	61	59	56
	40	75	75	75	75	75	75	72	66	63	61	59	56
	50	68	68	68	68	68	68	68	66	63	61	59	56
	60	63	63	63	63	63	63	63	63	63	61	59	56
	70	58	58	58	58	58	58	58	58	58	58	58	56
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 3	0	87	79	75	72	66	61	57	54	50	49	48	45
	10	87	79	75	72	66	61	57	54	50	49	48	45
	20	87	79	75	72	66	61	57	54	50	49	48	45
	30	86	79	75	72	66	61	57	54	50	49	48	45
	40	75	75	75	72	66	61	57	54	50	49	48	45
	50	68	68	68	68	66	61	57	54	50	49	48	45
	60	63	63	63	63	63	61	57	54	50	49	48	45
	70	58	58	58	58	58	58	57	54	50	49	48	45
	80	55	55	55	55	55	55	55	54	50	49	48	45
	90	52	52	52	52	52	52	52	52	50	49	48	45

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 28		Mean Roof Height: 0 < h ≤ 30 ft						Panel Orientation: Landscape					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: B											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	117	113	108	103	98	96	94	90
	10	121	119	118	116	112	108	104	101	97	96	94	90
	20	106	104	102	101	98	96	93	91	88	87	86	83
	30	94	93	92	91	89	87	85	83	81	80	79	77
	40	83	83	83	83	82	80	79	77	75	75	74	72
	50	75	75	75	75	75	75	73	72	72	70	70	68
	60	69	69	69	69	69	69	69	68	67	66	66	65
	70	65	65	65	65	65	65	65	65	64	63	63	62
	80	61	61	61	61	61	61	61	61	61	60	60	59
	90	58	58	58	58	58	58	58	58	58	58	58	57
Zone 2	0	121	121	121	121	117	113	108	101	95	92	90	85
	10	121	119	118	116	112	108	104	101	95	92	90	85
	20	106	104	102	101	98	96	93	91	88	87	86	83
	30	94	93	92	91	89	87	85	83	81	80	79	77
	40	83	83	83	83	82	80	79	77	75	75	74	72
	50	75	75	75	75	75	75	73	72	72	70	70	68
	60	69	69	69	69	69	69	69	68	67	66	66	65
	70	65	65	65	65	65	65	65	65	64	63	63	62
	80	61	61	61	61	61	61	61	61	61	60	60	59
	90	58	58	58	58	58	58	58	58	58	58	58	57
Zone 3	0	121	121	121	121	117	113	108	101	95	92	90	85
	10	121	119	118	116	112	108	104	101	95	92	90	85
	20	106	104	102	101	98	96	93	91	88	87	86	83
	30	94	93	92	91	89	87	85	83	81	80	79	77
	40	83	83	83	83	82	80	79	77	75	75	74	72
	50	75	75	75	75	75	75	73	72	72	70	70	68
	60	69	69	69	69	69	69	69	68	67	66	66	65
	70	65	65	65	65	65	65	65	65	64	63	63	62
	80	61	61	61	61	61	61	61	61	61	60	60	59
	90	58	58	58	58	58	58	58	58	58	58	58	57

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 29		Mean Roof Height: 15 < h ≤ 30 ft							Panel Orientation: Landscape				
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	117	115	112	106	100	95	90	86	84	82	78
	10	116	112	109	107	103	99	95	90	86	84	82	78
	20	101	98	97	95	92	89	86	83	81	79	78	75
	30	91	89	88	86	84	82	80	77	75	74	73	72
	40	83	82	81	80	78	76	74	72	71	70	69	67
	50	75	75	75	74	73	72	70	68	67	66	65	64
	60	69	69	69	69	69	67	66	65	64	63	62	61
	70	65	65	65	65	65	64	63	62	61	60	60	58
	80	61	61	61	61	61	61	60	59	58	58	57	56
	90	58	58	58	58	58	58	58	57	56	56	55	54
Zone 2	0	121	117	115	112	105	98	91	85	80	78	76	72
	10	116	112	109	107	103	98	91	85	80	78	76	72
	20	101	98	97	95	92	89	86	83	80	78	76	72
	30	91	89	88	86	84	82	80	77	75	74	73	72
	40	83	82	81	80	78	76	74	72	71	70	69	67
	50	75	75	75	74	73	72	70	68	67	66	65	64
	60	69	69	69	69	69	67	66	65	64	63	62	61
	70	65	65	65	65	65	64	63	62	61	60	60	58
	80	61	61	61	61	61	61	60	59	58	58	57	56
	90	58	58	58	58	58	58	58	57	56	56	55	54
Zone 3	0	121	117	115	112	105	98	91	85	80	78	76	72
	10	116	112	109	107	103	98	91	85	80	78	76	72
	20	101	98	97	95	92	89	86	83	80	78	76	72
	30	91	89	88	86	84	82	80	77	75	74	73	72
	40	83	82	81	80	78	76	74	72	71	70	69	67
	50	75	75	75	74	73	72	70	68	67	66	65	64
	60	69	69	69	69	69	67	66	65	64	63	62	61
	70	65	65	65	65	65	64	63	62	61	60	60	58
	80	61	61	61	61	61	61	60	59	58	58	57	56
	90	58	58	58	58	58	58	58	57	56	56	55	54

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 30		Mean Roof Height: 15 < h ≤ 30 ft						Panel Orientation: Landscape					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	118	112	110	106	100	94	89	84	80	78	76	72
	10	112	107	105	103	98	94	89	84	80	78	76	72
	20	99	95	94	92	89	85	82	79	77	75	74	72
	30	89	87	85	84	81	79	77	74	72	72	70	68
	40	82	80	79	78	76	74	72	70	68	67	66	64
	50	75	74	74	73	72	70	68	66	65	64	63	61
	60	69	69	69	69	67	66	64	63	62	61	60	59
	70	65	65	65	65	64	63	62	60	59	58	58	57
	80	61	61	61	61	61	60	59	58	57	56	56	54
	90	58	58	58	58	58	58	57	56	55	54	54	53
Zone 2	0	118	112	109	105	97	90	84	78	74	72	70	66
	10	112	107	105	103	97	90	84	78	74	72	70	66
	20	99	95	94	92	89	85	82	78	74	72	70	66
	30	89	87	85	84	81	79	77	74	72	72	70	66
	40	82	80	79	78	76	74	72	70	68	67	66	64
	50	75	74	74	73	72	70	68	66	65	64	63	61
	60	69	69	69	69	67	66	64	63	62	61	60	59
	70	65	65	65	65	64	63	62	60	59	58	58	57
	80	61	61	61	61	61	60	59	58	57	56	56	54
	90	58	58	58	58	58	58	57	56	55	54	54	53
Zone 3	0	118	112	109	105	97	90	84	78	74	72	70	66
	10	112	107	105	103	97	90	84	78	74	72	70	66
	20	99	95	94	92	89	85	82	78	74	72	70	66
	30	89	87	85	84	81	79	77	74	72	72	70	66
	40	82	80	79	78	76	74	72	70	68	67	66	64
	50	75	74	74	73	72	70	68	66	65	64	63	61
	60	69	69	69	69	67	66	64	63	62	61	60	59
	70	65	65	65	65	64	63	62	60	59	58	58	57
	80	61	61	61	61	61	60	59	58	57	56	56	54
	90	58	58	58	58	58	58	57	56	55	54	54	53

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 31		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Portrait				
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: B											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	116	116	114	104	95	89	82	77	75	73	69
	10	102	102	102	101	100	95	89	82	77	75	73	69
	20	86	86	86	86	86	86	86	82	77	75	73	69
	30	74	74	74	74	74	74	74	74	74	73	73	69
	40	65	65	65	65	65	65	65	65	65	65	65	65
	50	59	59	59	59	59	59	59	59	59	59	59	59
	60	54	54	54	54	54	54	54	54	54	54	54	54
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 2	0	100	90	86	82	75	69	65	60	57	55	53	50
	10	100	90	86	82	75	69	65	60	57	55	53	50
	20	86	86	86	82	75	69	65	60	57	55	53	50
	30	74	74	74	74	74	69	65	60	57	55	53	50
	40	65	65	65	65	65	65	65	60	57	55	53	50
	50	59	59	59	59	59	59	59	59	57	55	53	50
	60	54	54	54	54	54	54	54	54	54	54	53	50
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 3	0	79	72	68	65	59	55	51	48	45	44	42	40
	10	79	72	68	65	59	55	51	48	45	44	42	40
	20	79	72	68	65	59	55	51	48	45	44	42	40
	30	74	72	68	65	59	55	51	48	45	44	42	40
	40	65	65	65	65	59	55	51	48	45	44	42	40
	50	59	59	59	59	59	55	51	48	45	44	42	40
	60	54	54	54	54	54	54	51	48	45	44	42	40
	70	50	50	50	50	50	50	50	48	45	44	42	40
	80	48	48	48	48	48	48	48	48	45	44	42	40
	90	44	44	44	44	44	44	44	44	44	44	42	40

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 32		Mean Roof Height: 30 < h ≤ 60 ft						Panel Orientation: Portrait					
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	107	101	97	89	82	76	72	66	64	62	59
	10	102	101	100	97	89	82	76	72	66	64	62	59
	20	86	86	86	86	86	82	76	72	66	64	62	59
	30	74	74	74	74	74	74	73	72	66	64	62	59
	40	65	65	65	65	65	65	65	65	65	64	62	59
	50	59	59	59	59	59	59	59	59	59	59	59	58
	60	54	54	54	54	54	54	54	54	54	54	54	54
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 2	0	86	77	74	70	65	60	56	52	49	48	46	43
	10	86	77	74	70	65	60	56	52	49	48	46	43
	20	86	77	74	70	65	60	56	52	49	48	46	43
	30	74	74	74	70	65	60	56	52	49	48	46	43
	40	65	65	65	65	65	60	56	52	49	48	46	43
	50	59	59	59	59	59	59	56	52	49	48	46	43
	60	54	54	54	54	54	54	54	52	49	48	46	43
	70	50	50	50	50	50	50	50	50	49	48	46	43
	80	48	48	48	48	48	48	48	48	48	48	46	43
	90	44	44	44	44	44	44	44	44	44	44	44	43
Zone 3	0	68	61	58	56	51	48	44	41	39	38	37	35
	10	68	61	58	56	51	48	44	41	39	38	37	35
	20	68	61	58	56	51	48	44	41	39	38	37	35
	30	68	61	58	56	51	48	44	41	39	38	37	35
	40	65	61	58	56	51	48	44	41	39	38	37	35
	50	59	59	58	56	51	48	44	41	39	38	37	35
	60	54	54	54	54	51	48	44	41	39	38	37	35
	70	50	50	50	50	50	48	44	41	39	38	37	35
	80	48	48	48	48	48	48	44	41	39	38	37	35
	90	44	44	44	44	44	44	44	41	39	38	37	35

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 33		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Portrait				
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	109	98	93	89	82	75	70	65	61	60	58	55
	10	101	98	93	89	82	75	70	65	61	60	58	55
	20	86	86	86	86	82	75	70	65	61	60	58	55
	30	74	74	74	74	74	73	70	65	61	60	58	55
	40	65	65	65	65	65	65	65	65	61	60	58	55
	50	59	59	59	59	59	59	59	59	59	59	58	55
	60	54	54	54	54	54	54	54	54	54	54	54	54
	70	50	50	50	50	50	50	50	50	50	50	50	50
	80	48	48	48	48	48	48	48	48	48	48	48	48
	90	44	44	44	44	44	44	44	44	44	44	44	44
Zone 2	0	79	72	68	65	60	55	51	48	45	44	43	40
	10	79	72	68	65	60	55	51	48	45	44	43	40
	20	79	72	68	65	60	55	51	48	45	44	43	40
	30	74	72	68	65	60	55	51	48	45	44	43	40
	40	65	65	65	65	60	55	51	48	45	44	43	40
	50	59	59	59	59	59	55	51	48	45	44	43	40
	60	54	54	54	54	54	54	51	48	45	44	43	40
	70	50	50	50	50	50	50	50	48	45	44	43	40
	80	48	48	48	48	48	48	48	48	45	44	43	40
	90	44	44	44	44	44	44	44	44	44	44	43	40
Zone 3	0	62	56	54	52	48	44	41	38	36	35	34	32
	10	62	56	54	52	48	44	41	38	36	35	34	32
	20	62	56	54	52	48	44	41	38	36	35	34	32
	30	62	56	54	52	48	44	41	38	36	35	34	32
	40	62	56	54	52	48	44	41	38	36	35	34	32
	50	59	56	54	52	48	44	41	38	36	35	34	32
	60	54	54	54	52	48	44	41	38	36	35	34	32
	70	50	50	50	50	48	44	41	38	36	35	34	32
	80	48	48	48	48	48	44	41	38	36	35	34	32
	90	44	44	44	44	44	44	41	38	36	35	34	32

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 34		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Portrait				
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: B											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	116	116	114	112	106	98	91	85	80	78	75	72
	10	99	97	96	95	92	90	87	85	80	78	75	72
	20	80	80	80	79	78	76	75	73	72	72	72	69
	30	67	67	67	67	67	67	67	66	64	64	63	62
	40	59	59	59	59	59	59	59	59	59	58	58	57
	50	54	54	54	54	54	54	54	54	54	54	54	53
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 2	0	100	90	86	83	76	70	66	61	58	56	54	51
	10	99	90	86	83	76	70	66	61	58	56	54	51
	20	80	80	80	79	76	70	66	61	58	56	54	51
	30	67	67	67	67	67	67	66	61	58	56	54	51
	40	59	59	59	59	59	59	59	59	58	56	54	51
	50	54	54	54	54	54	54	54	54	54	54	54	51
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 3	0	80	73	69	66	61	57	53	49	46	45	44	41
	10	80	73	69	66	61	57	53	49	46	45	44	41
	20	80	73	69	66	61	57	53	49	46	45	44	41
	30	67	67	67	66	61	57	53	49	46	45	44	41
	40	59	59	59	59	59	57	53	49	46	45	44	41
	50	54	54	54	54	54	54	53	49	46	45	44	41
	60	49	49	49	49	49	49	49	49	46	45	44	41
	70	46	46	46	46	46	46	46	46	46	45	44	41
	80	43	43	43	43	43	43	43	43	43	43	43	41
	90	41	41	41	41	41	41	41	41	41	41	41	41

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 35		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Portrait				
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	114	109	104	99	91	84	79	74	69	67	65	62
	10	96	93	92	90	88	84	79	74	69	67	65	62
	20	80	78	77	77	75	73	72	70	68	67	65	62
	30	67	67	67	67	67	65	64	63	62	61	60	59
	40	59	59	59	59	59	59	59	58	57	56	56	55
	50	54	54	54	54	54	54	54	54	53	52	52	51
	60	49	49	49	49	49	49	49	49	49	49	49	48
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 2	0	86	78	75	72	66	61	57	53	50	48	48	45
	10	86	78	75	72	66	61	57	53	50	48	48	45
	20	80	78	75	72	66	61	57	53	50	48	48	45
	30	67	67	67	67	66	61	57	53	50	48	48	45
	40	59	59	59	59	59	59	57	53	50	48	48	45
	50	54	54	54	54	54	54	54	53	50	48	48	45
	60	49	49	49	49	49	49	49	49	49	48	48	45
	70	46	46	46	46	46	46	46	46	46	46	46	45
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 3	0	69	63	60	57	53	49	46	43	40	39	38	36
	10	69	63	60	57	53	49	46	43	40	39	38	36
	20	69	63	60	57	53	49	46	43	40	39	38	36
	30	67	63	60	57	53	49	46	43	40	39	38	36
	40	59	59	59	57	53	49	46	43	40	39	38	36
	50	54	54	54	54	53	49	46	43	40	39	38	36
	60	49	49	49	49	49	49	46	43	40	39	38	36
	70	46	46	46	46	46	46	46	43	40	39	38	36
	80	43	43	43	43	43	43	43	43	40	39	38	36
	90	41	41	41	41	41	41	41	41	40	39	38	36

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 36		Mean Roof Height: 30 < h ≤ 60 ft						Panel Orientation: Portrait					
		Roof Angle: 7 < θ ≤ 27 degrees						Exposure Category: D					
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	110	101	96	92	85	78	73	68	64	62	60	57
	10	94	91	89	88	85	78	73	68	64	62	60	57
	20	79	77	76	75	73	72	70	68	64	62	60	57
	30	67	67	67	67	65	64	63	61	60	59	59	57
	40	59	59	59	59	59	59	58	57	55	55	54	53
	50	54	54	54	54	54	54	53	53	52	51	51	50
	60	49	49	49	49	49	49	49	49	49	48	48	48
	70	46	46	46	46	46	46	46	46	46	46	46	45
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 2	0	80	72	69	66	61	56	53	49	46	45	44	41
	10	80	72	69	66	61	56	53	49	46	45	44	41
	20	79	72	69	66	61	56	53	49	46	45	44	41
	30	67	67	67	66	61	56	53	49	46	45	44	41
	40	59	59	59	59	59	56	53	49	46	45	44	41
	50	54	54	54	54	54	54	53	49	46	45	44	41
	60	49	49	49	49	49	49	49	49	46	45	44	41
	70	46	46	46	46	46	46	46	46	46	45	44	41
	80	43	43	43	43	43	43	43	43	43	43	43	41
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 3	0	64	58	55	53	49	45	42	40	37	36	35	33
	10	64	58	55	53	49	45	42	40	37	36	35	33
	20	64	58	55	53	49	45	42	40	37	36	35	33
	30	64	58	55	53	49	45	42	40	37	36	35	33
	40	59	58	55	53	49	45	42	40	37	36	35	33
	50	54	54	54	53	49	45	42	40	37	36	35	33
	60	49	49	49	49	49	45	42	40	37	36	35	33
	70	46	46	46	46	46	45	42	40	37	36	35	33
	80	43	43	43	43	43	43	42	40	37	36	35	33
	90	41	41	41	41	41	41	41	40	37	36	35	33

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 37		Mean Roof Height: 30 < h ≤ 60 ft						Panel Orientation: Portrait					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: B											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	106	100	97	94	88	84	79	75	72	70	68	65
	10	94	91	89	87	84	81	78	75	72	70	68	65
	20	82	79	78	77	75	72	70	68	66	65	64	62
	30	73	72	70	70	68	66	64	63	61	60	60	58
	40	65	65	65	64	63	61	60	59	57	57	56	55
	50	59	59	59	59	58	57	56	55	54	53	53	52
	60	55	55	55	55	55	54	53	52	51	51	50	49
	70	51	51	51	51	51	51	51	50	49	48	48	48
	80	48	48	48	48	48	48	48	48	48	46	46	45
	90	45	45	45	45	45	45	45	45	45	45	44	44
Zone 2	0	106	100	97	94	88	83	77	72	68	66	64	61
	10	94	91	89	87	84	81	77	72	68	66	64	61
	20	82	79	78	77	75	72	70	68	66	65	64	61
	30	73	72	70	70	68	66	64	63	61	60	60	58
	40	65	65	65	64	63	61	60	59	57	57	56	55
	50	59	59	59	59	58	57	56	55	54	53	53	52
	60	55	55	55	55	55	54	53	52	51	51	50	49
	70	51	51	51	51	51	51	51	50	49	48	48	48
	80	48	48	48	48	48	48	48	48	48	46	46	45
	90	45	45	45	45	45	45	45	45	45	45	44	44
Zone 3	0	106	100	97	94	88	83	77	72	68	66	64	61
	10	94	91	89	87	84	81	77	72	68	66	64	61
	20	82	79	78	77	75	72	70	68	66	65	64	61
	30	73	72	70	70	68	66	64	63	61	60	60	58
	40	65	65	65	64	63	61	60	59	57	57	56	55
	50	59	59	59	59	58	57	56	55	54	53	53	52
	60	55	55	55	55	55	54	53	52	51	51	50	49
	70	51	51	51	51	51	51	51	50	49	48	48	48
	80	48	48	48	48	48	48	48	48	48	46	46	45
	90	45	45	45	45	45	45	45	45	45	45	44	44

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 38		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Portrait				
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	96	90	87	84	79	75	72	67	63	62	60	57
	10	89	85	83	81	78	75	72	67	63	62	60	57
	20	78	75	74	73	70	68	65	63	61	60	59	57
	30	70	68	67	66	65	63	61	59	57	56	55	54
	40	65	63	62	62	60	58	57	55	54	53	52	51
	50	59	59	58	58	56	55	54	52	51	50	50	49
	60	55	55	55	54	53	52	51	50	49	48	48	48
	70	51	51	51	51	51	50	49	48	48	46	46	45
	80	48	48	48	48	48	48	48	46	45	44	44	43
	90	45	45	45	45	45	45	45	44	43	43	42	42
Zone 2	0	96	90	87	83	77	72	67	63	59	57	56	53
	10	89	85	83	81	77	72	67	63	59	57	56	53
	20	78	75	74	73	70	68	65	63	59	57	56	53
	30	70	68	67	66	65	63	61	59	57	56	55	53
	40	65	63	62	62	60	58	57	55	54	53	52	51
	50	59	59	58	58	56	55	54	52	51	50	50	49
	60	55	55	55	54	53	52	51	50	49	48	48	48
	70	51	51	51	51	51	50	49	48	48	46	46	45
	80	48	48	48	48	48	48	48	46	45	44	44	43
	90	45	45	45	45	45	45	45	44	43	43	42	42
Zone 3	0	96	90	87	83	77	72	67	63	59	57	56	53
	10	89	85	83	81	77	72	67	63	59	57	56	53
	20	78	75	74	73	70	68	65	63	59	57	56	53
	30	70	68	67	66	65	63	61	59	57	56	55	53
	40	65	63	62	62	60	58	57	55	54	53	52	51
	50	59	59	58	58	56	55	54	52	51	50	50	49
	60	55	55	55	54	53	52	51	50	49	48	48	48
	70	51	51	51	51	51	50	49	48	48	46	46	45
	80	48	48	48	48	48	48	48	46	45	44	44	43
	90	45	45	45	45	45	45	45	44	43	43	42	42

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 39		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Portrait				
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	91	85	82	80	75	70	66	63	59	58	56	54
	10	86	82	80	78	75	70	66	63	59	58	56	54
	20	76	73	72	70	68	65	63	60	58	57	56	54
	30	69	67	66	65	63	61	59	57	55	54	53	51
	40	63	62	61	60	58	57	55	53	52	51	50	49
	50	59	58	57	56	55	54	52	51	49	49	48	48
	60	55	54	54	53	52	51	50	48	48	48	46	45
	70	51	51	51	51	50	49	48	46	45	45	44	43
	80	48	48	48	48	48	46	46	45	44	43	43	42
	90	45	45	45	45	45	45	44	43	42	42	41	41
Zone 2	0	91	85	81	78	72	66	62	58	55	53	52	49
	10	86	82	80	78	72	66	62	58	55	53	52	49
	20	76	73	72	70	68	65	62	58	55	53	52	49
	30	69	67	66	65	63	61	59	57	55	53	52	49
	40	63	62	61	60	58	57	55	53	52	51	50	49
	50	59	58	57	56	55	54	52	51	49	49	48	48
	60	55	54	54	53	52	51	50	48	48	48	46	45
	70	51	51	51	51	50	49	48	46	45	45	44	43
	80	48	48	48	48	48	46	46	45	44	43	43	42
	90	45	45	45	45	45	45	44	43	42	42	41	41
Zone 3	0	91	85	81	78	72	66	62	58	55	53	52	49
	10	86	82	80	78	72	66	62	58	55	53	52	49
	20	76	73	72	70	68	65	62	58	55	53	52	49
	30	69	67	66	65	63	61	59	57	55	53	52	49
	40	63	62	61	60	58	57	55	53	52	51	50	49
	50	59	58	57	56	55	54	52	51	49	49	48	48
	60	55	54	54	53	52	51	50	48	48	48	46	45
	70	51	51	51	51	50	49	48	46	45	45	44	43
	80	48	48	48	48	48	46	46	45	44	43	43	42
	90	45	45	45	45	45	45	44	43	42	42	41	41

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 67.5"

Rail Spans for Quick Mount PV QRail Standard System

Table 40		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Landscape				
		Roof Angle: 0 < θ ≤ 7 degrees							Exposure Category: B				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	121	121	112	105	98	95	92	87
	10	120	120	119	119	117	116	112	105	98	95	92	87
	20	101	101	101	101	101	101	101	101	98	95	92	87
	30	90	90	90	90	90	90	90	90	90	90	90	87
	40	82	82	82	82	82	82	82	82	82	82	82	82
	50	74	74	74	74	74	74	74	74	74	74	74	74
	60	68	68	68	68	68	68	68	68	68	68	68	68
	70	64	64	64	64	64	64	64	64	64	64	64	64
	80	60	60	60	60	60	60	60	60	60	60	60	60
	90	56	56	56	56	56	56	56	56	56	56	56	56
Zone 2	0	121	114	109	104	95	88	82	77	72	70	68	64
	10	120	114	109	104	95	88	82	77	72	70	68	64
	20	101	101	101	101	95	88	82	77	72	70	68	64
	30	90	90	90	90	90	88	82	77	72	70	68	64
	40	82	82	82	82	82	82	82	77	72	70	68	64
	50	74	74	74	74	74	74	74	74	72	70	68	64
	60	68	68	68	68	68	68	68	68	68	68	68	64
	70	64	64	64	64	64	64	64	64	64	64	64	64
	80	60	60	60	60	60	60	60	60	60	60	60	60
	90	56	56	56	56	56	56	56	56	56	56	56	56
Zone 3	0	100	90	86	82	76	70	65	61	57	55	54	51
	10	100	90	86	82	76	70	65	61	57	55	54	51
	20	100	90	86	82	76	70	65	61	57	55	54	51
	30	90	90	86	82	76	70	65	61	57	55	54	51
	40	82	82	82	82	76	70	65	61	57	55	54	51
	50	74	74	74	74	74	70	65	61	57	55	54	51
	60	68	68	68	68	68	68	65	61	57	55	54	51
	70	64	64	64	64	64	64	64	61	57	55	54	51
	80	60	60	60	60	60	60	60	60	57	55	54	51
	90	56	56	56	56	56	56	56	56	56	55	54	51

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 41														
Mean Roof Height: 30 < h ≤ 60 ft														
Roof Angle: 0 < θ ≤ 7 degrees														
Exposure Category: C														
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)												
		100	110	115	120	130	140	150	160	170	175	180	190	
Zone 1	0	121	121	121	121	112	104	96	90	84	82	79	75	
	10	119	118	117	116	112	104	96	90	84	82	79	75	
	20	101	101	101	101	101	100	96	90	84	82	79	75	
	30	90	90	90	90	90	90	90	90	84	82	79	75	
	40	82	82	82	82	82	82	82	82	82	82	79	75	
	50	74	74	74	74	74	74	74	74	74	74	74	74	
	60	68	68	68	68	68	68	68	68	68	68	68	68	
	70	64	64	64	64	64	64	64	64	64	64	64	64	
	80	60	60	60	60	60	60	60	60	60	60	60	60	
	90	56	56	56	56	56	56	56	56	56	56	56	56	
Zone 2	0	109	98	93	89	82	76	72	66	62	60	58	55	
	10	109	98	93	89	82	76	72	66	62	60	58	55	
	20	101	98	93	89	82	76	72	66	62	60	58	55	
	30	90	90	90	89	82	76	72	66	62	60	58	55	
	40	82	82	82	82	82	76	72	66	62	60	58	55	
	50	74	74	74	74	74	74	72	66	62	60	58	55	
	60	68	68	68	68	68	68	68	66	62	60	58	55	
	70	64	64	64	64	64	64	64	64	62	60	58	55	
	80	60	60	60	60	60	60	60	60	60	60	58	55	
	90	56	56	56	56	56	56	56	56	56	56	56	55	
Zone 3	0	86	78	74	72	65	60	56	53	49	48	48	44	
	10	86	78	74	72	65	60	56	53	49	48	48	44	
	20	86	78	74	72	65	60	56	53	49	48	48	44	
	30	86	78	74	72	65	60	56	53	49	48	48	44	
	40	82	78	74	72	65	60	56	53	49	48	48	44	
	50	74	74	74	72	65	60	56	53	49	48	48	44	
	60	68	68	68	68	65	60	56	53	49	48	48	44	
	70	64	64	64	64	64	60	56	53	49	48	48	44	
	80	60	60	60	60	60	60	56	53	49	48	48	44	
	90	56	56	56	56	56	56	56	53	49	48	48	44	

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 42		Mean Roof Height: 30 < h ≤ 60 ft						Panel Orientation: Landscape					
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	119	113	104	96	89	83	78	76	73	69
	10	118	117	116	113	104	96	89	83	78	76	73	69
	20	101	101	101	101	100	96	89	83	78	76	73	69
	30	90	90	90	90	90	90	89	83	78	76	73	69
	40	82	82	82	82	82	82	82	82	78	76	73	69
	50	74	74	74	74	74	74	74	74	74	74	73	69
	60	68	68	68	68	68	68	68	68	68	68	68	68
	70	64	64	64	64	64	64	64	64	64	64	64	64
	80	60	60	60	60	60	60	60	60	60	60	60	60
	90	56	56	56	56	56	56	56	56	56	56	56	56
Zone 2	0	100	91	86	83	76	70	65	61	57	56	54	51
	10	100	91	86	83	76	70	65	61	57	56	54	51
	20	100	91	86	83	76	70	65	61	57	56	54	51
	30	90	90	86	83	76	70	65	61	57	56	54	51
	40	82	82	82	82	76	70	65	61	57	56	54	51
	50	74	74	74	74	74	70	65	61	57	56	54	51
	60	68	68	68	68	68	68	65	61	57	56	54	51
	70	64	64	64	64	64	64	64	61	57	56	54	51
	80	60	60	60	60	60	60	60	60	57	56	54	51
	90	56	56	56	56	56	56	56	56	56	56	54	51
Zone 3	0	79	72	69	66	60	56	52	49	46	44	43	41
	10	79	72	69	66	60	56	52	49	46	44	43	41
	20	79	72	69	66	60	56	52	49	46	44	43	41
	30	79	72	69	66	60	56	52	49	46	44	43	41
	40	79	72	69	66	60	56	52	49	46	44	43	41
	50	74	72	69	66	60	56	52	49	46	44	43	41
	60	68	68	68	66	60	56	52	49	46	44	43	41
	70	64	64	64	64	60	56	52	49	46	44	43	41
	80	60	60	60	60	60	56	52	49	46	44	43	41
	90	56	56	56	56	56	56	52	49	46	44	43	41

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 43		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Landscape				
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: B											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	121	121	116	108	102	99	96	91
	10	119	117	116	115	113	111	109	107	102	99	96	91
	20	101	101	101	101	99	97	95	93	91	90	90	88
	30	86	86	86	86	86	86	85	83	82	81	81	79
	40	75	75	75	75	75	75	75	75	75	74	74	73
	50	68	68	68	68	68	68	68	68	68	68	68	68
	60	63	63	63	63	63	63	63	63	63	63	63	63
	70	58	58	58	58	58	58	58	58	58	58	58	58
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 2	0	121	115	110	105	97	89	83	78	73	72	69	65
	10	119	115	110	105	97	89	83	78	73	72	69	65
	20	101	101	101	101	97	89	83	78	73	72	69	65
	30	86	86	86	86	86	86	83	78	73	72	69	65
	40	75	75	75	75	75	75	75	75	73	72	69	65
	50	68	68	68	68	68	68	68	68	68	68	68	65
	60	63	63	63	63	63	63	63	63	63	63	63	63
	70	58	58	58	58	58	58	58	58	58	58	58	58
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 3	0	102	92	88	84	78	72	67	63	59	57	56	53
	10	102	92	88	84	78	72	67	63	59	57	56	53
	20	101	92	88	84	78	72	67	63	59	57	56	53
	30	86	86	86	84	78	72	67	63	59	57	56	53
	40	75	75	75	75	75	72	67	63	59	57	56	53
	50	68	68	68	68	68	68	67	63	59	57	56	53
	60	63	63	63	63	63	63	63	63	59	57	56	53
	70	58	58	58	58	58	58	58	58	58	57	56	53
	80	55	55	55	55	55	55	55	55	55	55	55	53
	90	52	52	52	52	52	52	52	52	52	52	52	52

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 44		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Landscape				
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	121	116	107	100	93	88	85	83	78
	10	116	114	113	112	109	107	100	93	88	85	83	78
	20	101	99	98	97	95	93	91	89	87	85	83	78
	30	86	86	86	86	85	83	81	80	78	78	77	75
	40	75	75	75	75	75	75	75	73	72	72	72	70
	50	68	68	68	68	68	68	68	68	67	67	66	65
	60	63	63	63	63	63	63	63	63	63	63	62	61
	70	58	58	58	58	58	58	58	58	58	58	58	58
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 2	0	109	99	95	91	83	77	72	67	63	62	60	57
	10	109	99	95	91	83	77	72	67	63	62	60	57
	20	101	99	95	91	83	77	72	67	63	62	60	57
	30	86	86	86	86	83	77	72	67	63	62	60	57
	40	75	75	75	75	75	75	72	67	63	62	60	57
	50	68	68	68	68	68	68	68	67	63	62	60	57
	60	63	63	63	63	63	63	63	63	63	62	60	57
	70	58	58	58	58	58	58	58	58	58	58	58	57
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 3	0	88	80	76	73	67	62	58	54	51	50	48	46
	10	88	80	76	73	67	62	58	54	51	50	48	46
	20	88	80	76	73	67	62	58	54	51	50	48	46
	30	86	80	76	73	67	62	58	54	51	50	48	46
	40	75	75	75	73	67	62	58	54	51	50	48	46
	50	68	68	68	68	67	62	58	54	51	50	48	46
	60	63	63	63	63	63	62	58	54	51	50	48	46
	70	58	58	58	58	58	58	58	54	51	50	48	46
	80	55	55	55	55	55	55	55	54	51	50	48	46
	90	52	52	52	52	52	52	52	52	51	50	48	46

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 45		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Landscape				
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	121	117	107	99	92	87	81	79	77	73
	10	114	112	111	109	107	99	92	87	81	79	77	73
	20	100	98	97	95	93	91	88	86	81	79	77	73
	30	86	86	85	85	83	81	80	78	76	75	75	73
	40	75	75	75	75	75	74	73	72	70	70	69	68
	50	68	68	68	68	68	68	68	67	66	65	65	64
	60	63	63	63	63	63	63	63	63	62	61	61	60
	70	58	58	58	58	58	58	58	58	58	58	58	57
	80	55	55	55	55	55	55	55	55	55	55	55	55
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 2	0	101	92	88	84	77	72	67	62	59	57	55	52
	10	101	92	88	84	77	72	67	62	59	57	55	52
	20	100	92	88	84	77	72	67	62	59	57	55	52
	30	86	86	85	84	77	72	67	62	59	57	55	52
	40	75	75	75	75	75	72	67	62	59	57	55	52
	50	68	68	68	68	68	68	67	62	59	57	55	52
	60	63	63	63	63	63	63	63	62	59	57	55	52
	70	58	58	58	58	58	58	58	58	58	57	55	52
	80	55	55	55	55	55	55	55	55	55	55	55	52
	90	52	52	52	52	52	52	52	52	52	52	52	52
Zone 3	0	81	74	70	67	62	58	54	50	48	46	45	42
	10	81	74	70	67	62	58	54	50	48	46	45	42
	20	81	74	70	67	62	58	54	50	48	46	45	42
	30	81	74	70	67	62	58	54	50	48	46	45	42
	40	75	74	70	67	62	58	54	50	48	46	45	42
	50	68	68	68	67	62	58	54	50	48	46	45	42
	60	63	63	63	63	62	58	54	50	48	46	45	42
	70	58	58	58	58	58	58	54	50	48	46	45	42
	80	55	55	55	55	55	55	54	50	48	46	45	42
	90	52	52	52	52	52	52	52	50	48	46	45	42

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 46		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Landscape				
		Roof Angle: 27 < θ ≤ 45 degrees							Exposure Category: B				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	121	121	119	116	112	106	101	96	91	89	87	83
	10	119	115	113	111	107	103	99	95	91	89	87	83
	20	104	101	99	98	95	92	89	86	84	82	81	79
	30	93	91	89	88	86	84	82	80	78	77	76	74
	40	83	83	82	81	80	78	76	74	73	72	72	69
	50	75	75	75	75	74	73	72	70	69	68	67	66
	60	69	69	69	69	69	69	68	66	65	64	64	63
	70	65	65	65	65	65	65	64	63	62	62	61	60
	80	61	61	61	61	61	61	61	60	59	59	58	58
	90	58	58	58	58	58	58	58	58	57	57	56	55
Zone 2	0	121	121	119	116	112	105	98	92	86	84	82	77
	10	119	115	113	111	107	103	98	92	86	84	82	77
	20	104	101	99	98	95	92	89	86	84	82	81	77
	30	93	91	89	88	86	84	82	80	78	77	76	74
	40	83	83	82	81	80	78	76	74	73	72	72	69
	50	75	75	75	75	74	73	72	70	69	68	67	66
	60	69	69	69	69	69	69	68	66	65	64	64	63
	70	65	65	65	65	65	65	64	63	62	62	61	60
	80	61	61	61	61	61	61	61	60	59	59	58	58
	90	58	58	58	58	58	58	58	58	57	57	56	55
Zone 3	0	121	121	119	116	112	105	98	92	86	84	82	77
	10	119	115	113	111	107	103	98	92	86	84	82	77
	20	104	101	99	98	95	92	89	86	84	82	81	77
	30	93	91	89	88	86	84	82	80	78	77	76	74
	40	83	83	82	81	80	78	76	74	73	72	72	69
	50	75	75	75	75	74	73	72	70	69	68	67	66
	60	69	69	69	69	69	69	68	66	65	64	64	63
	70	65	65	65	65	65	65	64	63	62	62	61	60
	80	61	61	61	61	61	61	61	60	59	59	58	58
	90	58	58	58	58	58	58	58	58	57	57	56	55

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 48		Mean Roof Height: 30 < h ≤ 60 ft							Panel Orientation: Landscape				
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	119	113	111	107	101	95	90	85	81	79	77	73
	10	113	108	106	103	99	95	90	85	81	79	77	73
	20	99	96	94	92	89	86	83	80	77	76	75	72
	30	89	87	86	84	82	79	77	75	72	72	70	68
	40	82	80	79	78	76	74	72	70	68	67	66	65
	50	75	75	74	73	72	70	68	66	65	64	63	62
	60	69	69	69	69	68	66	65	63	62	61	60	59
	70	65	65	65	65	64	63	62	61	59	59	58	57
	80	61	61	61	61	61	60	59	58	57	56	56	55
	90	58	58	58	58	58	58	57	56	55	54	54	53
Zone 2	0	119	113	111	106	98	91	85	80	75	73	72	67
	10	113	108	106	103	98	91	85	80	75	73	72	67
	20	99	96	94	92	89	86	83	80	75	73	72	67
	30	89	87	86	84	82	79	77	75	72	72	70	67
	40	82	80	79	78	76	74	72	70	68	67	66	65
	50	75	75	74	73	72	70	68	66	65	64	63	62
	60	69	69	69	69	68	66	65	63	62	61	60	59
	70	65	65	65	65	64	63	62	61	59	59	58	57
	80	61	61	61	61	61	60	59	58	57	56	56	55
	90	58	58	58	58	58	58	57	56	55	54	54	53
Zone 3	0	119	113	111	106	98	91	85	80	75	73	72	67
	10	113	108	106	103	98	91	85	80	75	73	72	67
	20	99	96	94	92	89	86	83	80	75	73	72	67
	30	89	87	86	84	82	79	77	75	72	72	70	67
	40	82	80	79	78	76	74	72	70	68	67	66	65
	50	75	75	74	73	72	70	68	66	65	64	63	62
	60	69	69	69	69	68	66	65	63	62	61	60	59
	70	65	65	65	65	64	63	62	61	59	59	58	57
	80	61	61	61	61	61	60	59	58	57	56	56	55
	90	58	58	58	58	58	58	57	56	55	54	54	53

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 48		Mean Roof Height: 30 < h ≤ 60 ft						Panel Orientation: Landscape					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	114	108	105	101	95	89	84	80	75	74	72	68
	10	109	104	102	99	95	89	84	80	75	74	72	68
	20	97	93	91	89	86	83	80	77	74	72	72	68
	30	88	85	83	82	79	77	74	72	70	68	67	65
	40	81	78	77	76	74	72	70	68	66	65	64	62
	50	75	73	72	72	70	68	66	64	63	62	61	59
	60	69	69	68	68	66	65	63	62	60	59	59	57
	70	65	65	65	64	63	62	60	59	58	57	56	55
	80	61	61	61	61	60	59	58	57	56	55	54	53
	90	58	58	58	58	58	57	56	55	54	53	53	51
Zone 2	0	114	107	103	98	91	84	79	74	69	68	66	62
	10	109	104	102	98	91	84	79	74	69	68	66	62
	20	97	93	91	89	86	83	79	74	69	68	66	62
	30	88	85	83	82	79	77	74	72	69	68	66	62
	40	81	78	77	76	74	72	70	68	66	65	64	62
	50	75	73	72	72	70	68	66	64	63	62	61	59
	60	69	69	68	68	66	65	63	62	60	59	59	57
	70	65	65	65	64	63	62	60	59	58	57	56	55
	80	61	61	61	61	60	59	58	57	56	55	54	53
	90	58	58	58	58	58	57	56	55	54	53	53	51
Zone 3	0	114	107	103	98	91	84	79	74	69	68	66	62
	10	109	104	102	98	91	84	79	74	69	68	66	62
	20	97	93	91	89	86	83	79	74	69	68	66	62
	30	88	85	83	82	79	77	74	72	69	68	66	62
	40	81	78	77	76	74	72	70	68	66	65	64	62
	50	75	73	72	72	70	68	66	64	63	62	61	59
	60	69	69	68	68	66	65	63	62	60	59	59	57
	70	65	65	65	64	63	62	60	59	58	57	56	55
	80	61	61	61	61	60	59	58	57	56	55	54	53
	90	58	58	58	58	58	57	56	55	54	53	53	51

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in landscape orientation with a maximum width of 42"

Rail Spans for Quick Mount PV QRail Standard System

Table 49		Mean Roof Height: 0 < h ≤ 60 ft							Panel Orientation: Portrait				
		Roof Angle: 0 < θ ≤ 7 degrees							Exposure Category: B				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	114	114	108	103	94	87	80	75	70	68	66	62
	10	96	96	95	95	94	87	80	75	70	68	66	62
	20	79	79	79	79	79	79	78	75	70	68	66	62
	30	67	67	67	67	67	67	67	67	67	66	66	62
	40	59	59	59	59	59	59	59	59	59	59	59	59
	50	53	53	53	53	53	53	53	53	53	53	53	53
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	45	45	45	45	45	45	45	45	45	45	45	45
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	40	40	40	40	40	40	40	40	40	40	40	40
Zone 2	0	91	82	78	74	68	63	59	55	51	50	48	46
	10	91	82	78	74	68	63	59	55	51	50	48	46
	20	79	79	78	74	68	63	59	55	51	50	48	46
	30	67	67	67	67	67	63	59	55	51	50	48	46
	40	59	59	59	59	59	59	59	55	51	50	48	46
	50	53	53	53	53	53	53	53	53	51	50	48	46
	60	49	49	49	49	49	49	49	49	49	49	48	46
	70	45	45	45	45	45	45	45	45	45	45	45	45
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	40	40	40	40	40	40	40	40	40	40	40	40
Zone 3	0	72	64	61	59	54	50	46	43	41	40	38	36
	10	72	64	61	59	54	50	46	43	41	40	38	36
	20	72	64	61	59	54	50	46	43	41	40	38	36
	30	67	64	61	59	54	50	46	43	41	40	38	36
	40	59	59	59	59	54	50	46	43	41	40	38	36
	50	53	53	53	53	53	50	46	43	41	40	38	36
	60	49	49	49	49	49	49	46	43	41	40	38	36
	70	45	45	45	45	45	45	45	43	41	40	38	36
	80	43	43	43	43	43	43	43	43	41	40	38	36
	90	40	40	40	40	40	40	40	40	40	40	38	36

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 82"

Rail Spans for Quick Mount PV QRail Standard System

Table 50		Mean Roof Height: 0 < h ≤ 60 ft							Panel Orientation: Portrait				
		Roof Angle: 0 < θ ≤ 7 degrees							Exposure Category: C				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	108	97	92	88	80	74	69	64	60	58	57	54
	10	95	94	92	88	80	74	69	64	60	58	57	54
	20	79	79	79	79	78	74	69	64	60	58	57	54
	30	67	67	67	67	67	67	66	64	60	58	57	54
	40	59	59	59	59	59	59	59	59	59	58	57	54
	50	53	53	53	53	53	53	53	53	53	53	53	53
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	45	45	45	45	45	45	45	45	45	45	45	45
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	40	40	40	40	40	40	40	40	40	40	40	40
Zone 2	0	78	70	67	64	59	54	50	48	44	43	42	39
	10	78	70	67	64	59	54	50	48	44	43	42	39
	20	78	70	67	64	59	54	50	48	44	43	42	39
	30	67	67	67	64	59	54	50	48	44	43	42	39
	40	59	59	59	59	59	54	50	48	44	43	42	39
	50	53	53	53	53	53	53	50	48	44	43	42	39
	60	49	49	49	49	49	49	49	48	44	43	42	39
	70	45	45	45	45	45	45	45	45	44	43	42	39
	80	43	43	43	43	43	43	43	43	43	43	42	39
	90	40	40	40	40	40	40	40	40	40	40	40	39
Zone 3	0	61	55	53	51	46	43	40	37	35	34	33	31
	10	61	55	53	51	46	43	40	37	35	34	33	31
	20	61	55	53	51	46	43	40	37	35	34	33	31
	30	61	55	53	51	46	43	40	37	35	34	33	31
	40	59	55	53	51	46	43	40	37	35	34	33	31
	50	53	53	53	51	46	43	40	37	35	34	33	31
	60	49	49	49	49	46	43	40	37	35	34	33	31
	70	45	45	45	45	45	43	40	37	35	34	33	31
	80	43	43	43	43	43	43	40	37	35	34	33	31
	90	40	40	40	40	40	40	40	37	35	34	33	31

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 82"

Rail Spans for Quick Mount PV QRail Standard System

Table 51		Mean Roof Height: 0 < h ≤ 60 ft						Panel Orientation: Portrait					
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	99	89	85	81	74	68	64	59	56	54	52	50
	10	95	89	85	81	74	68	64	59	56	54	52	50
	20	79	79	79	78	74	68	64	59	56	54	52	50
	30	67	67	67	67	67	66	64	59	56	54	52	50
	40	59	59	59	59	59	59	59	59	56	54	52	50
	50	53	53	53	53	53	53	53	53	53	53	52	50
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	45	45	45	45	45	45	45	45	45	45	45	45
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	40	40	40	40	40	40	40	40	40	40	40	40
Zone 2	0	72	65	62	59	54	50	48	44	41	40	39	37
	10	72	65	62	59	54	50	48	44	41	40	39	37
	20	72	65	62	59	54	50	48	44	41	40	39	37
	30	67	65	62	59	54	50	48	44	41	40	39	37
	40	59	59	59	59	54	50	48	44	41	40	39	37
	50	53	53	53	53	53	50	48	44	41	40	39	37
	60	49	49	49	49	49	49	48	44	41	40	39	37
	70	45	45	45	45	45	45	45	44	41	40	39	37
	80	43	43	43	43	43	43	43	43	41	40	39	37
	90	40	40	40	40	40	40	40	40	40	40	39	37
Zone 3	0	57	51	49	48	43	40	37	35	33	32	31	29
	10	57	51	49	48	43	40	37	35	33	32	31	29
	20	57	51	49	48	43	40	37	35	33	32	31	29
	30	57	51	49	48	43	40	37	35	33	32	31	29
	40	57	51	49	48	43	40	37	35	33	32	31	29
	50	53	51	49	48	43	40	37	35	33	32	31	29
	60	49	49	49	48	43	40	37	35	33	32	31	29
	70	45	45	45	45	43	40	37	35	33	32	31	29
	80	43	43	43	43	43	40	37	35	33	32	31	29
	90	40	40	40	40	40	40	37	35	33	32	31	29

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 82"

Rail Spans for Quick Mount PV QRail Standard System

Table 52		Mean Roof Height: 0 < h ≤ 60 ft							Panel Orientation: Portrait				
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: B											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	112	108	106	104	96	89	83	77	73	70	68	65
	10	90	88	87	86	84	81	79	77	73	70	68	65
	20	72	72	72	72	72	69	68	67	65	65	64	63
	30	61	61	61	61	61	61	60	59	58	58	57	57
	40	54	54	54	54	54	54	54	54	53	53	53	52
	50	49	49	49	49	49	49	49	49	49	49	49	48
	60	45	45	45	45	45	45	45	45	45	45	45	45
	70	42	42	42	42	42	42	42	42	42	42	42	42
	80	39	39	39	39	39	39	39	39	39	39	39	39
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 2	0	91	82	78	75	69	64	59	56	52	51	49	48
	10	90	82	78	75	69	64	59	56	52	51	49	48
	20	72	72	72	72	69	64	59	56	52	51	49	48
	30	61	61	61	61	61	61	59	56	52	51	49	48
	40	54	54	54	54	54	54	54	54	52	51	49	48
	50	49	49	49	49	49	49	49	49	49	49	49	48
	60	45	45	45	45	45	45	45	45	45	45	45	45
	70	42	42	42	42	42	42	42	42	42	42	42	42
	80	39	39	39	39	39	39	39	39	39	39	39	39
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 3	0	73	66	63	60	55	51	48	45	42	41	40	38
	10	73	66	63	60	55	51	48	45	42	41	40	38
	20	72	66	63	60	55	51	48	45	42	41	40	38
	30	61	61	61	60	55	51	48	45	42	41	40	38
	40	54	54	54	54	54	51	48	45	42	41	40	38
	50	49	49	49	49	49	49	48	45	42	41	40	38
	60	45	45	45	45	45	45	45	45	42	41	40	38
	70	42	42	42	42	42	42	42	42	42	41	40	38
	80	39	39	39	39	39	39	39	39	39	39	39	38
	90	37	37	37	37	37	37	37	37	37	37	37	37

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 82"

Rail Spans for Quick Mount PV QRail Standard System

Table 53		Mean Roof Height: 0 < h ≤ 60 ft						Panel Orientation: Portrait					
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	106	99	94	90	83	77	72	67	63	61	59	56
	10	87	84	83	82	79	77	72	67	63	61	59	56
	20	72	72	70	70	68	66	65	63	62	61	59	56
	30	61	61	61	61	60	59	58	57	56	55	55	54
	40	54	54	54	54	54	54	53	52	51	51	51	50
	50	49	49	49	49	49	49	49	49	48	48	48	46
	60	45	45	45	45	45	45	45	45	45	45	44	44
	70	42	42	42	42	42	42	42	42	42	42	42	42
	80	39	39	39	39	39	39	39	39	39	39	39	39
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 2	0	78	72	68	65	60	55	51	48	45	44	43	40
	10	78	72	68	65	60	55	51	48	45	44	43	40
	20	72	72	68	65	60	55	51	48	45	44	43	40
	30	61	61	61	61	60	55	51	48	45	44	43	40
	40	54	54	54	54	54	54	51	48	45	44	43	40
	50	49	49	49	49	49	49	49	48	45	44	43	40
	60	45	45	45	45	45	45	45	45	45	44	43	40
	70	42	42	42	42	42	42	42	42	42	42	42	40
	80	39	39	39	39	39	39	39	39	39	39	39	39
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 3	0	63	57	54	52	48	44	41	39	36	35	34	32
	10	63	57	54	52	48	44	41	39	36	35	34	32
	20	63	57	54	52	48	44	41	39	36	35	34	32
	30	61	57	54	52	48	44	41	39	36	35	34	32
	40	54	54	54	52	48	44	41	39	36	35	34	32
	50	49	49	49	49	48	44	41	39	36	35	34	32
	60	45	45	45	45	45	44	41	39	36	35	34	32
	70	42	42	42	42	42	42	41	39	36	35	34	32
	80	39	39	39	39	39	39	39	39	36	35	34	32
	90	37	37	37	37	37	37	37	37	36	35	34	32

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 82"

Rail Spans for Quick Mount PV QRail Standard System

Table 54		Mean Roof Height: 0 < h ≤ 60 ft						Panel Orientation: Portrait					
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	101	91	87	83	77	72	66	62	58	56	55	52
	10	85	82	81	80	77	72	66	62	58	56	55	52
	20	72	70	69	68	66	65	63	61	58	56	55	52
	30	61	61	61	60	59	58	57	56	54	54	53	52
	40	54	54	54	54	54	53	52	51	50	50	49	48
	50	49	49	49	49	49	49	48	48	48	48	46	45
	60	45	45	45	45	45	45	45	45	44	44	44	43
	70	42	42	42	42	42	42	42	42	42	42	41	41
	80	39	39	39	39	39	39	39	39	39	39	39	39
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 2	0	72	66	63	60	55	51	48	45	42	41	40	37
	10	72	66	63	60	55	51	48	45	42	41	40	37
	20	72	66	63	60	55	51	48	45	42	41	40	37
	30	61	61	61	60	55	51	48	45	42	41	40	37
	40	54	54	54	54	54	51	48	45	42	41	40	37
	50	49	49	49	49	49	49	48	45	42	41	40	37
	60	45	45	45	45	45	45	45	45	42	41	40	37
	70	42	42	42	42	42	42	42	42	42	41	40	37
	80	39	39	39	39	39	39	39	39	39	39	39	37
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 3	0	58	53	50	48	44	41	38	36	34	33	32	30
	10	58	53	50	48	44	41	38	36	34	33	32	30
	20	58	53	50	48	44	41	38	36	34	33	32	30
	30	58	53	50	48	44	41	38	36	34	33	32	30
	40	54	53	50	48	44	41	38	36	34	33	32	30
	50	49	49	49	48	44	41	38	36	34	33	32	30
	60	45	45	45	45	44	41	38	36	34	33	32	30
	70	42	42	42	42	42	41	38	36	34	33	32	30
	80	39	39	39	39	39	39	38	36	34	33	32	30
	90	37	37	37	37	37	37	37	36	34	33	32	30

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 82"

Rail Spans for Quick Mount PV QRail Standard System

Table 55		Mean Roof Height: 0 < h ≤ 60 ft						Panel Orientation: Portrait					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: B											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	97	91	88	86	81	76	72	69	65	63	62	59
	10	87	84	81	81	78	75	72	69	65	63	62	59
	20	76	74	72	72	69	67	65	63	61	59	59	57
	30	68	66	65	65	63	61	60	58	57	55	55	53
	40	62	61	60	60	58	57	56	54	53	52	52	50
	50	56	56	56	56	54	53	52	51	50	49	49	48
	60	51	51	51	51	51	50	49	49	48	48	48	46
	70	48	48	48	48	48	48	48	46	45	45	45	44
	80	45	45	45	45	45	45	45	44	44	43	43	42
	90	43	43	43	43	43	43	43	43	42	41	41	41
Zone 2	0	97	91	88	86	81	76	72	67	63	60	59	56
	10	87	84	81	81	78	75	72	67	63	60	59	56
	20	76	74	72	72	69	67	65	63	61	59	59	56
	30	68	66	65	65	63	61	60	58	57	55	55	53
	40	62	61	60	60	58	57	56	54	53	52	52	50
	50	56	56	56	56	54	53	52	51	50	49	49	48
	60	51	51	51	51	51	50	49	49	48	48	48	46
	70	48	48	48	48	48	48	48	46	45	45	45	44
	80	45	45	45	45	45	45	45	44	44	43	43	42
	90	43	43	43	43	43	43	43	43	42	41	41	41
Zone 3	0	97	91	88	86	81	76	72	67	63	60	59	56
	10	87	84	81	81	78	75	72	67	63	60	59	56
	20	76	74	72	72	69	67	65	63	61	59	59	56
	30	68	66	65	65	63	61	60	58	57	55	55	53
	40	62	61	60	60	58	57	56	54	53	52	52	50
	50	56	56	56	56	54	53	52	51	50	49	49	48
	60	51	51	51	51	51	50	49	49	48	48	48	46
	70	48	48	48	48	48	48	48	46	45	45	45	44
	80	45	45	45	45	45	45	45	44	44	43	43	42
	90	43	43	43	43	43	43	43	43	42	41	41	41

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 82"

Rail Spans for Quick Mount PV QRail Standard System

Table 56		Mean Roof Height: 0 < h ≤ 60 ft						Panel Orientation: Portrait					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: C											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	88	82	79	77	72	68	64	61	58	56	55	52
	10	82	79	75	75	72	68	64	61	58	56	55	52
	20	73	70	67	67	65	63	60	58	56	54	54	52
	30	66	64	62	62	60	58	56	54	53	51	51	49
	40	60	59	57	57	56	54	53	51	50	48	48	48
	50	56	55	54	54	52	51	50	49	48	46	46	45
	60	51	51	51	51	49	48	48	46	45	44	44	43
	70	48	48	48	48	48	46	45	44	43	42	42	41
	80	45	45	45	45	45	44	43	42	42	41	41	40
	90	43	43	43	43	43	42	42	41	40	39	39	39
Zone 2	0	88	82	79	77	72	66	61	58	54	52	51	48
	10	82	79	75	75	72	66	61	58	54	52	51	48
	20	73	70	67	67	65	63	60	58	54	52	51	48
	30	66	64	62	62	60	58	56	54	53	51	51	48
	40	60	59	57	57	56	54	53	51	50	48	48	48
	50	56	55	54	54	52	51	50	49	48	46	46	45
	60	51	51	51	51	49	48	48	46	45	44	44	43
	70	48	48	48	48	48	46	45	44	43	42	42	41
	80	45	45	45	45	45	44	43	42	42	41	41	40
	90	43	43	43	43	43	42	42	41	40	39	39	39
Zone 3	0	88	82	79	77	72	66	61	58	54	52	51	48
	10	82	79	75	75	72	66	61	58	54	52	51	48
	20	73	70	67	67	65	63	60	58	54	52	51	48
	30	66	64	62	62	60	58	56	54	53	51	51	48
	40	60	59	57	57	56	54	53	51	50	48	48	48
	50	56	55	54	54	52	51	50	49	48	46	46	45
	60	51	51	51	51	49	48	48	46	45	44	44	43
	70	48	48	48	48	48	46	45	44	43	42	42	41
	80	45	45	45	45	45	44	43	42	42	41	41	40
	90	43	43	43	43	43	42	42	41	40	39	39	39

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 82"

Rail Spans for Quick Mount PV QRail Standard System

Table 57		Mean Roof Height: 0 < h ≤ 60 ft							Panel Orientation: Portrait				
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	84	78	75	73	68	64	60	57	54	53	51	49
	10	79	76	73	72	68	64	60	57	54	53	51	49
	20	72	68	65	65	63	60	58	56	53	52	51	49
	30	64	62	60	60	58	56	54	52	50	49	49	48
	40	59	57	56	56	54	53	51	49	48	46	46	45
	50	55	54	52	52	51	50	48	48	46	44	44	43
	60	51	51	50	50	48	48	46	45	44	43	43	42
	70	48	48	48	48	46	45	44	43	42	41	41	40
	80	45	45	45	45	44	43	42	41	41	40	40	39
	90	43	43	43	43	42	42	41	40	39	38	38	38
Zone 2	0	84	78	73	72	66	61	57	53	50	48	48	45
	10	79	76	73	72	66	61	57	53	50	48	48	45
	20	72	68	65	65	63	60	57	53	50	48	48	45
	30	64	62	60	60	58	56	54	52	50	48	48	45
	40	59	57	56	56	54	53	51	49	48	46	46	45
	50	55	54	52	52	51	50	48	48	46	44	44	43
	60	51	51	50	50	48	48	46	45	44	43	43	42
	70	48	48	48	48	46	45	44	43	42	41	41	40
	80	45	45	45	45	44	43	42	41	41	40	40	39
	90	43	43	43	43	42	42	41	40	39	38	38	38
Zone 3	0	84	78	73	72	66	61	57	53	50	48	48	45
	10	79	76	73	72	66	61	57	53	50	48	48	45
	20	72	68	65	65	63	60	57	53	50	48	48	45
	30	64	62	60	60	58	56	54	52	50	48	48	45
	40	59	57	56	56	54	53	51	49	48	46	46	45
	50	55	54	52	52	51	50	48	48	46	44	44	43
	60	51	51	50	50	48	48	46	45	44	43	43	42
	70	48	48	48	48	46	45	44	43	42	41	41	40
	80	45	45	45	45	44	43	42	41	41	40	40	39
	90	43	43	43	43	42	42	41	40	39	38	38	38

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 82"

Rail Spans for Quick Mount PV QRail Standard System

Table 58		Mean Roof Height: 0 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 0 < θ ≤ 7 degrees							Exposure Category: B				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	98	98	98	98	98	98	90	84	79	76	74	70
	10	97	97	97	97	96	95	90	84	79	76	74	70
	20	80	80	80	80	80	80	80	79	78	76	74	70
	30	68	68	68	68	68	68	68	68	68	68	68	67
	40	59	59	59	59	59	59	59	59	59	59	59	59
	50	54	54	54	54	54	54	54	54	54	54	54	54
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 2	0	98	92	88	84	77	72	66	61	58	56	54	51
	10	97	92	88	84	77	72	66	61	58	56	54	51
	20	80	80	80	80	77	72	66	61	58	56	54	51
	30	68	68	68	68	68	68	66	61	58	56	54	51
	40	59	59	59	59	59	59	59	59	58	56	54	51
	50	54	54	54	54	54	54	54	54	54	54	54	51
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 3	0	80	72	69	66	60	56	52	49	46	44	43	41
	10	80	72	69	66	60	56	52	49	46	44	43	41
	20	80	72	69	66	60	56	52	49	46	44	43	41
	30	68	68	68	66	60	56	52	49	46	44	43	41
	40	59	59	59	59	59	56	52	49	46	44	43	41
	50	54	54	54	54	54	54	52	49	46	44	43	41
	60	49	49	49	49	49	49	49	49	46	44	43	41
	70	46	46	46	46	46	46	46	46	46	44	43	41
	80	43	43	43	43	43	43	43	43	43	43	43	41
	90	41	41	41	41	41	41	41	41	41	41	41	41

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 80"

Rail Spans for Quick Mount PV QRail Standard System

Table 59		Mean Roof Height: 0 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 0 < θ ≤ 7 degrees							Exposure Category: C				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	98	98	98	96	88	81	75	70	66	64	62	58
	10	97	96	95	95	88	81	75	70	66	64	62	58
	20	80	80	80	80	80	79	75	70	66	64	62	58
	30	68	68	68	68	68	68	68	67	66	64	62	58
	40	59	59	59	59	59	59	59	59	59	59	59	58
	50	54	54	54	54	54	54	54	54	54	54	54	54
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 2	0	85	77	73	70	64	59	55	51	48	48	45	43
	10	85	77	73	70	64	59	55	51	48	48	45	43
	20	80	77	73	70	64	59	55	51	48	48	45	43
	30	68	68	68	68	64	59	55	51	48	48	45	43
	40	59	59	59	59	59	59	55	51	48	48	45	43
	50	54	54	54	54	54	54	54	51	48	48	45	43
	60	49	49	49	49	49	49	49	49	48	48	45	43
	70	46	46	46	46	46	46	46	46	46	46	45	43
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 3	0	67	60	58	55	51	48	44	41	38	37	36	34
	10	67	60	58	55	51	48	44	41	38	37	36	34
	20	67	60	58	55	51	48	44	41	38	37	36	34
	30	67	60	58	55	51	48	44	41	38	37	36	34
	40	59	59	58	55	51	48	44	41	38	37	36	34
	50	54	54	54	54	51	48	44	41	38	37	36	34
	60	49	49	49	49	49	48	44	41	38	37	36	34
	70	46	46	46	46	46	46	44	41	38	37	36	34
	80	43	43	43	43	43	43	43	41	38	37	36	34
	90	41	41	41	41	41	41	41	41	38	37	36	34

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 80"

Rail Spans for Quick Mount PV QRail Standard System

Table 60		Mean Roof Height: 0 < h ≤ 30 ft						Panel Orientation: Portrait					
		Roof Angle: 0 < θ ≤ 7 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	98	97	92	88	80	74	69	64	60	58	57	53
	10	96	95	92	88	80	74	69	64	60	58	57	53
	20	80	80	80	80	78	74	69	64	60	58	57	53
	30	68	68	68	68	68	68	67	64	60	58	57	53
	40	59	59	59	59	59	59	59	59	59	58	57	53
	50	54	54	54	54	54	54	54	54	54	54	54	53
	60	49	49	49	49	49	49	49	49	49	49	49	49
	70	46	46	46	46	46	46	46	46	46	46	46	46
	80	43	43	43	43	43	43	43	43	43	43	43	43
	90	41	41	41	41	41	41	41	41	41	41	41	41
Zone 2	0	77	70	67	64	58	54	50	48	44	43	42	39
	10	77	70	67	64	58	54	50	48	44	43	42	39
	20	77	70	67	64	58	54	50	48	44	43	42	39
	30	68	68	67	64	58	54	50	48	44	43	42	39
	40	59	59	59	59	58	54	50	48	44	43	42	39
	50	54	54	54	54	54	54	50	48	44	43	42	39
	60	49	49	49	49	49	49	49	48	44	43	42	39
	70	46	46	46	46	46	46	46	46	44	43	42	39
	80	43	43	43	43	43	43	43	43	43	43	42	39
	90	41	41	41	41	41	41	41	41	41	41	41	39
Zone 3	0	61	55	53	50	46	43	40	37	35	34	33	31
	10	61	55	53	50	46	43	40	37	35	34	33	31
	20	61	55	53	50	46	43	40	37	35	34	33	31
	30	61	55	53	50	46	43	40	37	35	34	33	31
	40	59	55	53	50	46	43	40	37	35	34	33	31
	50	54	54	53	50	46	43	40	37	35	34	33	31
	60	49	49	49	49	46	43	40	37	35	34	33	31
	70	46	46	46	46	46	43	40	37	35	34	33	31
	80	43	43	43	43	43	43	40	37	35	34	33	31
	90	41	41	41	41	41	41	40	37	35	34	33	31

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 80"

Rail Spans for Quick Mount PV QRail Standard System

Table 61		Mean Roof Height: 0 < h ≤ 30 ft						Panel Orientation: Portrait					
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: B											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	98	98	98	98	98	98	93	87	81	79	77	72
	10	93	91	90	89	87	85	83	81	79	78	77	72
	20	73	73	73	73	73	72	72	69	68	68	67	66
	30	62	62	62	62	62	62	62	62	61	60	60	59
	40	54	54	54	54	54	54	54	54	54	54	54	54
	50	49	49	49	49	49	49	49	49	49	49	49	49
	60	45	45	45	45	45	45	45	45	45	45	45	45
	70	42	42	42	42	42	42	42	42	42	42	42	42
	80	40	40	40	40	40	40	40	40	40	40	40	40
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 2	0	98	92	88	84	77	72	67	62	59	57	55	52
	10	93	91	88	84	77	72	67	62	59	57	55	52
	20	73	73	73	73	73	72	67	62	59	57	55	52
	30	62	62	62	62	62	62	62	62	59	57	55	52
	40	54	54	54	54	54	54	54	54	54	54	54	52
	50	49	49	49	49	49	49	49	49	49	49	49	49
	60	45	45	45	45	45	45	45	45	45	45	45	45
	70	42	42	42	42	42	42	42	42	42	42	42	42
	80	40	40	40	40	40	40	40	40	40	40	40	40
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 3	0	81	74	70	67	62	57	53	50	48	46	44	42
	10	81	74	70	67	62	57	53	50	48	46	44	42
	20	73	73	70	67	62	57	53	50	48	46	44	42
	30	62	62	62	62	62	57	53	50	48	46	44	42
	40	54	54	54	54	54	54	53	50	48	46	44	42
	50	49	49	49	49	49	49	49	49	48	46	44	42
	60	45	45	45	45	45	45	45	45	45	45	44	42
	70	42	42	42	42	42	42	42	42	42	42	42	42
	80	40	40	40	40	40	40	40	40	40	40	40	40
	90	37	37	37	37	37	37	37	37	37	37	37	37

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 80"

Rail Spans for Quick Mount PV QRail Standard System

Table 62		Mean Roof Height: 0 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 7 < θ ≤ 27 degrees							Exposure Category: C				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	98	98	98	98	90	84	78	73	68	66	64	61
	10	90	87	86	85	83	80	78	73	68	66	64	61
	20	73	73	72	72	70	69	67	66	64	64	63	61
	30	62	62	62	62	62	61	60	59	58	57	57	56
	40	54	54	54	54	54	54	54	54	53	53	52	51
	50	49	49	49	49	49	49	49	49	49	49	49	48
	60	45	45	45	45	45	45	45	45	45	45	45	45
	70	42	42	42	42	42	42	42	42	42	42	42	42
	80	40	40	40	40	40	40	40	40	40	40	40	40
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 2	0	85	77	74	70	65	60	56	52	49	48	46	44
	10	85	77	74	70	65	60	56	52	49	48	46	44
	20	73	73	72	70	65	60	56	52	49	48	46	44
	30	62	62	62	62	62	60	56	52	49	48	46	44
	40	54	54	54	54	54	54	54	52	49	48	46	44
	50	49	49	49	49	49	49	49	49	49	48	46	44
	60	45	45	45	45	45	45	45	45	45	45	45	44
	70	42	42	42	42	42	42	42	42	42	42	42	42
	80	40	40	40	40	40	40	40	40	40	40	40	40
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 3	0	68	62	59	57	52	48	45	42	40	38	37	35
	10	68	62	59	57	52	48	45	42	40	38	37	35
	20	68	62	59	57	52	48	45	42	40	38	37	35
	30	62	62	59	57	52	48	45	42	40	38	37	35
	40	54	54	54	54	52	48	45	42	40	38	37	35
	50	49	49	49	49	49	48	45	42	40	38	37	35
	60	45	45	45	45	45	45	45	42	40	38	37	35
	70	42	42	42	42	42	42	42	42	40	38	37	35
	80	40	40	40	40	40	40	40	40	40	38	37	35
	90	37	37	37	37	37	37	37	37	37	37	37	35

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 80"

Rail Spans for Quick Mount PV QRail Standard System

Table 63		Mean Roof Height: 0 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 7 < θ ≤ 27 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	98	98	94	90	83	77	72	67	63	61	59	56
	10	88	85	84	82	80	77	72	67	63	61	59	56
	20	73	72	72	70	69	67	65	64	62	61	59	56
	30	62	62	62	62	61	60	59	58	56	56	55	54
	40	54	54	54	54	54	54	54	53	52	51	51	50
	50	49	49	49	49	49	49	49	49	48	48	48	48
	60	45	45	45	45	45	45	45	45	45	45	45	44
	70	42	42	42	42	42	42	42	42	42	42	42	42
	80	40	40	40	40	40	40	40	40	40	40	40	40
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 2	0	78	72	67	65	59	55	51	48	45	44	43	40
	10	78	72	67	65	59	55	51	48	45	44	43	40
	20	73	72	67	65	59	55	51	48	45	44	43	40
	30	62	62	62	62	59	55	51	48	45	44	43	40
	40	54	54	54	54	54	54	51	48	45	44	43	40
	50	49	49	49	49	49	49	49	48	45	44	43	40
	60	45	45	45	45	45	45	45	45	45	44	43	40
	70	42	42	42	42	42	42	42	42	42	42	42	40
	80	40	40	40	40	40	40	40	40	40	40	40	40
	90	37	37	37	37	37	37	37	37	37	37	37	37
Zone 3	0	63	57	54	52	48	44	41	39	36	35	34	32
	10	63	57	54	52	48	44	41	39	36	35	34	32
	20	63	57	54	52	48	44	41	39	36	35	34	32
	30	62	57	54	52	48	44	41	39	36	35	34	32
	40	54	54	54	52	48	44	41	39	36	35	34	32
	50	49	49	49	49	48	44	41	39	36	35	34	32
	60	45	45	45	45	45	44	41	39	36	35	34	32
	70	42	42	42	42	42	42	41	39	36	35	34	32
	80	40	40	40	40	40	40	40	39	36	35	34	32
	90	37	37	37	37	37	37	37	37	36	35	34	32

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 80"

Rail Spans for Quick Mount PV QRail Standard System

Table 64		Mean Roof Height: 0 < h ≤ 30 ft						Panel Orientation: Portrait					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: B											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	98	97	95	92	87	83	78	75	72	70	68	65
	10	89	87	85	84	81	78	75	73	70	69	68	65
	20	77	75	74	73	72	69	67	65	64	63	62	60
	30	68	67	66	66	64	63	61	60	59	58	57	56
	40	60	60	60	60	59	58	57	56	54	54	53	52
	50	54	54	54	54	54	54	53	52	51	51	50	49
	60	50	50	50	50	50	50	50	49	48	48	48	48
	70	48	48	48	48	48	48	48	48	46	46	45	45
	80	44	44	44	44	44	44	44	44	44	44	43	43
	90	42	42	42	42	42	42	42	42	42	42	42	41
Zone 2	0	98	97	95	92	87	83	78	73	69	67	65	62
	10	89	87	85	84	81	78	75	73	69	67	65	62
	20	77	75	74	73	72	69	67	65	64	63	62	60
	30	68	67	66	66	64	63	61	60	59	58	57	56
	40	60	60	60	60	59	58	57	56	54	54	53	52
	50	54	54	54	54	54	54	53	52	51	51	50	49
	60	50	50	50	50	50	50	50	49	48	48	48	48
	70	48	48	48	48	48	48	48	48	46	46	45	45
	80	44	44	44	44	44	44	44	44	44	44	43	43
	90	42	42	42	42	42	42	42	42	42	42	42	41
Zone 3	0	98	97	95	92	87	83	78	73	69	67	65	62
	10	89	87	85	84	81	78	75	73	69	67	65	62
	20	77	75	74	73	72	69	67	65	64	63	62	60
	30	68	67	66	66	64	63	61	60	59	58	57	56
	40	60	60	60	60	59	58	57	56	54	54	53	52
	50	54	54	54	54	54	54	53	52	51	51	50	49
	60	50	50	50	50	50	50	50	49	48	48	48	48
	70	48	48	48	48	48	48	48	48	46	46	45	45
	80	44	44	44	44	44	44	44	44	44	44	43	43
	90	42	42	42	42	42	42	42	42	42	42	42	41

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 80"

Rail Spans for Quick Mount PV QRail Standard System

Table 65		Mean Roof Height: 0 < h ≤ 30 ft							Panel Orientation: Portrait				
		Roof Angle: 27 < θ ≤ 45 degrees							Exposure Category: C				
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	93	87	84	82	77	73	69	65	62	60	59	56
	10	84	81	79	77	74	72	68	65	62	60	59	56
	20	73	72	70	69	67	64	62	60	58	57	56	55
	30	66	64	63	63	61	59	57	56	54	53	53	51
	40	60	59	58	58	56	55	54	52	51	50	50	48
	50	54	54	54	54	53	52	50	49	48	48	48	46
	60	50	50	50	50	50	49	48	48	46	45	45	44
	70	48	48	48	48	48	46	46	45	44	43	43	42
	80	44	44	44	44	44	44	44	43	42	42	41	41
	90	42	42	42	42	42	42	42	41	40	40	40	39
Zone 2	0	93	87	84	82	76	72	66	62	58	56	55	52
	10	84	81	79	77	74	72	66	62	58	56	55	52
	20	73	72	70	69	67	64	62	60	58	56	55	52
	30	66	64	63	63	61	59	57	56	54	53	53	51
	40	60	59	58	58	56	55	54	52	51	50	50	48
	50	54	54	54	54	53	52	50	49	48	48	48	46
	60	50	50	50	50	50	49	48	48	46	45	45	44
	70	48	48	48	48	48	46	46	45	44	43	43	42
	80	44	44	44	44	44	44	44	43	42	42	41	41
	90	42	42	42	42	42	42	42	41	40	40	40	39
Zone 3	0	93	87	84	82	76	72	66	62	58	56	55	52
	10	84	81	79	77	74	72	66	62	58	56	55	52
	20	73	72	70	69	67	64	62	60	58	56	55	52
	30	66	64	63	63	61	59	57	56	54	53	53	51
	40	60	59	58	58	56	55	54	52	51	50	50	48
	50	54	54	54	54	53	52	50	49	48	48	48	46
	60	50	50	50	50	50	49	48	48	46	45	45	44
	70	48	48	48	48	48	46	46	45	44	43	43	42
	80	44	44	44	44	44	44	44	43	42	42	41	41
	90	42	42	42	42	42	42	42	41	40	40	40	39

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 80"

Rail Spans for Quick Mount PV QRail Standard System

Table 66		Mean Roof Height: 0 < h ≤ 30 ft						Panel Orientation: Portrait					
		Roof Angle: 27 < θ ≤ 45 degrees											
		Exposure Category: D											
Roof Wind Zone	Ground Snow Load	Wind Speed (mph)											
		100	110	115	120	130	140	150	160	170	175	180	190
Zone 1	0	88	82	79	77	72	68	64	61	58	56	55	52
	10	81	78	76	74	72	68	64	61	58	56	55	52
	20	72	69	68	66	64	62	60	57	55	54	53	52
	30	64	63	62	61	59	57	55	54	52	51	50	49
	40	59	58	57	56	55	53	52	50	49	48	48	46
	50	54	54	53	53	51	50	49	48	48	46	45	44
	60	50	50	50	50	49	48	48	46	44	44	43	42
	70	48	48	48	48	46	45	44	44	43	42	42	41
	80	44	44	44	44	44	43	43	42	41	41	40	39
	90	42	42	42	42	42	42	41	40	39	39	39	38
Zone 2	0	88	82	79	76	70	65	61	57	53	52	50	48
	10	81	78	76	74	70	65	61	57	53	52	50	48
	20	72	69	68	66	64	62	60	57	53	52	50	48
	30	64	63	62	61	59	57	55	54	52	51	50	48
	40	59	58	57	56	55	53	52	50	49	48	48	46
	50	54	54	53	53	51	50	49	48	48	46	45	44
	60	50	50	50	50	49	48	48	46	44	44	43	42
	70	48	48	48	48	46	45	44	44	43	42	42	41
	80	44	44	44	44	44	43	43	42	41	41	40	39
	90	42	42	42	42	42	42	41	40	39	39	39	38
Zone 3	0	88	82	79	76	70	65	61	57	53	52	50	48
	10	81	78	76	74	70	65	61	57	53	52	50	48
	20	72	69	68	66	64	62	60	57	53	52	50	48
	30	64	63	62	61	59	57	55	54	52	51	50	48
	40	59	58	57	56	55	53	52	50	49	48	48	46
	50	54	54	53	53	51	50	49	48	48	46	45	44
	60	50	50	50	50	49	48	48	46	44	44	43	42
	70	48	48	48	48	46	45	44	44	43	42	42	41
	80	44	44	44	44	44	43	43	42	41	41	40	39
	90	42	42	42	42	42	42	41	40	39	39	39	38

Notes:

1. Tables are based on critical rail span for loads as specified in Section R301 of the IRC 2018 and allowable design loads per the 2015 Aluminum Design Manual.
2. Panels are assumed to be in portrait orientation with a maximum length of 80"

116	116	116	110	100	92	86	80	75	73	70	66
100	100	100	99	98	92	86	80	75	73	70	66
84	84	84	84	84	84	83	80	75	73	70	66
71	71	71	71	71	71	71	71	71	71	70	66
63	63	63	63	63	63	63	63	63	63	63	63
57	57	57	57	57	57	57	57	57	57	57	57
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
97	87	83	79	73	67	63	58	55	53	52	49
97	87	83	79	73	67	63	58	55	53	52	49
84	84	83	79	73	67	63	58	55	53	52	49
71	71	71	71	71	67	63	58	55	53	52	49
63	63	63	63	63	63	63	58	55	53	52	49
57	57	57	57	57	57	57	57	55	53	52	49
52	52	52	52	52	52	52	52	52	52	52	49
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
76	69	66	63	58	53	50	46	44	42	41	39
76	69	66	63	58	53	50	46	44	42	41	39
76	69	66	63	58	53	50	46	44	42	41	39
71	69	66	63	58	53	50	46	44	42	41	39
63	63	63	63	58	53	50	46	44	42	41	39
57	57	57	57	57	53	50	46	44	42	41	39
52	52	52	52	52	52	50	46	44	42	41	39
48	48	48	48	48	48	48	46	44	42	41	39
45	45	45	45	45	45	45	45	44	42	41	39
43	43	43	43	43	43	43	43	43	42	41	39

116	109	104	99	90	83	77	72	68	65	64	60
100	99	98	98	90	83	77	72	68	65	64	60
84	84	84	84	84	82	77	72	68	65	64	60
71	71	71	71	71	71	71	71	68	65	64	60
63	63	63	63	63	63	63	63	63	63	63	60
57	57	57	57	57	57	57	57	57	57	57	57
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
87	79	75	72	66	61	56	53	50	48	48	44
87	79	75	72	66	61	56	53	50	48	48	44
84	79	75	72	66	61	56	53	50	48	48	44
71	71	71	71	66	61	56	53	50	48	48	44
63	63	63	63	63	61	56	53	50	48	48	44
57	57	57	57	57	57	56	53	50	48	48	44
52	52	52	52	52	52	52	52	50	48	48	44
48	48	48	48	48	48	48	48	48	48	48	44
45	45	45	45	45	45	45	45	45	45	45	44
43	43	43	43	43	43	43	43	43	43	43	43
69	62	59	57	52	48	45	42	39	38	37	35
69	62	59	57	52	48	45	42	39	38	37	35
69	62	59	57	52	48	45	42	39	38	37	35
69	62	59	57	52	48	45	42	39	38	37	35
63	62	59	57	52	48	45	42	39	38	37	35
57	57	57	57	52	48	45	42	39	38	37	35
52	52	52	52	52	48	45	42	39	38	37	35
48	48	48	48	48	48	45	42	39	38	37	35
45	45	45	45	45	45	45	42	39	38	37	35
43	43	43	43	43	43	43	42	39	38	37	35

116	113	111	109	103	95	88	83	78	75	73	69
96	94	93	92	89	87	85	82	78	75	73	69
77	77	77	77	75	74	73	71	70	69	68	67
65	65	65	65	65	65	64	63	62	62	61	60
57	57	57	57	57	57	57	57	57	57	56	55
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
97	88	84	80	74	68	64	59	56	54	53	50
96	88	84	80	74	68	64	59	56	54	53	50
77	77	77	77	74	68	64	59	56	54	53	50
65	65	65	65	65	65	64	59	56	54	53	50
57	57	57	57	57	57	57	57	56	54	53	50
52	52	52	52	52	52	52	52	52	52	52	50
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
78	70	67	64	59	55	51	48	45	44	42	40
78	70	67	64	59	55	51	48	45	44	42	40
77	70	67	64	59	55	51	48	45	44	42	40
65	65	65	64	59	55	51	48	45	44	42	40
57	57	57	57	57	55	51	48	45	44	42	40
52	52	52	52	52	52	51	48	45	44	42	40
48	48	48	48	48	48	48	48	45	44	42	40
44	44	44	44	44	44	44	44	44	44	42	40
42	42	42	42	42	42	42	42	42	42	42	40
39	39	39	39	39	39	39	39	39	39	39	39

113	109	106	101	93	86	80	75	70	68	66	63
94	91	90	89	86	84	80	75	70	68	66	63
77	77	76	75	74	72	70	69	67	66	66	63
65	65	65	65	65	64	63	62	61	60	59	58
57	57	57	57	57	57	57	57	56	55	55	54
52	52	52	52	52	52	52	52	52	51	51	50
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
88	79	76	72	67	62	58	54	51	49	48	45
88	79	76	72	67	62	58	54	51	49	48	45
77	77	76	72	67	62	58	54	51	49	48	45
65	65	65	65	65	62	58	54	51	49	48	45
57	57	57	57	57	57	57	54	51	49	48	45
52	52	52	52	52	52	52	52	51	49	48	45
48	48	48	48	48	48	48	48	48	48	48	45
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
70	64	61	58	54	50	46	43	41	40	38	36
70	64	61	58	54	50	46	43	41	40	38	36
70	64	61	58	54	50	46	43	41	40	38	36
65	64	61	58	54	50	46	43	41	40	38	36
57	57	57	57	54	50	46	43	41	40	38	36
52	52	52	52	52	50	46	43	41	40	38	36
48	48	48	48	48	48	46	43	41	40	38	36
44	44	44	44	44	44	44	43	41	40	38	36
42	42	42	42	42	42	42	42	41	40	38	36
39	39	39	39	39	39	39	39	39	39	38	36

102	96	93	91	86	81	77	73	69	68	66	63
91	88	86	85	81	78	75	73	69	68	66	63
79	77	76	75	72	70	68	66	64	63	62	60
71	69	68	67	66	64	62	61	59	58	58	56
63	63	63	62	61	59	58	57	55	55	54	53
57	57	57	57	57	56	54	53	52	52	51	50
53	53	53	53	53	52	51	51	50	49	49	48
49	49	49	49	49	49	49	48	48	48	46	46
46	46	46	46	46	46	46	46	45	45	45	44
44	44	44	44	44	44	44	44	44	43	43	42
102	96	93	91	86	80	75	70	66	64	62	59
91	88	86	85	81	78	75	70	66	64	62	59
79	77	76	75	72	70	68	66	64	63	62	59
71	69	68	67	66	64	62	61	59	58	58	56
63	63	63	62	61	59	58	57	55	55	54	53
57	57	57	57	57	56	54	53	52	52	51	50
53	53	53	53	53	52	51	51	50	49	49	48
49	49	49	49	49	49	49	48	48	48	46	46
46	46	46	46	46	46	46	46	45	45	45	44
44	44	44	44	44	44	44	44	44	43	43	42
102	96	93	91	86	80	75	70	66	64	62	59
91	88	86	85	81	78	75	70	66	64	62	59
79	77	76	75	72	70	68	66	64	63	62	59
71	69	68	67	66	64	62	61	59	58	58	56
63	63	63	62	61	59	58	57	55	55	54	53
57	57	57	57	57	56	54	53	52	52	51	50
53	53	53	53	53	52	51	51	50	49	49	48
49	49	49	49	49	49	49	48	48	48	46	46
46	46	46	46	46	46	46	46	45	45	45	44
44	44	44	44	44	44	44	44	44	43	43	42

96	90	87	85	80	75	71	67	64	62	61	58
88	84	82	81	77	74	71	67	64	62	61	58
77	74	73	72	69	67	65	63	61	60	59	57
69	67	66	65	64	62	60	58	57	56	55	53
63	62	61	60	59	57	56	55	53	52	52	50
57	57	57	56	55	54	53	52	50	50	49	48
53	53	53	53	52	51	50	49	48	48	48	46
49	49	49	49	49	49	48	48	46	45	45	44
46	46	46	46	46	46	46	45	44	44	43	42
44	44	44	44	44	44	44	43	42	42	42	41
96	90	87	85	78	73	68	64	60	58	56	53
88	84	82	81	77	73	68	64	60	58	56	53
77	74	73	72	69	67	65	63	60	58	56	53
69	67	66	65	64	62	60	58	57	56	55	53
63	62	61	60	59	57	56	55	53	52	52	50
57	57	57	56	55	54	53	52	50	50	49	48
53	53	53	53	52	51	50	49	48	48	48	46
49	49	49	49	49	49	48	48	46	45	45	44
46	46	46	46	46	46	46	45	44	44	43	42
44	44	44	44	44	44	44	43	42	42	42	41
96	90	87	85	78	73	68	64	60	58	56	53
88	84	82	81	77	73	68	64	60	58	56	53
77	74	73	72	69	67	65	63	60	58	56	53
69	67	66	65	64	62	60	58	57	56	55	53
63	62	61	60	59	57	56	55	53	52	52	50
57	57	57	56	55	54	53	52	50	50	49	48
53	53	53	53	52	51	50	49	48	48	48	46
49	49	49	49	49	49	48	48	46	45	45	44
46	46	46	46	46	46	46	45	44	44	43	42
44	44	44	44	44	44	44	43	42	42	42	41

121	121	121	121	121	117	109	101	95	92	89	84
118	118	117	116	115	114	109	101	95	92	89	84
99	99	99	99	99	99	99	98	95	92	89	84
88	88	88	88	88	88	88	88	88	88	88	84
80	80	80	80	80	80	80	80	80	80	80	80
72	72	72	72	72	72	72	72	72	72	72	72
66	66	66	66	66	66	66	66	66	66	66	66
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
121	111	105	101	92	85	79	74	70	68	66	62
118	111	105	101	92	85	79	74	70	68	66	62
99	99	99	99	92	85	79	74	70	68	66	62
88	88	88	88	88	85	79	74	70	68	66	62
80	80	80	80	80	80	79	74	70	68	66	62
72	72	72	72	72	72	72	72	70	68	66	62
66	66	66	66	66	66	66	66	66	66	66	62
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
97	87	83	80	73	68	63	59	55	54	52	49
97	87	83	80	73	68	63	59	55	54	52	49
97	87	83	80	73	68	63	59	55	54	52	49
88	87	83	80	73	68	63	59	55	54	52	49
80	80	80	80	73	68	63	59	55	54	52	49
72	72	72	72	72	68	63	59	55	54	52	49
66	66	66	66	66	66	63	59	55	54	52	49
62	62	62	62	62	62	62	59	55	54	52	49
58	58	58	58	58	58	58	58	55	54	52	49
55	55	55	55	55	55	55	55	55	54	52	49

121	121	121	121	115	106	98	91	86	83	81	76
118	116	115	115	113	106	98	91	86	83	81	76
99	99	99	99	99	99	98	91	86	83	81	76
88	88	88	88	88	88	88	88	86	83	81	76
80	80	80	80	80	80	80	80	80	80	79	76
72	72	72	72	72	72	72	72	72	72	72	72
66	66	66	66	66	66	66	66	66	66	66	66
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
111	100	95	91	83	77	72	67	63	61	59	56
111	100	95	91	83	77	72	67	63	61	59	56
99	99	95	91	83	77	72	67	63	61	59	56
88	88	88	88	83	77	72	67	63	61	59	56
80	80	80	80	80	77	72	67	63	61	59	56
72	72	72	72	72	72	72	67	63	61	59	56
66	66	66	66	66	66	66	66	63	61	59	56
62	62	62	62	62	62	62	62	62	61	59	56
58	58	58	58	58	58	58	58	58	58	58	56
55	55	55	55	55	55	55	55	55	55	55	55
87	79	75	72	66	61	57	53	50	49	48	45
87	79	75	72	66	61	57	53	50	49	48	45
87	79	75	72	66	61	57	53	50	49	48	45
87	79	75	72	66	61	57	53	50	49	48	45
80	79	75	72	66	61	57	53	50	49	48	45
72	72	72	72	66	61	57	53	50	49	48	45
66	66	66	66	66	61	57	53	50	49	48	45
62	62	62	62	62	61	57	53	50	49	48	45
58	58	58	58	58	58	57	53	50	49	48	45
55	55	55	55	55	55	55	53	50	49	48	45

121	121	121	121	121	120	112	105	98	95	93	88
116	114	114	113	111	109	107	105	98	95	93	88
98	98	98	97	96	94	92	90	88	88	87	85
83	83	83	83	83	83	82	81	79	79	78	77
73	73	73	73	73	73	73	73	72	72	71	70
66	66	66	66	66	66	66	66	66	66	66	65
61	61	61	61	61	61	61	61	61	61	61	61
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
121	111	106	102	93	87	81	75	71	69	67	63
116	111	106	102	93	87	81	75	71	69	67	63
98	98	98	97	93	87	81	75	71	69	67	63
83	83	83	83	83	83	81	75	71	69	67	63
73	73	73	73	73	73	73	73	71	69	67	63
66	66	66	66	66	66	66	66	66	66	66	63
61	61	61	61	61	61	61	61	61	61	61	61
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
98	89	85	82	75	70	65	61	57	55	54	51
98	89	85	82	75	70	65	61	57	55	54	51
98	89	85	82	75	70	65	61	57	55	54	51
83	83	83	82	75	70	65	61	57	55	54	51
73	73	73	73	73	70	65	61	57	55	54	51
66	66	66	66	66	66	65	61	57	55	54	51
61	61	61	61	61	61	61	61	57	55	54	51
56	56	56	56	56	56	56	56	56	55	54	51
53	53	53	53	53	53	53	53	53	53	53	51
50	50	50	50	50	50	50	50	50	50	50	50

121	121	121	121	118	109	101	95	89	86	84	79
114	112	111	110	108	106	101	95	89	86	84	79
98	97	96	95	93	91	89	87	85	84	83	79
83	83	83	83	83	81	80	78	77	76	76	74
73	73	73	73	73	73	73	72	71	70	70	68
66	66	66	66	66	66	66	66	66	65	65	64
61	61	61	61	61	61	61	61	61	61	61	60
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
111	101	96	92	85	78	73	68	64	62	61	57
111	101	96	92	85	78	73	68	64	62	61	57
98	97	96	92	85	78	73	68	64	62	61	57
83	83	83	83	83	78	73	68	64	62	61	57
73	73	73	73	73	73	73	68	64	62	61	57
66	66	66	66	66	66	66	66	64	62	61	57
61	61	61	61	61	61	61	61	61	61	61	57
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
89	81	77	74	68	63	59	55	52	50	49	46
89	81	77	74	68	63	59	55	52	50	49	46
89	81	77	74	68	63	59	55	52	50	49	46
83	81	77	74	68	63	59	55	52	50	49	46
73	73	73	73	68	63	59	55	52	50	49	46
66	66	66	66	66	63	59	55	52	50	49	46
61	61	61	61	61	61	59	55	52	50	49	46
56	56	56	56	56	56	56	55	52	50	49	46
53	53	53	53	53	53	53	53	52	50	49	46
50	50	50	50	50	50	50	50	50	50	49	46

121	119	116	114	109	103	97	93	88	86	84	80
116	111	109	107	103	99	96	92	88	86	84	80
100	97	96	95	92	89	86	84	81	80	79	76
90	88	87	86	83	81	79	77	75	74	73	71
80	80	80	79	77	75	74	72	70	70	69	67
73	73	73	73	72	71	69	68	66	66	65	64
67	67	67	67	67	67	65	64	63	62	62	61
63	63	63	63	63	63	62	61	60	60	59	58
59	59	59	59	59	59	59	58	58	57	57	56
56	56	56	56	56	56	56	56	55	55	54	54
121	119	116	114	109	101	95	89	84	81	79	75
116	111	109	107	103	99	95	89	84	81	79	75
100	97	96	95	92	89	86	84	81	80	79	75
90	88	87	86	83	81	79	77	75	74	73	71
80	80	80	79	77	75	74	72	70	70	69	67
73	73	73	73	72	71	69	68	66	66	65	64
67	67	67	67	67	67	65	64	63	62	62	61
63	63	63	63	63	63	62	61	60	60	59	58
59	59	59	59	59	59	59	58	58	57	57	56
56	56	56	56	56	56	56	56	55	55	54	54
121	119	116	114	109	101	95	89	84	81	79	75
116	111	109	107	103	99	95	89	84	81	79	75
100	97	96	95	92	89	86	84	81	80	79	75
90	88	87	86	83	81	79	77	75	74	73	71
80	80	80	79	77	75	74	72	70	70	69	67
73	73	73	73	72	71	69	68	66	66	65	64
67	67	67	67	67	67	65	64	63	62	62	61
63	63	63	63	63	63	62	61	60	60	59	58
59	59	59	59	59	59	59	58	58	57	57	56
56	56	56	56	56	56	56	56	55	55	54	54

119	113	111	107	101	95	90	85	81	79	77	74
111	107	105	102	98	94	90	85	81	79	77	74
97	94	93	91	88	85	82	80	77	76	74	72
88	85	84	83	81	78	76	74	72	71	70	68
80	79	78	77	75	73	71	69	68	67	66	64
73	73	72	72	70	69	67	66	64	63	63	61
67	67	67	67	66	65	64	62	61	60	60	58
63	63	63	63	63	62	61	59	58	58	57	56
59	59	59	59	59	59	58	57	56	55	55	54
56	56	56	56	56	56	56	55	54	53	53	52
119	113	111	107	99	92	86	81	76	74	72	68
111	107	105	102	98	92	86	81	76	74	72	68
97	94	93	91	88	85	82	80	76	74	72	68
88	85	84	83	81	78	76	74	72	71	70	68
80	79	78	77	75	73	71	69	68	67	66	64
73	73	72	72	70	69	67	66	64	63	63	61
67	67	67	67	66	65	64	62	61	60	60	58
63	63	63	63	63	62	61	59	58	58	57	56
59	59	59	59	59	59	58	57	56	55	55	54
56	56	56	56	56	56	56	55	54	53	53	52
119	113	111	107	99	92	86	81	76	74	72	68
111	107	105	102	98	92	86	81	76	74	72	68
97	94	93	91	88	85	82	80	76	74	72	68
88	85	84	83	81	78	76	74	72	71	70	68
80	79	78	77	75	73	71	69	68	67	66	64
73	73	72	72	70	69	67	66	64	63	63	61
67	67	67	67	66	65	64	62	61	60	60	58
63	63	63	63	63	62	61	59	58	58	57	56
59	59	59	59	59	59	58	57	56	55	55	54
56	56	56	56	56	56	56	55	54	53	53	52

116	116	116	116	112	103	95	89	83	81	78	74
100	100	100	100	99	98	95	89	83	81	78	74
84	84	84	84	84	84	84	84	82	81	78	74
71	71	71	71	71	71	71	71	71	71	71	71
63	63	63	63	63	63	63	63	63	63	63	63
57	57	57	57	57	57	57	57	57	57	57	57
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
108	97	92	88	81	75	69	65	61	59	57	54
100	97	92	88	81	75	69	65	61	59	57	54
84	84	84	84	81	75	69	65	61	59	57	54
71	71	71	71	71	71	69	65	61	59	57	54
63	63	63	63	63	63	63	63	61	59	57	54
57	57	57	57	57	57	57	57	57	57	57	54
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
85	76	73	69	64	59	55	51	48	48	45	43
85	76	73	69	64	59	55	51	48	48	45	43
84	76	73	69	64	59	55	51	48	48	45	43
71	71	71	69	64	59	55	51	48	48	45	43
63	63	63	63	63	59	55	51	48	48	45	43
57	57	57	57	57	57	55	51	48	48	45	43
52	52	52	52	52	52	52	51	48	48	45	43
48	48	48	48	48	48	48	48	48	48	45	43
45	45	45	45	45	45	45	45	45	45	45	43
43	43	43	43	43	43	43	43	43	43	43	43

116	112	106	101	93	85	79	74	69	67	65	62
100	99	99	98	93	85	79	74	69	67	65	62
84	84	84	84	84	83	79	74	69	67	65	62
71	71	71	71	71	71	71	71	69	67	65	62
63	63	63	63	63	63	63	63	63	63	63	62
57	57	57	57	57	57	57	57	57	57	57	57
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
90	81	77	73	67	62	58	54	51	49	48	45
90	81	77	73	67	62	58	54	51	49	48	45
84	81	77	73	67	62	58	54	51	49	48	45
71	71	71	71	67	62	58	54	51	49	48	45
63	63	63	63	63	62	58	54	51	49	48	45
57	57	57	57	57	57	57	54	51	49	48	45
52	52	52	52	52	52	52	52	51	49	48	45
48	48	48	48	48	48	48	48	48	48	48	45
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
70	64	61	58	53	49	46	43	40	39	38	36
70	64	61	58	53	49	46	43	40	39	38	36
70	64	61	58	53	49	46	43	40	39	38	36
70	64	61	58	53	49	46	43	40	39	38	36
63	63	61	58	53	49	46	43	40	39	38	36
57	57	57	57	53	49	46	43	40	39	38	36
52	52	52	52	52	49	46	43	40	39	38	36
48	48	48	48	48	48	46	43	40	39	38	36
45	45	45	45	45	45	45	43	40	39	38	36
43	43	43	43	43	43	43	43	40	39	38	36

114	102	97	92	85	78	72	68	63	61	60	56
100	98	97	92	85	78	72	68	63	61	60	56
84	84	84	84	83	78	72	68	63	61	60	56
71	71	71	71	71	71	71	68	63	61	60	56
63	63	63	63	63	63	63	63	62	61	60	56
57	57	57	57	57	57	57	57	57	57	57	56
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
82	74	70	67	62	57	53	50	48	45	44	42
82	74	70	67	62	57	53	50	48	45	44	42
82	74	70	67	62	57	53	50	48	45	44	42
71	71	70	67	62	57	53	50	48	45	44	42
63	63	63	63	62	57	53	50	48	45	44	42
57	57	57	57	57	57	53	50	48	45	44	42
52	52	52	52	52	52	52	50	48	45	44	42
48	48	48	48	48	48	48	48	48	45	44	42
45	45	45	45	45	45	45	45	45	45	44	42
43	43	43	43	43	43	43	43	43	43	43	42
64	58	56	53	49	45	42	39	37	36	35	33
64	58	56	53	49	45	42	39	37	36	35	33
64	58	56	53	49	45	42	39	37	36	35	33
64	58	56	53	49	45	42	39	37	36	35	33
63	58	56	53	49	45	42	39	37	36	35	33
57	57	56	53	49	45	42	39	37	36	35	33
52	52	52	52	49	45	42	39	37	36	35	33
48	48	48	48	48	45	42	39	37	36	35	33
45	45	45	45	45	45	42	39	37	36	35	33
43	43	43	43	43	43	42	39	37	36	35	33

116	116	115	113	110	105	98	91	86	83	81	76
98	96	95	94	92	90	88	86	84	83	81	76
77	77	77	77	77	76	75	73	72	71	71	69
65	65	65	65	65	65	65	65	64	64	63	62
57	57	57	57	57	57	57	57	57	57	57	57
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
107	97	93	89	81	75	70	66	62	60	58	55
98	96	93	89	81	75	70	66	62	60	58	55
77	77	77	77	77	75	70	66	62	60	58	55
65	65	65	65	65	65	65	65	62	60	58	55
57	57	57	57	57	57	57	57	57	57	57	55
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
86	78	74	71	65	61	56	53	50	48	48	44
86	78	74	71	65	61	56	53	50	48	48	44
77	77	74	71	65	61	56	53	50	48	48	44
65	65	65	65	65	61	56	53	50	48	48	44
57	57	57	57	57	57	56	53	50	48	48	44
52	52	52	52	52	52	52	52	50	48	48	44
48	48	48	48	48	48	48	48	48	48	48	44
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39

114	110	108	104	95	88	82	77	72	70	68	64
94	92	91	90	87	85	82	77	72	70	68	64
77	77	76	76	74	73	71	69	68	67	66	64
65	65	65	65	65	64	63	62	61	61	60	59
57	57	57	57	57	57	57	57	56	56	55	54
52	52	52	52	52	52	52	52	52	52	51	51
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
90	81	78	74	68	63	59	55	52	50	49	46
90	81	78	74	68	63	59	55	52	50	49	46
77	77	76	74	68	63	59	55	52	50	49	46
65	65	65	65	65	63	59	55	52	50	49	46
57	57	57	57	57	57	57	55	52	50	49	46
52	52	52	52	52	52	52	52	52	50	49	46
48	48	48	48	48	48	48	48	48	48	48	46
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
72	65	62	60	55	51	48	44	42	41	39	37
72	65	62	60	55	51	48	44	42	41	39	37
72	65	62	60	55	51	48	44	42	41	39	37
65	65	62	60	55	51	48	44	42	41	39	37
57	57	57	57	55	51	48	44	42	41	39	37
52	52	52	52	52	51	48	44	42	41	39	37
48	48	48	48	48	48	48	44	42	41	39	37
44	44	44	44	44	44	44	44	42	41	39	37
42	42	42	42	42	42	42	42	42	41	39	37
39	39	39	39	39	39	39	39	39	39	39	37

111	104	99	95	87	81	75	70	66	64	62	59
92	90	88	87	84	81	75	70	66	64	62	59
77	76	75	74	72	71	69	67	66	64	62	59
65	65	65	65	64	63	62	61	59	59	58	57
57	57	57	57	57	57	57	56	55	54	54	53
52	52	52	52	52	52	52	52	51	51	50	49
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
82	75	71	68	63	58	54	51	48	46	45	43
82	75	71	68	63	58	54	51	48	46	45	43
77	75	71	68	63	58	54	51	48	46	45	43
65	65	65	65	63	58	54	51	48	46	45	43
57	57	57	57	57	57	54	51	48	46	45	43
52	52	52	52	52	52	52	51	48	46	45	43
48	48	48	48	48	48	48	48	48	46	45	43
44	44	44	44	44	44	44	44	44	44	44	43
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
66	60	57	55	50	48	44	41	38	37	36	34
66	60	57	55	50	48	44	41	38	37	36	34
66	60	57	55	50	48	44	41	38	37	36	34
65	60	57	55	50	48	44	41	38	37	36	34
57	57	57	55	50	48	44	41	38	37	36	34
52	52	52	52	50	48	44	41	38	37	36	34
48	48	48	48	48	48	44	41	38	37	36	34
44	44	44	44	44	44	44	41	38	37	36	34
42	42	42	42	42	42	42	41	38	37	36	34
39	39	39	39	39	39	39	39	38	37	36	34

109	103	100	97	92	87	83	79	75	73	72	69
94	91	90	88	85	82	79	77	74	73	72	69
81	79	78	77	75	73	71	69	67	66	65	63
72	71	70	69	68	66	65	63	62	61	60	59
63	63	63	63	62	61	60	59	57	57	56	55
57	57	57	57	57	57	56	55	54	53	53	52
53	53	53	53	53	53	53	52	51	51	50	49
49	49	49	49	49	49	49	49	49	48	48	48
46	46	46	46	46	46	46	46	46	46	46	45
44	44	44	44	44	44	44	44	44	44	44	43
109	103	100	97	92	87	82	77	73	70	68	65
94	91	90	88	85	82	79	77	73	70	68	65
81	79	78	77	75	73	71	69	67	66	65	63
72	71	70	69	68	66	65	63	62	61	60	59
63	63	63	63	62	61	60	59	57	57	56	55
57	57	57	57	57	57	56	55	54	53	53	52
53	53	53	53	53	53	53	52	51	51	50	49
49	49	49	49	49	49	49	49	49	48	48	48
46	46	46	46	46	46	46	46	46	46	46	45
44	44	44	44	44	44	44	44	44	44	44	43
109	103	100	97	92	87	82	77	73	70	68	65
94	91	90	88	85	82	79	77	73	70	68	65
81	79	78	77	75	73	71	69	67	66	65	63
72	71	70	69	68	66	65	63	62	61	60	59
63	63	63	63	62	61	60	59	57	57	56	55
57	57	57	57	57	57	56	55	54	53	53	52
53	53	53	53	53	53	53	52	51	51	50	49
49	49	49	49	49	49	49	49	49	48	48	48
46	46	46	46	46	46	46	46	46	46	46	45
44	44	44	44	44	44	44	44	44	44	44	43

98	92	89	86	81	77	72	69	65	64	62	59
89	85	83	82	78	75	72	69	65	64	62	59
77	75	74	73	70	68	66	64	61	60	59	57
69	68	67	66	64	62	61	59	57	56	56	54
63	62	62	61	59	58	57	55	54	53	52	51
57	57	57	57	56	54	53	52	51	50	50	49
53	53	53	53	52	51	50	49	48	48	48	46
49	49	49	49	49	49	48	48	46	46	45	45
46	46	46	46	46	46	46	45	44	44	44	43
44	44	44	44	44	44	44	43	43	42	42	41
98	92	89	86	80	74	69	65	61	60	58	55
89	85	83	82	78	74	69	65	61	60	58	55
77	75	74	73	70	68	66	64	61	60	58	55
69	68	67	66	64	62	61	59	57	56	56	54
63	62	62	61	59	58	57	55	54	53	52	51
57	57	57	57	56	54	53	52	51	50	50	49
53	53	53	53	52	51	50	49	48	48	48	46
49	49	49	49	49	49	48	48	46	46	45	45
46	46	46	46	46	46	46	45	44	44	44	43
44	44	44	44	44	44	44	43	43	42	42	41
98	92	89	86	80	74	69	65	61	60	58	55
89	85	83	82	78	74	69	65	61	60	58	55
77	75	74	73	70	68	66	64	61	60	58	55
69	68	67	66	64	62	61	59	57	56	56	54
63	62	62	61	59	58	57	55	54	53	52	51
57	57	57	57	56	54	53	52	51	50	50	49
53	53	53	53	52	51	50	49	48	48	48	46
49	49	49	49	49	49	48	48	46	46	45	45
46	46	46	46	46	46	46	45	44	44	44	43
44	44	44	44	44	44	44	43	43	42	42	41

92	86	84	81	76	72	68	64	61	59	58	55
86	82	80	78	75	72	68	64	61	59	58	55
75	73	71	70	68	65	63	61	58	57	56	54
68	66	65	64	62	60	58	57	55	54	53	51
62	61	60	59	58	56	55	53	52	51	50	49
57	57	56	56	54	53	52	50	49	49	48	48
53	53	53	52	51	50	49	48	48	46	46	45
49	49	49	49	49	48	48	46	45	44	44	43
46	46	46	46	46	46	45	44	43	43	42	42
44	44	44	44	44	44	43	42	42	41	41	40
92	86	83	80	74	68	64	60	56	55	53	50
86	82	80	78	74	68	64	60	56	55	53	50
75	73	71	70	68	65	63	60	56	55	53	50
68	66	65	64	62	60	58	57	55	54	53	50
62	61	60	59	58	56	55	53	52	51	50	49
57	57	56	56	54	53	52	50	49	49	48	48
53	53	53	52	51	50	49	48	48	46	46	45
49	49	49	49	49	48	48	46	45	44	44	43
46	46	46	46	46	46	45	44	43	43	42	42
44	44	44	44	44	44	43	42	42	41	41	40
92	86	83	80	74	68	64	60	56	55	53	50
86	82	80	78	74	68	64	60	56	55	53	50
75	73	71	70	68	65	63	60	56	55	53	50
68	66	65	64	62	60	58	57	55	54	53	50
62	61	60	59	58	56	55	53	52	51	50	49
57	57	56	56	54	53	52	50	49	49	48	48
53	53	53	52	51	50	49	48	48	46	46	45
49	49	49	49	49	48	48	46	45	44	44	43
46	46	46	46	46	46	45	44	43	43	42	42
44	44	44	44	44	44	43	42	42	41	41	40

121	121	121	121	121	121	121	113	105	102	99	94
118	118	118	118	117	115	114	113	105	102	99	94
99	99	99	99	99	99	99	99	99	99	98	94
88	88	88	88	88	88	88	88	88	88	88	88
80	80	80	80	80	80	80	80	80	80	80	80
72	72	72	72	72	72	72	72	72	72	72	72
66	66	66	66	66	66	66	66	66	66	66	66
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
121	121	117	112	103	95	88	82	77	75	73	69
118	118	117	112	103	95	88	82	77	75	73	69
99	99	99	99	99	95	88	82	77	75	73	69
88	88	88	88	88	88	88	82	77	75	73	69
80	80	80	80	80	80	80	80	77	75	73	69
72	72	72	72	72	72	72	72	72	72	72	69
66	66	66	66	66	66	66	66	66	66	66	66
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
107	97	92	88	81	75	70	65	61	59	58	55
107	97	92	88	81	75	70	65	61	59	58	55
99	97	92	88	81	75	70	65	61	59	58	55
88	88	88	88	81	75	70	65	61	59	58	55
80	80	80	80	80	75	70	65	61	59	58	55
72	72	72	72	72	72	70	65	61	59	58	55
66	66	66	66	66	66	66	65	61	59	58	55
62	62	62	62	62	62	62	62	61	59	58	55
58	58	58	58	58	58	58	58	58	58	58	55
55	55	55	55	55	55	55	55	55	55	55	55

121	121	121	121	118	109	101	94	88	85	83	78
118	117	116	115	114	109	101	94	88	85	83	78
99	99	99	99	99	99	98	94	88	85	83	78
88	88	88	88	88	88	88	88	88	85	83	78
80	80	80	80	80	80	80	80	80	80	80	78
72	72	72	72	72	72	72	72	72	72	72	72
66	66	66	66	66	66	66	66	66	66	66	66
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
114	102	98	93	86	79	74	69	65	63	61	58
114	102	98	93	86	79	74	69	65	63	61	58
99	99	98	93	86	79	74	69	65	63	61	58
88	88	88	88	86	79	74	69	65	63	61	58
80	80	80	80	80	79	74	69	65	63	61	58
72	72	72	72	72	72	72	69	65	63	61	58
66	66	66	66	66	66	66	66	65	63	61	58
62	62	62	62	62	62	62	62	62	62	61	58
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
90	81	77	74	68	63	59	55	51	50	48	46
90	81	77	74	68	63	59	55	51	50	48	46
90	81	77	74	68	63	59	55	51	50	48	46
88	81	77	74	68	63	59	55	51	50	48	46
80	80	77	74	68	63	59	55	51	50	48	46
72	72	72	72	68	63	59	55	51	50	48	46
66	66	66	66	66	63	59	55	51	50	48	46
62	62	62	62	62	62	59	55	51	50	48	46
58	58	58	58	58	58	58	55	51	50	48	46
55	55	55	55	55	55	55	55	51	50	48	46

121	121	121	117	107	99	92	86	80	78	76	72
117	115	114	114	107	99	92	86	80	78	76	72
99	99	99	99	99	98	92	86	80	78	76	72
88	88	88	88	88	88	88	86	80	78	76	72
80	80	80	80	80	80	80	80	79	78	76	72
72	72	72	72	72	72	72	72	72	72	72	72
66	66	66	66	66	66	66	66	66	66	66	66
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
104	94	89	85	78	72	67	63	59	57	56	53
104	94	89	85	78	72	67	63	59	57	56	53
99	94	89	85	78	72	67	63	59	57	56	53
88	88	88	85	78	72	67	63	59	57	56	53
80	80	80	80	78	72	67	63	59	57	56	53
72	72	72	72	72	72	67	63	59	57	56	53
66	66	66	66	66	66	66	63	59	57	56	53
62	62	62	62	62	62	62	62	59	57	56	53
58	58	58	58	58	58	58	58	58	57	56	53
55	55	55	55	55	55	55	55	55	55	55	53
82	74	71	68	62	58	54	50	48	46	44	42
82	74	71	68	62	58	54	50	48	46	44	42
82	74	71	68	62	58	54	50	48	46	44	42
82	74	71	68	62	58	54	50	48	46	44	42
80	74	71	68	62	58	54	50	48	46	44	42
72	72	71	68	62	58	54	50	48	46	44	42
66	66	66	66	62	58	54	50	48	46	44	42
62	62	62	62	62	58	54	50	48	46	44	42
58	58	58	58	58	58	54	50	48	46	44	42
55	55	55	55	55	55	54	50	48	46	44	42

121	121	121	121	121	121	121	116	109	106	103	97
118	116	115	115	113	111	110	108	106	105	103	97
98	98	98	98	98	96	95	93	91	91	90	88
83	83	83	83	83	83	83	82	81	81	80	79
73	73	73	73	73	73	73	73	73	73	73	72
66	66	66	66	66	66	66	66	66	66	66	66
61	61	61	61	61	61	61	61	61	61	61	61
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
121	121	117	112	103	96	89	83	78	76	74	70
118	116	115	112	103	96	89	83	78	76	74	70
98	98	98	98	98	96	89	83	78	76	74	70
83	83	83	83	83	83	83	82	78	76	74	70
73	73	73	73	73	73	73	73	73	73	73	70
66	66	66	66	66	66	66	66	66	66	66	66
61	61	61	61	61	61	61	61	61	61	61	61
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
109	99	94	90	83	77	72	67	63	61	59	56
109	99	94	90	83	77	72	67	63	61	59	56
98	98	94	90	83	77	72	67	63	61	59	56
83	83	83	83	83	77	72	67	63	61	59	56
73	73	73	73	73	73	72	67	63	61	59	56
66	66	66	66	66	66	66	66	63	61	59	56
61	61	61	61	61	61	61	61	61	61	59	56
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50

121	121	121	121	120	112	104	97	91	89	86	82
115	113	112	111	109	107	104	97	91	89	86	82
98	98	97	96	94	92	90	88	86	85	84	82
83	83	83	83	83	82	80	79	78	77	76	75
73	73	73	73	73	73	73	72	71	71	70	69
66	66	66	66	66	66	66	66	66	66	65	64
61	61	61	61	61	61	61	61	61	61	61	60
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
114	103	99	94	87	80	75	70	66	64	62	59
114	103	99	94	87	80	75	70	66	64	62	59
98	98	97	94	87	80	75	70	66	64	62	59
83	83	83	83	83	80	75	70	66	64	62	59
73	73	73	73	73	73	73	70	66	64	62	59
66	66	66	66	66	66	66	66	66	64	62	59
61	61	61	61	61	61	61	61	61	61	61	59
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
91	83	79	76	70	65	60	56	53	52	50	48
91	83	79	76	70	65	60	56	53	52	50	48
91	83	79	76	70	65	60	56	53	52	50	48
83	83	79	76	70	65	60	56	53	52	50	48
73	73	73	73	70	65	60	56	53	52	50	48
66	66	66	66	66	65	60	56	53	52	50	48
61	61	61	61	61	61	60	56	53	52	50	48
56	56	56	56	56	56	56	56	53	52	50	48
53	53	53	53	53	53	53	53	53	52	50	48
50	50	50	50	50	50	50	50	50	50	50	48

121	121	121	120	111	102	95	89	84	81	79	75
113	111	110	109	107	102	95	89	84	81	79	75
98	96	95	94	92	90	88	85	83	81	79	75
83	83	83	83	82	80	79	77	75	75	74	72
73	73	73	73	73	73	72	71	70	69	68	67
66	66	66	66	66	66	66	66	65	64	64	63
61	61	61	61	61	61	61	61	61	60	60	59
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
104	95	90	86	80	74	69	64	61	59	57	54
104	95	90	86	80	74	69	64	61	59	57	54
98	95	90	86	80	74	69	64	61	59	57	54
83	83	83	83	80	74	69	64	61	59	57	54
73	73	73	73	73	73	69	64	61	59	57	54
66	66	66	66	66	66	66	64	61	59	57	54
61	61	61	61	61	61	61	61	61	59	57	54
56	56	56	56	56	56	56	56	56	56	56	54
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
84	76	73	70	64	59	55	52	49	48	46	44
84	76	73	70	64	59	55	52	49	48	46	44
84	76	73	70	64	59	55	52	49	48	46	44
83	76	73	70	64	59	55	52	49	48	46	44
73	73	73	70	64	59	55	52	49	48	46	44
66	66	66	66	64	59	55	52	49	48	46	44
61	61	61	61	61	59	55	52	49	48	46	44
56	56	56	56	56	56	55	52	49	48	46	44
53	53	53	53	53	53	53	52	49	48	46	44
50	50	50	50	50	50	50	50	49	48	46	44

121	121	121	119	115	111	105	100	95	93	91	87
120	116	114	112	108	104	101	97	94	92	91	87
103	100	99	98	95	93	90	88	85	84	83	80
91	90	89	88	86	84	82	80	78	77	77	75
80	80	80	80	79	78	76	75	73	72	71	70
73	73	73	73	73	72	71	70	69	68	67	66
67	67	67	67	67	67	67	66	65	64	64	63
63	63	63	63	63	63	63	63	62	61	61	60
59	59	59	59	59	59	59	59	59	59	58	57
56	56	56	56	56	56	56	56	56	56	56	55
121	121	121	119	115	111	104	98	92	89	87	82
120	116	114	112	108	104	101	97	92	89	87	82
103	100	99	98	95	93	90	88	85	84	83	80
91	90	89	88	86	84	82	80	78	77	77	75
80	80	80	80	79	78	76	75	73	72	71	70
73	73	73	73	73	72	71	70	69	68	67	66
67	67	67	67	67	67	67	66	65	64	64	63
63	63	63	63	63	63	63	63	62	61	61	60
59	59	59	59	59	59	59	59	59	59	58	57
56	56	56	56	56	56	56	56	56	56	56	55
121	121	121	119	115	111	104	98	92	89	87	82
120	116	114	112	108	104	101	97	92	89	87	82
103	100	99	98	95	93	90	88	85	84	83	80
91	90	89	88	86	84	82	80	78	77	77	75
80	80	80	80	79	78	76	75	73	72	71	70
73	73	73	73	73	72	71	70	69	68	67	66
67	67	67	67	67	67	67	66	65	64	64	63
63	63	63	63	63	63	63	63	62	61	61	60
59	59	59	59	59	59	59	59	59	59	58	57
56	56	56	56	56	56	56	56	56	56	56	55

120	115	112	109	103	97	92	87	83	81	79	75
113	108	106	104	100	96	92	87	83	81	79	75
98	95	94	92	89	86	83	81	78	77	75	73
88	86	85	84	81	79	77	75	73	72	71	69
80	79	78	77	75	74	72	70	68	67	67	65
73	73	73	72	71	69	68	66	65	64	63	62
67	67	67	67	67	65	64	63	62	61	60	59
63	63	63	63	63	62	61	60	59	58	58	57
59	59	59	59	59	59	58	57	56	56	55	54
56	56	56	56	56	56	56	55	54	54	53	52
120	115	112	109	102	94	88	83	78	76	73	70
113	108	106	104	100	94	88	83	78	76	73	70
98	95	94	92	89	86	83	81	78	76	73	70
88	86	85	84	81	79	77	75	73	72	71	69
80	79	78	77	75	74	72	70	68	67	67	65
73	73	73	72	71	69	68	66	65	64	63	62
67	67	67	67	67	65	64	63	62	61	60	59
63	63	63	63	63	62	61	60	59	58	58	57
59	59	59	59	59	59	58	57	56	56	55	54
56	56	56	56	56	56	56	55	54	54	53	52
120	115	112	109	102	94	88	83	78	76	73	70
113	108	106	104	100	94	88	83	78	76	73	70
98	95	94	92	89	86	83	81	78	76	73	70
88	86	85	84	81	79	77	75	73	72	71	69
80	79	78	77	75	74	72	70	68	67	67	65
73	73	73	72	71	69	68	66	65	64	63	62
67	67	67	67	67	65	64	63	62	61	60	59
63	63	63	63	63	62	61	60	59	58	58	57
59	59	59	59	59	59	58	57	56	56	55	54
56	56	56	56	56	56	56	55	54	54	53	52

115	110	106	103	96	91	86	81	77	75	73	70
109	104	102	99	95	91	86	81	77	75	73	70
96	92	91	89	86	83	80	77	74	73	72	69
86	84	83	81	79	76	74	72	70	69	67	65
79	77	76	75	73	71	70	68	66	65	64	62
73	72	71	71	69	67	66	64	62	62	61	59
67	67	67	67	65	64	62	61	60	59	58	57
63	63	63	63	62	61	60	58	57	57	56	55
59	59	59	59	59	58	57	56	55	54	54	53
56	56	56	56	56	56	55	54	53	52	52	51
115	110	106	101	94	87	81	76	72	69	68	64
109	104	102	99	94	87	81	76	72	69	68	64
96	92	91	89	86	83	80	76	72	69	68	64
86	84	83	81	79	76	74	72	70	69	67	64
79	77	76	75	73	71	70	68	66	65	64	62
73	72	71	71	69	67	66	64	62	62	61	59
67	67	67	67	65	64	62	61	60	59	58	57
63	63	63	63	62	61	60	58	57	57	56	55
59	59	59	59	59	58	57	56	55	54	54	53
56	56	56	56	56	56	55	54	53	52	52	51
115	110	106	101	94	87	81	76	72	69	68	64
109	104	102	99	94	87	81	76	72	69	68	64
96	92	91	89	86	83	80	76	72	69	68	64
86	84	83	81	79	76	74	72	70	69	67	64
79	77	76	75	73	71	70	68	66	65	64	62
73	72	71	71	69	67	66	64	62	62	61	59
67	67	67	67	65	64	62	61	60	59	58	57
63	63	63	63	62	61	60	58	57	57	56	55
59	59	59	59	59	58	57	56	55	54	54	53
56	56	56	56	56	56	55	54	53	52	52	51

116	116	116	110	100	92	86	80	75	73	70	66
100	100	100	99	98	92	86	80	75	73	70	66
84	84	84	84	84	84	83	80	75	73	70	66
71	71	71	71	71	71	71	71	71	71	70	66
63	63	63	63	63	63	63	63	63	63	63	63
57	57	57	57	57	57	57	57	57	57	57	57
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
97	87	83	79	73	67	63	58	55	53	52	49
97	87	83	79	73	67	63	58	55	53	52	49
84	84	83	79	73	67	63	58	55	53	52	49
71	71	71	71	71	67	63	58	55	53	52	49
63	63	63	63	63	63	63	58	55	53	52	49
57	57	57	57	57	57	57	57	55	53	52	49
52	52	52	52	52	52	52	52	52	52	52	49
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
76	69	66	63	58	53	50	46	44	42	41	39
76	69	66	63	58	53	50	46	44	42	41	39
76	69	66	63	58	53	50	46	44	42	41	39
71	69	66	63	58	53	50	46	44	42	41	39
63	63	63	63	58	53	50	46	44	42	41	39
57	57	57	57	57	53	50	46	44	42	41	39
52	52	52	52	52	52	50	46	44	42	41	39
48	48	48	48	48	48	48	46	44	42	41	39
45	45	45	45	45	45	45	45	44	42	41	39
43	43	43	43	43	43	43	43	43	42	41	39

115	103	98	94	86	79	73	69	64	62	61	57
100	98	98	94	86	79	73	69	64	62	61	57
84	84	84	84	83	79	73	69	64	62	61	57
71	71	71	71	71	71	71	69	64	62	61	57
63	63	63	63	63	63	63	63	63	62	61	57
57	57	57	57	57	57	57	57	57	57	57	57
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
83	75	71	68	63	58	54	50	48	46	45	42
83	75	71	68	63	58	54	50	48	46	45	42
83	75	71	68	63	58	54	50	48	46	45	42
71	71	71	68	63	58	54	50	48	46	45	42
63	63	63	63	63	58	54	50	48	46	45	42
57	57	57	57	57	57	54	50	48	46	45	42
52	52	52	52	52	52	52	50	48	46	45	42
48	48	48	48	48	48	48	48	48	46	45	42
45	45	45	45	45	45	45	45	45	45	45	42
43	43	43	43	43	43	43	43	43	43	43	42
65	59	56	54	50	46	43	40	38	36	35	34
65	59	56	54	50	46	43	40	38	36	35	34
65	59	56	54	50	46	43	40	38	36	35	34
65	59	56	54	50	46	43	40	38	36	35	34
63	59	56	54	50	46	43	40	38	36	35	34
57	57	56	54	50	46	43	40	38	36	35	34
52	52	52	52	50	46	43	40	38	36	35	34
48	48	48	48	48	46	43	40	38	36	35	34
45	45	45	45	45	45	43	40	38	36	35	34
43	43	43	43	43	43	43	40	38	36	35	34

106	95	90	86	79	73	68	63	59	58	56	53
99	95	90	86	79	73	68	63	59	58	56	53
84	84	84	83	79	73	68	63	59	58	56	53
71	71	71	71	71	71	68	63	59	58	56	53
63	63	63	63	63	63	63	62	59	58	56	53
57	57	57	57	57	57	57	57	57	57	56	53
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
45	45	45	45	45	45	45	45	45	45	45	45
43	43	43	43	43	43	43	43	43	43	43	43
76	69	66	63	58	54	50	48	44	42	41	39
76	69	66	63	58	54	50	48	44	42	41	39
76	69	66	63	58	54	50	48	44	42	41	39
71	69	66	63	58	54	50	48	44	42	41	39
63	63	63	63	58	54	50	48	44	42	41	39
57	57	57	57	57	54	50	48	44	42	41	39
52	52	52	52	52	52	50	48	44	42	41	39
48	48	48	48	48	48	48	48	44	42	41	39
45	45	45	45	45	45	45	45	44	42	41	39
43	43	43	43	43	43	43	43	43	42	41	39
60	55	52	50	46	43	40	37	35	34	33	31
60	55	52	50	46	43	40	37	35	34	33	31
60	55	52	50	46	43	40	37	35	34	33	31
60	55	52	50	46	43	40	37	35	34	33	31
60	55	52	50	46	43	40	37	35	34	33	31
57	55	52	50	46	43	40	37	35	34	33	31
52	52	52	50	46	43	40	37	35	34	33	31
48	48	48	48	46	43	40	37	35	34	33	31
45	45	45	45	45	43	40	37	35	34	33	31
43	43	43	43	43	43	40	37	35	34	33	31

116	113	111	109	103	95	88	83	78	75	73	69
96	94	93	92	89	87	85	82	78	75	73	69
77	77	77	77	75	74	73	71	70	69	68	67
65	65	65	65	65	65	64	63	62	62	61	60
57	57	57	57	57	57	57	57	57	57	56	55
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
97	88	84	80	74	68	64	59	56	54	53	50
96	88	84	80	74	68	64	59	56	54	53	50
77	77	77	77	74	68	64	59	56	54	53	50
65	65	65	65	65	65	64	59	56	54	53	50
57	57	57	57	57	57	57	57	56	54	53	50
52	52	52	52	52	52	52	52	52	52	52	50
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
78	70	67	64	59	55	51	48	45	44	42	40
78	70	67	64	59	55	51	48	45	44	42	40
77	70	67	64	59	55	51	48	45	44	42	40
65	65	65	64	59	55	51	48	45	44	42	40
57	57	57	57	57	55	51	48	45	44	42	40
52	52	52	52	52	52	51	48	45	44	42	40
48	48	48	48	48	48	48	48	45	44	42	40
44	44	44	44	44	44	44	44	44	44	42	40
42	42	42	42	42	42	42	42	42	42	42	40
39	39	39	39	39	39	39	39	39	39	39	39

111	105	101	96	88	82	76	71	67	65	63	60
93	90	89	87	85	82	76	71	67	65	63	60
77	76	75	74	73	71	69	68	66	65	63	60
65	65	65	65	64	63	62	61	60	59	59	57
57	57	57	57	57	57	57	56	55	54	54	53
52	52	52	52	52	52	52	52	51	51	50	50
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
83	76	72	69	64	59	55	51	48	48	46	43
83	76	72	69	64	59	55	51	48	48	46	43
77	76	72	69	64	59	55	51	48	48	46	43
65	65	65	65	64	59	55	51	48	48	46	43
57	57	57	57	57	57	55	51	48	48	46	43
52	52	52	52	52	52	52	51	48	48	46	43
48	48	48	48	48	48	48	48	48	48	46	43
44	44	44	44	44	44	44	44	44	44	44	43
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
67	61	58	55	51	48	44	41	39	38	37	35
67	61	58	55	51	48	44	41	39	38	37	35
67	61	58	55	51	48	44	41	39	38	37	35
65	61	58	55	51	48	44	41	39	38	37	35
57	57	57	55	51	48	44	41	39	38	37	35
52	52	52	52	51	48	44	41	39	38	37	35
48	48	48	48	48	48	44	41	39	38	37	35
44	44	44	44	44	44	44	41	39	38	37	35
42	42	42	42	42	42	42	41	39	38	37	35
39	39	39	39	39	39	39	39	39	38	37	35

108	97	93	89	82	76	71	66	62	60	58	55
91	88	86	85	82	76	71	66	62	60	58	55
76	74	74	73	71	69	67	66	62	60	58	55
65	65	65	65	63	62	61	59	58	57	57	55
57	57	57	57	57	57	56	55	54	53	53	52
52	52	52	52	52	52	52	51	50	50	49	48
48	48	48	48	48	48	48	48	48	48	46	46
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
77	70	67	64	59	55	51	48	45	43	42	40
77	70	67	64	59	55	51	48	45	43	42	40
76	70	67	64	59	55	51	48	45	43	42	40
65	65	65	64	59	55	51	48	45	43	42	40
57	57	57	57	57	55	51	48	45	43	42	40
52	52	52	52	52	52	51	48	45	43	42	40
48	48	48	48	48	48	48	48	45	43	42	40
44	44	44	44	44	44	44	44	44	43	42	40
42	42	42	42	42	42	42	42	42	42	42	40
39	39	39	39	39	39	39	39	39	39	39	39
62	56	54	51	48	44	41	38	36	35	34	32
62	56	54	51	48	44	41	38	36	35	34	32
62	56	54	51	48	44	41	38	36	35	34	32
62	56	54	51	48	44	41	38	36	35	34	32
57	56	54	51	48	44	41	38	36	35	34	32
52	52	52	51	48	44	41	38	36	35	34	32
48	48	48	48	48	44	41	38	36	35	34	32
44	44	44	44	44	44	41	38	36	35	34	32
42	42	42	42	42	42	41	38	36	35	34	32
39	39	39	39	39	39	39	38	36	35	34	32

102	96	93	91	86	81	77	73	69	68	66	63
91	88	86	85	81	78	75	73	69	68	66	63
79	77	76	75	72	70	68	66	64	63	62	60
71	69	68	67	66	64	62	61	59	58	58	56
63	63	63	62	61	59	58	57	55	55	54	53
57	57	57	57	57	56	54	53	52	52	51	50
53	53	53	53	53	52	51	51	50	49	49	48
49	49	49	49	49	49	49	48	48	48	46	46
46	46	46	46	46	46	46	46	45	45	45	44
44	44	44	44	44	44	44	44	44	43	43	42
102	96	93	91	86	80	75	70	66	64	62	59
91	88	86	85	81	78	75	70	66	64	62	59
79	77	76	75	72	70	68	66	64	63	62	59
71	69	68	67	66	64	62	61	59	58	58	56
63	63	63	62	61	59	58	57	55	55	54	53
57	57	57	57	57	56	54	53	52	52	51	50
53	53	53	53	53	52	51	51	50	49	49	48
49	49	49	49	49	49	49	48	48	48	46	46
46	46	46	46	46	46	46	46	45	45	45	44
44	44	44	44	44	44	44	44	44	43	43	42
102	96	93	91	86	80	75	70	66	64	62	59
91	88	86	85	81	78	75	70	66	64	62	59
79	77	76	75	72	70	68	66	64	63	62	59
71	69	68	67	66	64	62	61	59	58	58	56
63	63	63	62	61	59	58	57	55	55	54	53
57	57	57	57	57	56	54	53	52	52	51	50
53	53	53	53	53	52	51	51	50	49	49	48
49	49	49	49	49	49	49	48	48	48	46	46
46	46	46	46	46	46	46	46	45	45	45	44
44	44	44	44	44	44	44	44	44	43	43	42

93	87	84	82	77	72	68	65	61	60	58	56
86	82	81	79	75	72	68	65	61	60	58	56
76	73	72	70	68	66	63	61	59	58	57	55
68	66	65	64	62	61	59	57	55	54	53	52
63	61	60	60	58	57	55	54	52	51	51	49
57	57	56	56	54	53	52	51	49	49	48	48
53	53	53	53	51	50	49	48	48	48	46	45
49	49	49	49	49	48	48	46	45	45	44	43
46	46	46	46	46	46	45	44	43	43	43	42
44	44	44	44	44	44	43	43	42	41	41	40
93	87	84	81	75	69	65	61	57	55	54	51
86	82	81	79	75	69	65	61	57	55	54	51
76	73	72	70	68	66	63	61	57	55	54	51
68	66	65	64	62	61	59	57	55	54	53	51
63	61	60	60	58	57	55	54	52	51	51	49
57	57	56	56	54	53	52	51	49	49	48	48
53	53	53	53	51	50	49	48	48	48	46	45
49	49	49	49	49	48	48	46	45	45	44	43
46	46	46	46	46	46	45	44	43	43	43	42
44	44	44	44	44	44	43	43	42	41	41	40
93	87	84	81	75	69	65	61	57	55	54	51
86	82	81	79	75	69	65	61	57	55	54	51
76	73	72	70	68	66	63	61	57	55	54	51
68	66	65	64	62	61	59	57	55	54	53	51
63	61	60	60	58	57	55	54	52	51	51	49
57	57	56	56	54	53	52	51	49	49	48	48
53	53	53	53	51	50	49	48	48	48	46	45
49	49	49	49	49	48	48	46	45	45	44	43
46	46	46	46	46	46	45	44	43	43	43	42
44	44	44	44	44	44	43	43	42	41	41	40

89	83	80	77	72	68	64	61	58	56	55	52
83	79	77	76	72	68	64	61	58	56	55	52
74	71	70	68	66	63	61	58	56	55	54	52
67	65	64	63	61	59	57	55	53	52	51	50
61	60	59	58	57	55	53	52	50	49	49	48
57	56	55	55	53	52	50	49	48	48	48	45
53	53	52	52	50	49	48	48	46	45	45	44
49	49	49	49	48	48	46	45	44	43	43	42
46	46	46	46	46	45	44	43	42	42	41	41
44	44	44	44	44	43	42	42	41	40	40	39
89	82	78	75	69	64	60	56	53	51	50	48
83	79	77	75	69	64	60	56	53	51	50	48
74	71	70	68	66	63	60	56	53	51	50	48
67	65	64	63	61	59	57	55	53	51	50	48
61	60	59	58	57	55	53	52	50	49	49	48
57	56	55	55	53	52	50	49	48	48	48	45
53	53	52	52	50	49	48	48	46	45	45	44
49	49	49	49	48	48	46	45	44	43	43	42
46	46	46	46	46	45	44	43	42	42	41	41
44	44	44	44	44	43	42	42	41	40	40	39
89	82	78	75	69	64	60	56	53	51	50	48
83	79	77	75	69	64	60	56	53	51	50	48
74	71	70	68	66	63	60	56	53	51	50	48
67	65	64	63	61	59	57	55	53	51	50	48
61	60	59	58	57	55	53	52	50	49	49	48
57	56	55	55	53	52	50	49	48	48	48	45
53	53	52	52	50	49	48	48	46	45	45	44
49	49	49	49	48	48	46	45	44	43	43	42
46	46	46	46	46	45	44	43	42	42	41	41
44	44	44	44	44	43	42	42	41	40	40	39

121	121	121	121	121	117	109	101	95	92	89	84
118	118	117	116	115	114	109	101	95	92	89	84
99	99	99	99	99	99	99	98	95	92	89	84
88	88	88	88	88	88	88	88	88	88	88	84
80	80	80	80	80	80	80	80	80	80	80	80
72	72	72	72	72	72	72	72	72	72	72	72
66	66	66	66	66	66	66	66	66	66	66	66
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
121	111	105	101	92	85	79	74	70	68	66	62
118	111	105	101	92	85	79	74	70	68	66	62
99	99	99	99	92	85	79	74	70	68	66	62
88	88	88	88	88	85	79	74	70	68	66	62
80	80	80	80	80	80	79	74	70	68	66	62
72	72	72	72	72	72	72	72	70	68	66	62
66	66	66	66	66	66	66	66	66	66	66	62
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
97	87	83	80	73	68	63	59	55	54	52	49
97	87	83	80	73	68	63	59	55	54	52	49
97	87	83	80	73	68	63	59	55	54	52	49
88	87	83	80	73	68	63	59	55	54	52	49
80	80	80	80	73	68	63	59	55	54	52	49
72	72	72	72	72	68	63	59	55	54	52	49
66	66	66	66	66	66	63	59	55	54	52	49
62	62	62	62	62	62	62	59	55	54	52	49
58	58	58	58	58	58	58	58	55	54	52	49
55	55	55	55	55	55	55	55	55	54	52	49

121	121	121	119	109	100	93	87	82	79	77	73
117	115	115	114	109	100	93	87	82	79	77	73
99	99	99	99	99	98	93	87	82	79	77	73
88	88	88	88	88	88	88	87	82	79	77	73
80	80	80	80	80	80	80	80	80	79	77	73
72	72	72	72	72	72	72	72	72	72	72	72
66	66	66	66	66	66	66	66	66	66	66	66
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
105	95	90	86	79	73	68	64	60	58	57	54
105	95	90	86	79	73	68	64	60	58	57	54
99	95	90	86	79	73	68	64	60	58	57	54
88	88	88	86	79	73	68	64	60	58	57	54
80	80	80	80	79	73	68	64	60	58	57	54
72	72	72	72	72	72	68	64	60	58	57	54
66	66	66	66	66	66	66	64	60	58	57	54
62	62	62	62	62	62	62	62	60	58	57	54
58	58	58	58	58	58	58	58	58	58	57	54
55	55	55	55	55	55	55	55	55	55	55	54
83	75	72	69	63	58	54	51	48	46	45	43
83	75	72	69	63	58	54	51	48	46	45	43
83	75	72	69	63	58	54	51	48	46	45	43
83	75	72	69	63	58	54	51	48	46	45	43
80	75	72	69	63	58	54	51	48	46	45	43
72	72	72	69	63	58	54	51	48	46	45	43
66	66	66	66	63	58	54	51	48	46	45	43
62	62	62	62	62	58	54	51	48	46	45	43
58	58	58	58	58	58	54	51	48	46	45	43
55	55	55	55	55	55	54	51	48	46	45	43

121	121	115	110	100	93	86	80	75	73	71	67
116	114	113	110	100	93	86	80	75	73	71	67
99	99	99	99	98	93	86	80	75	73	71	67
88	88	88	88	88	88	86	80	75	73	71	67
80	80	80	80	80	80	80	79	75	73	71	67
72	72	72	72	72	72	72	72	72	72	71	67
66	66	66	66	66	66	66	66	66	66	66	66
62	62	62	62	62	62	62	62	62	62	62	62
58	58	58	58	58	58	58	58	58	58	58	58
55	55	55	55	55	55	55	55	55	55	55	55
97	88	84	80	73	68	63	59	56	54	52	50
97	88	84	80	73	68	63	59	56	54	52	50
97	88	84	80	73	68	63	59	56	54	52	50
88	88	84	80	73	68	63	59	56	54	52	50
80	80	80	80	73	68	63	59	56	54	52	50
72	72	72	72	72	68	63	59	56	54	52	50
66	66	66	66	66	66	63	59	56	54	52	50
62	62	62	62	62	62	62	59	56	54	52	50
58	58	58	58	58	58	58	58	56	54	52	50
55	55	55	55	55	55	55	55	55	54	52	50
77	69	66	63	58	54	50	48	44	43	42	40
77	69	66	63	58	54	50	48	44	43	42	40
77	69	66	63	58	54	50	48	44	43	42	40
77	69	66	63	58	54	50	48	44	43	42	40
77	69	66	63	58	54	50	48	44	43	42	40
72	69	66	63	58	54	50	48	44	43	42	40
66	66	66	63	58	54	50	48	44	43	42	40
62	62	62	62	58	54	50	48	44	43	42	40
58	58	58	58	58	54	50	48	44	43	42	40
55	55	55	55	55	54	50	48	44	43	42	40

121	121	121	121	121	120	112	105	98	95	93	88
116	114	114	113	111	109	107	105	98	95	93	88
98	98	98	97	96	94	92	90	88	88	87	85
83	83	83	83	83	83	82	81	79	79	78	77
73	73	73	73	73	73	73	73	72	72	71	70
66	66	66	66	66	66	66	66	66	66	66	65
61	61	61	61	61	61	61	61	61	61	61	61
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
121	111	106	102	93	87	81	75	71	69	67	63
116	111	106	102	93	87	81	75	71	69	67	63
98	98	98	97	93	87	81	75	71	69	67	63
83	83	83	83	83	83	81	75	71	69	67	63
73	73	73	73	73	73	73	73	71	69	67	63
66	66	66	66	66	66	66	66	66	66	66	63
61	61	61	61	61	61	61	61	61	61	61	61
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
98	89	85	82	75	70	65	61	57	55	54	51
98	89	85	82	75	70	65	61	57	55	54	51
98	89	85	82	75	70	65	61	57	55	54	51
83	83	83	82	75	70	65	61	57	55	54	51
73	73	73	73	73	70	65	61	57	55	54	51
66	66	66	66	66	66	65	61	57	55	54	51
61	61	61	61	61	61	61	61	57	55	54	51
56	56	56	56	56	56	56	56	56	55	54	51
53	53	53	53	53	53	53	53	53	53	53	51
50	50	50	50	50	50	50	50	50	50	50	50

121	121	121	121	112	104	97	90	85	82	80	76
113	111	110	109	107	104	97	90	85	82	80	76
98	96	95	94	92	90	88	86	84	82	80	76
83	83	83	83	82	80	79	77	76	75	74	73
73	73	73	73	73	73	72	71	70	69	69	67
66	66	66	66	66	66	66	66	65	64	64	63
61	61	61	61	61	61	61	61	61	61	60	59
56	56	56	56	56	56	56	56	56	56	56	56
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
106	96	92	88	81	75	70	65	61	60	58	55
106	96	92	88	81	75	70	65	61	60	58	55
98	96	92	88	81	75	70	65	61	60	58	55
83	83	83	83	81	75	70	65	61	60	58	55
73	73	73	73	73	73	70	65	61	60	58	55
66	66	66	66	66	66	66	65	61	60	58	55
61	61	61	61	61	61	61	61	61	60	58	55
56	56	56	56	56	56	56	56	56	56	56	55
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
85	77	74	70	65	60	56	53	49	48	48	44
85	77	74	70	65	60	56	53	49	48	48	44
85	77	74	70	65	60	56	53	49	48	48	44
83	77	74	70	65	60	56	53	49	48	48	44
73	73	73	70	65	60	56	53	49	48	48	44
66	66	66	66	65	60	56	53	49	48	48	44
61	61	61	61	61	60	56	53	49	48	48	44
56	56	56	56	56	56	56	53	49	48	48	44
53	53	53	53	53	53	53	53	49	48	48	44
50	50	50	50	50	50	50	50	49	48	48	44

121	121	118	113	104	96	90	84	79	76	74	70
112	109	108	107	104	96	90	84	79	76	74	70
97	95	93	92	90	88	86	83	79	76	74	70
83	83	83	82	80	79	77	75	74	73	72	70
73	73	73	73	73	72	71	70	68	68	67	66
66	66	66	66	66	66	66	65	64	63	63	62
61	61	61	61	61	61	61	61	60	60	59	58
56	56	56	56	56	56	56	56	56	56	56	55
53	53	53	53	53	53	53	53	53	53	53	53
50	50	50	50	50	50	50	50	50	50	50	50
98	89	85	81	75	69	65	60	57	55	54	51
98	89	85	81	75	69	65	60	57	55	54	51
97	89	85	81	75	69	65	60	57	55	54	51
83	83	83	81	75	69	65	60	57	55	54	51
73	73	73	73	73	69	65	60	57	55	54	51
66	66	66	66	66	66	65	60	57	55	54	51
61	61	61	61	61	61	61	60	57	55	54	51
56	56	56	56	56	56	56	56	56	55	54	51
53	53	53	53	53	53	53	53	53	53	53	51
50	50	50	50	50	50	50	50	50	50	50	50
79	71	68	65	60	56	52	49	46	44	43	41
79	71	68	65	60	56	52	49	46	44	43	41
79	71	68	65	60	56	52	49	46	44	43	41
79	71	68	65	60	56	52	49	46	44	43	41
73	71	68	65	60	56	52	49	46	44	43	41
66	66	66	65	60	56	52	49	46	44	43	41
61	61	61	61	60	56	52	49	46	44	43	41
56	56	56	56	56	56	52	49	46	44	43	41
53	53	53	53	53	53	52	49	46	44	43	41
50	50	50	50	50	50	50	49	46	44	43	41

121	119	116	114	109	103	97	93	88	86	84	80
116	111	109	107	103	99	96	92	88	86	84	80
100	97	96	95	92	89	86	84	81	80	79	76
90	88	87	86	83	81	79	77	75	74	73	71
80	80	80	79	77	75	74	72	70	70	69	67
73	73	73	73	72	71	69	68	66	66	65	64
67	67	67	67	67	67	65	64	63	62	62	61
63	63	63	63	63	63	62	61	60	60	59	58
59	59	59	59	59	59	59	58	58	57	57	56
56	56	56	56	56	56	56	56	55	55	54	54
121	119	116	114	109	101	95	89	84	81	79	75
116	111	109	107	103	99	95	89	84	81	79	75
100	97	96	95	92	89	86	84	81	80	79	75
90	88	87	86	83	81	79	77	75	74	73	71
80	80	80	79	77	75	74	72	70	70	69	67
73	73	73	73	72	71	69	68	66	66	65	64
67	67	67	67	67	67	65	64	63	62	62	61
63	63	63	63	63	63	62	61	60	60	59	58
59	59	59	59	59	59	59	58	58	57	57	56
56	56	56	56	56	56	56	56	55	55	54	54
121	119	116	114	109	101	95	89	84	81	79	75
116	111	109	107	103	99	95	89	84	81	79	75
100	97	96	95	92	89	86	84	81	80	79	75
90	88	87	86	83	81	79	77	75	74	73	71
80	80	80	79	77	75	74	72	70	70	69	67
73	73	73	73	72	71	69	68	66	66	65	64
67	67	67	67	67	67	65	64	63	62	62	61
63	63	63	63	63	63	62	61	60	60	59	58
59	59	59	59	59	59	59	58	58	57	57	56
56	56	56	56	56	56	56	56	55	55	54	54

116	111	107	104	97	92	87	82	78	76	74	71
109	105	102	100	96	92	87	82	78	76	74	71
96	93	91	89	86	83	80	78	75	74	72	70
87	84	83	82	79	77	75	72	70	69	68	66
79	78	77	76	74	72	70	68	66	65	64	63
73	72	72	71	69	68	66	64	63	62	61	60
67	67	67	67	65	64	63	61	60	59	59	57
63	63	63	63	62	61	60	59	57	57	56	55
59	59	59	59	59	58	57	56	55	55	54	53
56	56	56	56	56	56	55	54	53	53	52	51
116	111	107	103	95	88	82	77	72	70	68	65
109	105	102	100	95	88	82	77	72	70	68	65
96	93	91	89	86	83	80	77	72	70	68	65
87	84	83	82	79	77	75	72	70	69	68	65
79	78	77	76	74	72	70	68	66	65	64	63
73	72	72	71	69	68	66	64	63	62	61	60
67	67	67	67	65	64	63	61	60	59	59	57
63	63	63	63	62	61	60	59	57	57	56	55
59	59	59	59	59	58	57	56	55	55	54	53
56	56	56	56	56	56	55	54	53	53	52	51
116	111	107	103	95	88	82	77	72	70	68	65
109	105	102	100	95	88	82	77	72	70	68	65
96	93	91	89	86	83	80	77	72	70	68	65
87	84	83	82	79	77	75	72	70	69	68	65
79	78	77	76	74	72	70	68	66	65	64	63
73	72	72	71	69	68	66	64	63	62	61	60
67	67	67	67	65	64	63	61	60	59	59	57
63	63	63	63	62	61	60	59	57	57	56	55
59	59	59	59	59	58	57	56	55	55	54	53
56	56	56	56	56	56	55	54	53	53	52	51

112	105	101	98	92	86	81	77	73	71	69	66
106	101	98	96	92	86	81	77	73	71	69	66
93	90	88	87	83	80	77	74	71	70	69	66
85	82	81	79	77	74	72	70	67	66	65	63
78	76	75	74	72	70	68	66	64	63	62	60
73	71	70	69	68	66	64	62	61	60	59	58
67	67	66	65	64	63	61	60	58	57	57	55
63	63	63	62	61	60	58	57	56	55	55	53
59	59	59	59	58	57	56	55	54	53	53	51
56	56	56	56	56	55	54	53	52	51	51	50
112	104	99	95	88	82	76	71	67	65	64	60
106	101	98	95	88	82	76	71	67	65	64	60
93	90	88	87	83	80	76	71	67	65	64	60
85	82	81	79	77	74	72	70	67	65	64	60
78	76	75	74	72	70	68	66	64	63	62	60
73	71	70	69	68	66	64	62	61	60	59	58
67	67	66	65	64	63	61	60	58	57	57	55
63	63	63	62	61	60	58	57	56	55	55	53
59	59	59	59	58	57	56	55	54	53	53	51
56	56	56	56	56	55	54	53	52	51	51	50
112	104	99	95	88	82	76	71	67	65	64	60
106	101	98	95	88	82	76	71	67	65	64	60
93	90	88	87	83	80	76	71	67	65	64	60
85	82	81	79	77	74	72	70	67	65	64	60
78	76	75	74	72	70	68	66	64	63	62	60
73	71	70	69	68	66	64	62	61	60	59	58
67	67	66	65	64	63	61	60	58	57	57	55
63	63	63	62	61	60	58	57	56	55	55	53
59	59	59	59	58	57	56	55	54	53	53	51
56	56	56	56	56	55	54	53	52	51	51	50

109	109	105	100	91	84	78	72	68	66	64	60
94	94	93	93	91	84	78	72	68	66	64	60
77	77	77	77	77	76	75	72	68	66	64	60
65	65	65	65	65	65	65	65	65	64	64	60
57	57	57	57	57	57	57	57	57	57	57	57
51	51	51	51	51	51	51	51	51	51	51	51
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
41	41	41	41	41	41	41	41	41	41	41	41
39	39	39	39	39	39	39	39	39	39	39	39
88	79	75	72	66	61	57	53	50	48	48	44
88	79	75	72	66	61	57	53	50	48	48	44
77	77	75	72	66	61	57	53	50	48	48	44
65	65	65	65	65	61	57	53	50	48	48	44
57	57	57	57	57	57	57	53	50	48	48	44
51	51	51	51	51	51	51	51	50	48	48	44
48	48	48	48	48	48	48	48	48	48	48	44
44	44	44	44	44	44	44	44	44	44	44	44
41	41	41	41	41	41	41	41	41	41	41	41
39	39	39	39	39	39	39	39	39	39	39	39
69	62	59	57	52	48	45	42	39	38	37	35
69	62	59	57	52	48	45	42	39	38	37	35
69	62	59	57	52	48	45	42	39	38	37	35
65	62	59	57	52	48	45	42	39	38	37	35
57	57	57	57	52	48	45	42	39	38	37	35
51	51	51	51	51	48	45	42	39	38	37	35
48	48	48	48	48	48	45	42	39	38	37	35
44	44	44	44	44	44	44	42	39	38	37	35
41	41	41	41	41	41	41	41	39	38	37	35
39	39	39	39	39	39	39	39	39	38	37	35

105	94	89	85	78	72	67	62	58	57	55	52
93	92	89	85	78	72	67	62	58	57	55	52
77	77	77	77	75	72	67	62	58	57	55	52
65	65	65	65	65	65	64	62	58	57	55	52
57	57	57	57	57	57	57	57	57	56	55	52
51	51	51	51	51	51	51	51	51	51	51	51
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
41	41	41	41	41	41	41	41	41	41	41	41
39	39	39	39	39	39	39	39	39	39	39	39
75	68	65	62	57	52	49	46	43	42	40	38
75	68	65	62	57	52	49	46	43	42	40	38
75	68	65	62	57	52	49	46	43	42	40	38
65	65	65	62	57	52	49	46	43	42	40	38
57	57	57	57	57	52	49	46	43	42	40	38
51	51	51	51	51	51	49	46	43	42	40	38
48	48	48	48	48	48	48	46	43	42	40	38
44	44	44	44	44	44	44	44	43	42	40	38
41	41	41	41	41	41	41	41	41	41	40	38
39	39	39	39	39	39	39	39	39	39	39	38
59	54	51	49	45	42	39	36	34	33	32	30
59	54	51	49	45	42	39	36	34	33	32	30
59	54	51	49	45	42	39	36	34	33	32	30
59	54	51	49	45	42	39	36	34	33	32	30
57	54	51	49	45	42	39	36	34	33	32	30
51	51	51	49	45	42	39	36	34	33	32	30
48	48	48	48	45	42	39	36	34	33	32	30
44	44	44	44	44	42	39	36	34	33	32	30
41	41	41	41	41	41	39	36	34	33	32	30
39	39	39	39	39	39	39	36	34	33	32	30

96	86	82	78	72	66	62	57	54	52	51	48
93	86	82	78	72	66	62	57	54	52	51	48
77	77	76	75	72	66	62	57	54	52	51	48
65	65	65	65	65	64	62	57	54	52	51	48
57	57	57	57	57	57	57	57	54	52	51	48
51	51	51	51	51	51	51	51	51	51	51	48
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
41	41	41	41	41	41	41	41	41	41	41	41
39	39	39	39	39	39	39	39	39	39	39	39
69	63	60	57	52	49	45	42	40	38	37	35
69	63	60	57	52	49	45	42	40	38	37	35
69	63	60	57	52	49	45	42	40	38	37	35
65	63	60	57	52	49	45	42	40	38	37	35
57	57	57	57	52	49	45	42	40	38	37	35
51	51	51	51	51	49	45	42	40	38	37	35
48	48	48	48	48	48	45	42	40	38	37	35
44	44	44	44	44	44	44	42	40	38	37	35
41	41	41	41	41	41	41	41	40	38	37	35
39	39	39	39	39	39	39	39	39	38	37	35
55	50	48	45	42	39	36	34	32	31	30	28
55	50	48	45	42	39	36	34	32	31	30	28
55	50	48	45	42	39	36	34	32	31	30	28
55	50	48	45	42	39	36	34	32	31	30	28
55	50	48	45	42	39	36	34	32	31	30	28
51	50	48	45	42	39	36	34	32	31	30	28
48	48	48	45	42	39	36	34	32	31	30	28
44	44	44	44	42	39	36	34	32	31	30	28
41	41	41	41	41	39	36	34	32	31	30	28
39	39	39	39	39	39	36	34	32	31	30	28

109	105	103	101	93	86	80	75	70	68	66	63
87	85	84	83	81	79	77	75	70	68	66	63
70	70	70	70	68	67	66	64	63	63	62	61
59	59	59	59	59	59	58	58	57	56	56	55
52	52	52	52	52	52	52	52	52	51	51	50
48	48	48	48	48	48	48	48	48	48	48	48
43	43	43	43	43	43	43	43	43	43	43	43
40	40	40	40	40	40	40	40	40	40	40	40
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
88	79	76	73	67	62	58	54	51	49	48	45
87	79	76	73	67	62	58	54	51	49	48	45
70	70	70	70	67	62	58	54	51	49	48	45
59	59	59	59	59	59	58	54	51	49	48	45
52	52	52	52	52	52	52	52	51	49	48	45
48	48	48	48	48	48	48	48	48	48	48	45
43	43	43	43	43	43	43	43	43	43	43	43
40	40	40	40	40	40	40	40	40	40	40	40
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
70	64	61	58	54	50	46	43	41	40	38	36
70	64	61	58	54	50	46	43	41	40	38	36
70	64	61	58	54	50	46	43	41	40	38	36
59	59	59	58	54	50	46	43	41	40	38	36
52	52	52	52	52	50	46	43	41	40	38	36
48	48	48	48	48	48	46	43	41	40	38	36
43	43	43	43	43	43	43	43	41	40	38	36
40	40	40	40	40	40	40	40	40	40	38	36
38	38	38	38	38	38	38	38	38	38	38	36
36	36	36	36	36	36	36	36	36	36	36	36

103	96	91	87	80	74	69	65	61	59	57	54
84	82	80	79	77	74	69	65	61	59	57	54
70	69	68	67	66	64	63	61	60	59	57	54
59	59	59	59	58	57	56	55	54	54	53	52
52	52	52	52	52	52	51	51	50	49	49	48
48	48	48	48	48	48	48	48	46	46	46	45
43	43	43	43	43	43	43	43	43	43	43	42
40	40	40	40	40	40	40	40	40	40	40	40
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
76	68	65	63	58	53	50	48	44	42	41	39
76	68	65	63	58	53	50	48	44	42	41	39
70	68	65	63	58	53	50	48	44	42	41	39
59	59	59	59	58	53	50	48	44	42	41	39
52	52	52	52	52	52	50	48	44	42	41	39
48	48	48	48	48	48	48	48	44	42	41	39
43	43	43	43	43	43	43	43	43	42	41	39
40	40	40	40	40	40	40	40	40	40	40	39
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
61	55	53	50	46	43	40	37	35	34	33	31
61	55	53	50	46	43	40	37	35	34	33	31
61	55	53	50	46	43	40	37	35	34	33	31
59	55	53	50	46	43	40	37	35	34	33	31
52	52	52	50	46	43	40	37	35	34	33	31
48	48	48	48	46	43	40	37	35	34	33	31
43	43	43	43	43	43	40	37	35	34	33	31
40	40	40	40	40	40	40	37	35	34	33	31
38	38	38	38	38	38	38	37	35	34	33	31
36	36	36	36	36	36	36	36	35	34	33	31

98	88	84	81	74	69	64	60	56	55	53	50
82	80	78	77	74	69	64	60	56	55	53	50
69	68	67	66	64	63	61	59	56	55	53	50
59	59	59	59	57	56	55	54	53	52	52	50
52	52	52	52	52	51	51	50	49	48	48	48
48	48	48	48	48	48	48	46	45	45	45	44
43	43	43	43	43	43	43	43	43	42	42	41
40	40	40	40	40	40	40	40	40	40	40	39
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
70	63	61	58	53	49	46	43	41	39	38	36
70	63	61	58	53	49	46	43	41	39	38	36
69	63	61	58	53	49	46	43	41	39	38	36
59	59	59	58	53	49	46	43	41	39	38	36
52	52	52	52	52	49	46	43	41	39	38	36
48	48	48	48	48	48	46	43	41	39	38	36
43	43	43	43	43	43	43	43	41	39	38	36
40	40	40	40	40	40	40	40	40	39	38	36
38	38	38	38	38	38	38	38	38	38	38	36
36	36	36	36	36	36	36	36	36	36	36	36
56	51	49	48	43	40	37	35	33	32	31	29
56	51	49	48	43	40	37	35	33	32	31	29
56	51	49	48	43	40	37	35	33	32	31	29
56	51	49	48	43	40	37	35	33	32	31	29
52	51	49	48	43	40	37	35	33	32	31	29
48	48	48	48	43	40	37	35	33	32	31	29
43	43	43	43	43	40	37	35	33	32	31	29
40	40	40	40	40	40	37	35	33	32	31	29
38	38	38	38	38	38	37	35	33	32	31	29
36	36	36	36	36	36	36	35	33	32	31	29

93	87	85	82	78	73	70	66	63	61	60	57
83	80	78	77	74	71	68	66	63	61	60	57
72	70	69	68	66	64	62	60	58	57	56	54
64	63	62	61	60	58	57	55	54	53	52	51
57	57	57	56	55	54	53	51	50	50	49	48
52	52	52	52	51	50	49	48	48	48	46	45
48	48	48	48	48	48	48	46	45	45	44	43
45	45	45	45	45	45	44	44	43	42	42	41
42	42	42	42	42	42	42	42	41	41	40	40
40	40	40	40	40	40	40	40	39	39	39	38
93	87	85	82	78	72	68	63	60	58	56	53
83	80	78	77	74	71	68	63	60	58	56	53
72	70	69	68	66	64	62	60	58	57	56	53
64	63	62	61	60	58	57	55	54	53	52	51
57	57	57	56	55	54	53	51	50	50	49	48
52	52	52	52	51	50	49	48	48	48	46	45
48	48	48	48	48	48	48	46	45	45	44	43
45	45	45	45	45	45	44	44	43	42	42	41
42	42	42	42	42	42	42	42	41	41	40	40
40	40	40	40	40	40	40	40	39	39	39	38
93	87	85	82	78	72	68	63	60	58	56	53
83	80	78	77	74	71	68	63	60	58	56	53
72	70	69	68	66	64	62	60	58	57	56	53
64	63	62	61	60	58	57	55	54	53	52	51
57	57	57	56	55	54	53	51	50	50	49	48
52	52	52	52	51	50	49	48	48	48	46	45
48	48	48	48	48	48	48	46	45	45	44	43
45	45	45	45	45	45	44	44	43	42	42	41
42	42	42	42	42	42	42	42	41	41	40	40
40	40	40	40	40	40	40	40	39	39	39	38
93	87	85	82	78	72	68	63	60	58	56	53
83	80	78	77	74	71	68	63	60	58	56	53
72	70	69	68	66	64	62	60	58	57	56	53
64	63	62	61	60	58	57	55	54	53	52	51
57	57	57	56	55	54	53	51	50	50	49	48
52	52	52	52	51	50	49	48	48	48	46	45
48	48	48	48	48	48	48	46	45	45	44	43
45	45	45	45	45	45	44	44	43	42	42	41
42	42	42	42	42	42	42	42	41	41	40	40
40	40	40	40	40	40	40	40	39	39	39	38

85	79	77	74	70	66	62	59	56	54	53	50
78	75	73	71	68	65	62	59	56	54	53	50
69	66	65	64	62	59	57	55	53	52	52	50
62	60	59	58	57	55	53	52	50	49	48	48
57	55	55	54	53	51	50	49	48	48	46	45
52	52	51	51	49	48	48	46	45	44	44	43
48	48	48	48	48	46	45	44	43	42	42	41
45	45	45	45	44	43	43	42	41	40	40	39
42	42	42	42	42	42	41	40	39	39	39	38
40	40	40	40	40	40	39	39	38	38	37	37
85	79	76	73	68	63	59	55	52	50	49	46
78	75	73	71	68	63	59	55	52	50	49	46
69	66	65	64	62	59	57	55	52	50	49	46
62	60	59	58	57	55	53	52	50	49	48	46
57	55	55	54	53	51	50	49	48	48	46	45
52	52	51	51	49	48	48	46	45	44	44	43
48	48	48	48	48	46	45	44	43	42	42	41
45	45	45	45	44	43	43	42	41	40	40	39
42	42	42	42	42	42	41	40	39	39	39	38
40	40	40	40	40	40	39	39	38	38	37	37
85	79	76	73	68	63	59	55	52	50	49	46
78	75	73	71	68	63	59	55	52	50	49	46
69	66	65	64	62	59	57	55	52	50	49	46
62	60	59	58	57	55	53	52	50	49	48	46
57	55	55	54	53	51	50	49	48	48	46	45
52	52	51	51	49	48	48	46	45	44	44	43
48	48	48	48	48	46	45	44	43	42	42	41
45	45	45	45	44	43	43	42	41	40	40	39
42	42	42	42	42	42	41	40	39	39	39	38
40	40	40	40	40	40	39	39	38	38	37	37

80	75	72	70	66	62	58	55	52	51	50	48
75	72	70	69	65	62	58	55	52	51	50	48
67	64	63	62	59	57	55	53	51	50	49	48
60	59	58	57	55	53	51	50	48	48	46	45
56	54	53	53	51	50	48	48	46	45	44	43
52	51	50	49	48	48	46	45	43	43	42	41
48	48	48	48	46	45	44	43	41	41	40	39
45	45	45	44	43	43	42	41	40	39	39	38
42	42	42	42	42	41	40	39	38	38	38	37
40	40	40	40	40	39	38	38	37	37	36	36
80	74	71	68	63	58	54	51	48	48	45	43
75	72	70	68	63	58	54	51	48	48	45	43
67	64	63	62	59	57	54	51	48	48	45	43
60	59	58	57	55	53	51	50	48	48	45	43
56	54	53	53	51	50	48	48	46	45	44	43
52	51	50	49	48	48	46	45	43	43	42	41
48	48	48	48	46	45	44	43	41	41	40	39
45	45	45	44	43	43	42	41	40	39	39	38
42	42	42	42	42	41	40	39	38	38	38	37
40	40	40	40	40	39	38	38	37	37	36	36
80	74	71	68	63	58	54	51	48	48	45	43
75	72	70	68	63	58	54	51	48	48	45	43
67	64	63	62	59	57	54	51	48	48	45	43
60	59	58	57	55	53	51	50	48	48	45	43
56	54	53	53	51	50	48	48	46	45	44	43
52	51	50	49	48	48	46	45	43	43	42	41
48	48	48	48	46	45	44	43	41	41	40	39
45	45	45	44	43	43	42	41	40	39	39	38
42	42	42	42	42	41	40	39	38	38	38	37
40	40	40	40	40	39	38	38	37	37	36	36

98	98	98	98	98	95	88	82	76	74	72	68
95	95	95	95	94	93	88	82	76	74	72	68
78	78	78	78	78	78	78	77	76	74	72	68
65	65	65	65	65	65	65	65	65	65	65	65
58	58	58	58	58	58	58	58	58	58	58	58
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
98	89	85	81	74	68	64	59	56	54	52	50
95	89	85	81	74	68	64	59	56	54	52	50
78	78	78	78	74	68	64	59	56	54	52	50
65	65	65	65	65	65	64	59	56	54	52	50
58	58	58	58	58	58	58	58	56	54	52	50
52	52	52	52	52	52	52	52	52	52	52	50
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
78	70	67	64	59	54	50	48	44	43	42	39
78	70	67	64	59	54	50	48	44	43	42	39
78	70	67	64	59	54	50	48	44	43	42	39
65	65	65	64	59	54	50	48	44	43	42	39
58	58	58	58	58	54	50	48	44	43	42	39
52	52	52	52	52	52	50	48	44	43	42	39
48	48	48	48	48	48	48	48	44	43	42	39
44	44	44	44	44	44	44	44	44	43	42	39
42	42	42	42	42	42	42	42	42	42	42	39
39	39	39	39	39	39	39	39	39	39	39	39

98	98	98	93	85	78	73	68	64	62	60	57
95	94	93	93	85	78	73	68	64	62	60	57
78	78	78	78	77	76	73	68	64	62	60	57
65	65	65	65	65	65	65	65	64	62	60	57
58	58	58	58	58	58	58	58	58	58	58	57
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
82	74	71	67	62	57	53	50	48	45	44	42
82	74	71	67	62	57	53	50	48	45	44	42
78	74	71	67	62	57	53	50	48	45	44	42
65	65	65	65	62	57	53	50	48	45	44	42
58	58	58	58	58	57	53	50	48	45	44	42
52	52	52	52	52	52	52	50	48	45	44	42
48	48	48	48	48	48	48	48	48	45	44	42
44	44	44	44	44	44	44	44	44	44	44	42
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
65	58	56	53	49	45	42	40	37	36	35	33
65	58	56	53	49	45	42	40	37	36	35	33
65	58	56	53	49	45	42	40	37	36	35	33
65	58	56	53	49	45	42	40	37	36	35	33
58	58	56	53	49	45	42	40	37	36	35	33
52	52	52	52	49	45	42	40	37	36	35	33
48	48	48	48	48	45	42	40	37	36	35	33
44	44	44	44	44	44	42	40	37	36	35	33
42	42	42	42	42	42	42	40	37	36	35	33
39	39	39	39	39	39	39	39	37	36	35	33

98	93	89	85	78	72	66	62	58	56	55	52
94	93	89	85	78	72	66	62	58	56	55	52
78	78	78	77	76	72	66	62	58	56	55	52
65	65	65	65	65	65	65	62	58	56	55	52
58	58	58	58	58	58	58	58	57	56	55	52
52	52	52	52	52	52	52	52	52	52	52	52
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
42	42	42	42	42	42	42	42	42	42	42	42
39	39	39	39	39	39	39	39	39	39	39	39
75	68	64	62	57	52	49	46	43	42	40	38
75	68	64	62	57	52	49	46	43	42	40	38
75	68	64	62	57	52	49	46	43	42	40	38
65	65	64	62	57	52	49	46	43	42	40	38
58	58	58	58	57	52	49	46	43	42	40	38
52	52	52	52	52	52	49	46	43	42	40	38
48	48	48	48	48	48	48	46	43	42	40	38
44	44	44	44	44	44	44	44	43	42	40	38
42	42	42	42	42	42	42	42	42	42	40	38
39	39	39	39	39	39	39	39	39	39	39	38
59	54	51	49	45	42	39	36	34	33	32	30
59	54	51	49	45	42	39	36	34	33	32	30
59	54	51	49	45	42	39	36	34	33	32	30
59	54	51	49	45	42	39	36	34	33	32	30
58	54	51	49	45	42	39	36	34	33	32	30
52	52	51	49	45	42	39	36	34	33	32	30
48	48	48	48	45	42	39	36	34	33	32	30
44	44	44	44	44	42	39	36	34	33	32	30
42	42	42	42	42	42	39	36	34	33	32	30
39	39	39	39	39	39	39	36	34	33	32	30

98	98	98	98	98	97	90	84	79	76	74	70
90	88	87	86	85	83	81	79	77	76	74	70
71	71	71	71	71	70	68	67	66	65	65	64
60	60	60	60	60	60	60	60	59	58	58	57
53	53	53	53	53	53	53	53	53	53	53	52
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
41	41	41	41	41	41	41	41	41	41	41	41
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
98	89	85	81	75	69	64	60	57	55	53	51
90	88	85	81	75	69	64	60	57	55	53	51
71	71	71	71	71	69	64	60	57	55	53	51
60	60	60	60	60	60	60	60	57	55	53	51
53	53	53	53	53	53	53	53	53	53	53	51
48	48	48	48	48	48	48	48	48	48	48	48
44	44	44	44	44	44	44	44	44	44	44	44
41	41	41	41	41	41	41	41	41	41	41	41
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
79	71	68	65	60	56	52	48	46	44	43	41
79	71	68	65	60	56	52	48	46	44	43	41
71	71	68	65	60	56	52	48	46	44	43	41
60	60	60	60	60	56	52	48	46	44	43	41
53	53	53	53	53	53	52	48	46	44	43	41
48	48	48	48	48	48	48	48	46	44	43	41
44	44	44	44	44	44	44	44	44	44	43	41
41	41	41	41	41	41	41	41	41	41	41	41
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36

98	98	98	95	87	81	75	70	66	64	62	59
87	84	83	82	80	78	75	70	66	64	62	59
71	71	70	69	68	67	65	64	62	62	61	59
60	60	60	60	60	59	58	57	56	56	55	54
53	53	53	53	53	53	53	52	51	51	51	50
48	48	48	48	48	48	48	48	48	48	48	46
44	44	44	44	44	44	44	44	44	44	44	44
41	41	41	41	41	41	41	41	41	41	41	41
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
82	75	71	68	63	58	54	51	48	46	45	43
82	75	71	68	63	58	54	51	48	46	45	43
71	71	70	68	63	58	54	51	48	46	45	43
60	60	60	60	60	58	54	51	48	46	45	43
53	53	53	53	53	53	53	51	48	46	45	43
48	48	48	48	48	48	48	48	48	46	45	43
44	44	44	44	44	44	44	44	44	44	44	43
41	41	41	41	41	41	41	41	41	41	41	41
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
66	60	57	55	50	48	44	41	38	37	36	34
66	60	57	55	50	48	44	41	38	37	36	34
66	60	57	55	50	48	44	41	38	37	36	34
60	60	57	55	50	48	44	41	38	37	36	34
53	53	53	53	50	48	44	41	38	37	36	34
48	48	48	48	48	48	44	41	38	37	36	34
44	44	44	44	44	44	44	41	38	37	36	34
41	41	41	41	41	41	41	41	38	37	36	34
38	38	38	38	38	38	38	38	38	37	36	34
36	36	36	36	36	36	36	36	36	36	36	34



98	95	91	87	80	74	69	64	61	59	57	54
85	82	81	80	77	74	69	64	61	59	57	54
71	69	69	68	66	65	63	62	60	59	57	54
60	60	60	60	59	58	57	56	55	54	53	52
53	53	53	53	53	53	52	51	50	50	49	48
48	48	48	48	48	48	48	48	48	46	46	45
44	44	44	44	44	44	44	44	44	44	43	43
41	41	41	41	41	41	41	41	41	41	41	41
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
76	68	65	63	58	53	50	48	44	42	41	39
76	68	65	63	58	53	50	48	44	42	41	39
71	68	65	63	58	53	50	48	44	42	41	39
60	60	60	60	58	53	50	48	44	42	41	39
53	53	53	53	53	53	50	48	44	42	41	39
48	48	48	48	48	48	48	48	44	42	41	39
44	44	44	44	44	44	44	44	44	42	41	39
41	41	41	41	41	41	41	41	41	41	41	39
38	38	38	38	38	38	38	38	38	38	38	38
36	36	36	36	36	36	36	36	36	36	36	36
61	55	52	50	46	43	40	37	35	34	33	31
61	55	52	50	46	43	40	37	35	34	33	31
61	55	52	50	46	43	40	37	35	34	33	31
60	55	52	50	46	43	40	37	35	34	33	31
53	53	52	50	46	43	40	37	35	34	33	31
48	48	48	48	46	43	40	37	35	34	33	31
44	44	44	44	44	43	40	37	35	34	33	31
41	41	41	41	41	41	40	37	35	34	33	31
38	38	38	38	38	38	38	37	35	34	33	31
36	36	36	36	36	36	36	36	35	34	33	31

98	94	92	89	84	80	76	72	69	67	66	63
87	84	82	81	78	76	73	70	68	67	66	63
74	73	72	71	69	67	65	63	62	61	60	58
66	65	64	64	62	61	59	58	57	56	55	54
58	58	58	58	57	56	55	54	53	52	52	51
53	53	53	53	53	52	51	50	50	49	49	48
49	49	49	49	49	49	48	48	48	46	46	45
45	45	45	45	45	45	45	45	45	44	44	43
43	43	43	43	43	43	43	43	43	42	42	41
40	40	40	40	40	40	40	40	40	40	40	40
98	94	92	89	84	80	75	71	67	65	63	60
87	84	82	81	78	76	73	70	67	65	63	60
74	73	72	71	69	67	65	63	62	61	60	58
66	65	64	64	62	61	59	58	57	56	55	54
58	58	58	58	57	56	55	54	53	52	52	51
53	53	53	53	53	52	51	50	50	49	49	48
49	49	49	49	49	49	48	48	48	46	46	45
45	45	45	45	45	45	45	45	45	44	44	43
43	43	43	43	43	43	43	43	43	42	42	41
40	40	40	40	40	40	40	40	40	40	40	40
98	94	92	89	84	80	75	71	67	65	63	60
87	84	82	81	78	76	73	70	67	65	63	60
74	73	72	71	69	67	65	63	62	61	60	58
66	65	64	64	62	61	59	58	57	56	55	54
58	58	58	58	57	56	55	54	53	52	52	51
53	53	53	53	53	52	51	50	50	49	49	48
49	49	49	49	49	49	48	48	48	46	46	45
45	45	45	45	45	45	45	45	45	44	44	43
43	43	43	43	43	43	43	43	43	42	42	41
40	40	40	40	40	40	40	40	40	40	40	40

90	84	82	79	75	70	67	63	60	58	57	54
81	78	77	75	72	69	66	63	60	58	57	54
71	69	68	67	64	62	60	58	56	55	55	53
64	62	61	61	59	57	56	54	53	52	51	50
58	57	56	56	55	53	52	51	49	49	48	48
53	53	53	52	51	50	49	48	48	46	46	45
49	49	49	49	48	48	46	45	44	44	44	43
45	45	45	45	45	45	44	43	42	42	42	41
43	43	43	43	43	43	42	41	41	40	40	39
40	40	40	40	40	40	40	40	39	39	39	38
90	84	82	79	74	68	64	60	56	55	53	50
81	78	77	75	72	68	64	60	56	55	53	50
71	69	68	67	64	62	60	58	56	55	53	50
64	62	61	61	59	57	56	54	53	52	51	50
58	57	56	56	55	53	52	51	49	49	48	48
53	53	53	52	51	50	49	48	48	46	46	45
49	49	49	49	48	48	46	45	44	44	44	43
45	45	45	45	45	45	44	43	42	42	42	41
43	43	43	43	43	43	42	41	41	40	40	39
40	40	40	40	40	40	40	40	39	39	39	38
90	84	82	79	74	68	64	60	56	55	53	50
81	78	77	75	72	68	64	60	56	55	53	50
71	69	68	67	64	62	60	58	56	55	53	50
64	62	61	61	59	57	56	54	53	52	51	50
58	57	56	56	55	53	52	51	49	49	48	48
53	53	53	52	51	50	49	48	48	46	46	45
49	49	49	49	48	48	46	45	44	44	44	43
45	45	45	45	45	45	44	43	42	42	42	41
43	43	43	43	43	43	42	41	41	40	40	39
40	40	40	40	40	40	40	40	39	39	39	38

85	79	77	74	70	66	62	59	56	54	53	50
79	75	73	72	69	66	62	59	56	54	53	50
69	67	66	64	62	60	58	56	54	53	52	50
62	61	60	59	57	55	54	52	50	50	49	48
57	56	55	54	53	52	50	49	48	48	46	45
53	52	52	51	50	49	48	46	45	45	44	43
49	49	49	48	48	46	45	44	43	43	42	41
45	45	45	45	45	44	43	42	41	41	40	39
43	43	43	43	43	42	41	40	40	39	39	38
40	40	40	40	40	40	40	39	38	38	38	37
85	79	76	73	68	63	59	55	52	50	49	46
79	75	73	72	68	63	59	55	52	50	49	46
69	67	66	64	62	60	58	55	52	50	49	46
62	61	60	59	57	55	54	52	50	50	49	46
57	56	55	54	53	52	50	49	48	48	46	45
53	52	52	51	50	49	48	46	45	45	44	43
49	49	49	48	48	46	45	44	43	43	42	41
45	45	45	45	45	44	43	42	41	41	40	39
43	43	43	43	43	42	41	40	40	39	39	38
40	40	40	40	40	40	40	39	38	38	38	37
85	79	76	73	68	63	59	55	52	50	49	46
79	75	73	72	68	63	59	55	52	50	49	46
69	67	66	64	62	60	58	55	52	50	49	46
62	61	60	59	57	55	54	52	50	50	49	46
57	56	55	54	53	52	50	49	48	48	46	45
53	52	52	51	50	49	48	46	45	45	44	43
49	49	49	48	48	46	45	44	43	43	42	41
45	45	45	45	45	44	43	42	41	41	40	39
43	43	43	43	43	42	41	40	40	39	39	38
40	40	40	40	40	40	40	39	38	38	38	37
85	79	76	73	68	63	59	55	52	50	49	46
79	75	73	72	68	63	59	55	52	50	49	46
69	67	66	64	62	60	58	55	52	50	49	46
62	61	60	59	57	55	54	52	50	50	49	46
57	56	55	54	53	52	50	49	48	48	46	45
53	52	52	51	50	49	48	46	45	45	44	43
49	49	49	48	48	46	45	44	43	43	42	41
45	45	45	45	45	44	43	42	41	41	40	39
43	43	43	43	43	42	41	40	40	39	39	38
40	40	40	40	40	40	40	39	38	38	38	37

ITEM NO.	DESCRIPTION	QTY.
1	QRAIL, STANDARD, AL, MILL	1



- NOTES:
1. AVAILABLE IN 14' AND 17' - 4" LENGTHS
 2. AVAILABLE IN MILL FINISH AND BLACK FINISH

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF QUICK MOUNT PV. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF QUICK MOUNT PV IS PROHIBITED. COPYRIGHT © 2016 QUICK MOUNT PV

DO NOT SCALE DRAWING

Quick Mount PV[®]			
TITLE:			
QMR-RS: QRAIL STANDARD			
UNLESS OTHERWISE SPECIFIED:		SIZE	DRAWN BY: DFM
DIMENSIONS ARE IN INCHES		A	DATE: 12/22/2017
TOLERANCES:			REV 1
FRACTIONAL $\pm 1/8$			
TWO PLACE DECIMAL $\pm .19$		SCALE: 1:1	WEIGHT: 0.65
THREE PLACE DECIMAL $\pm .094$		SHEET 1 OF 1	